

連續自動監測紀錄月報表

中華民國111年11月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.02	52.62	6.91	10.10	1.48	79766.40	18.41	11.16	0.98	182.89	13.26
02	3.33	52.96	7.83	10.08	1.48	78952.84	18.27	11.60	0.98	181.49	13.04
03	3.25	49.06	9.50	9.84	1.47	79908.59	18.47	11.60	0.98	182.93	12.99
04	3.16	55.74	7.87	10.06	1.43	79512.67	18.16	11.73	0.96	181.97	13.11
05	3.41	62.92	7.73	10.13	1.41	79179.55	17.53	11.86	0.94	181.19	13.01
06	3.35	52.17	7.12	9.97	1.46	80282.27	18.08	11.54	0.97	182.51	13.13
07	3.44	49.82	7.55	10.00	1.51	79385.16	17.98	11.85	1.00	181.51	12.98
08	3.44	47.59	6.78	9.88	1.51	79182.84	18.35	11.86	1.00	180.93	12.85
09	3.56	50.97	7.06	10.01	1.57	78878.88	17.61	11.02	1.05	181.30	12.83
10	3.71	49.05	6.85	9.86	1.53	78994.09	17.30	11.25	1.02	179.63	12.58
11	3.72	52.62	8.08	10.02	1.52	78550.51	17.64	16.33	1.01	181.55	12.81
12	4.05	51.39	8.13	10.07	1.44	78014.82	17.07	11.90	0.96	180.25	12.66
13	3.75	51.01	7.00	10.07	1.37	78648.13	17.49	11.53	0.91	181.55	12.86
14	3.85	48.57	6.25	9.97	1.43	78741.76	17.33	11.81	0.96	180.89	12.70
15	3.54	48.05	6.54	9.89	1.48	79340.73	17.99	11.32	0.98	182.10	12.85
16	3.44	47.23	8.17	9.93	1.47	79514.91	17.89	11.67	0.98	182.32	12.92
17	3.24	47.14	6.93	9.85	1.47	78825.55	18.01	11.84	0.98	180.53	12.68
18	3.29	46.44	8.00	10.11	1.46	78643.44	17.69	11.44	0.97	182.39	12.96
19	3.36	45.15	6.13	10.04	1.52	78818.01	17.81	11.77	1.01	182.01	12.91
20	3.41	43.68	6.63	9.97	1.47	79822.51	18.08	11.86	0.98	183.48	13.08
21	3.24	43.25	5.12	9.96	1.45	79158.97	17.91	11.00	0.96	182.23	12.89
22	3.01	43.76	8.12	10.14	1.47	79067.55	17.97	10.82	0.98	184.50	13.18
23	3.06	41.14	7.01	10.04	1.43	79806.63	18.05	11.40	0.95	183.66	13.15
24	3.21	41.91	5.48	10.05	1.40	79121.76	17.72	11.76	0.93	181.69	12.95
25	2.72	44.69	6.60	10.12	1.34	78895.16	18.30	11.50	0.90	183.25	13.13
26	2.66	43.58	6.86	10.02	1.33	79366.04	18.28	11.75	0.89	182.70	13.08
27	2.52	42.25	5.80	10.04	1.42	79554.41	18.35	11.09	0.94	183.92	13.18
28	2.67	40.55	6.22	9.91	1.45	79207.20	18.40	11.69	0.97	183.21	12.94
29	2.56	40.90	7.83	10.10	1.49	78471.59	18.53	11.71	0.99	183.81	13.10
30	2.75	41.62	7.34	10.24	1.42	78753.97	17.31	11.79	0.94	182.18	13.07
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.26	47.59	7.11	10.02	1.46	79145.56	17.93	11.72	0.97	182.15	12.96
最大值	4.05	62.92	9.50	10.24	1.57	80282.27	18.53	16.33	1.05	184.50	13.26
發生日期											
最小值	2.52	40.55	5.12	9.84	1.33	78014.82	17.07	10.82	0.89	179.63	12.58
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國111年11月30日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.78	63.18	5.71	11.05	1.65	79713.40	17.84	11.40	1.10	195.27	14.81
02	3.88	62.24	6.04	11.02	1.70	79618.83	17.84	11.42	1.14	193.95	14.70
03	3.95	59.87	7.75	10.89	1.72	79749.30	17.89	11.62	1.15	193.90	14.55
04	3.50	63.87	6.82	11.10	1.63	79604.33	17.40	11.37	1.09	194.75	14.77
05	4.26	63.36	7.87	11.02	1.57	79586.13	16.95	11.85	1.05	192.80	14.51
06	3.85	61.33	7.48	10.73	1.55	81523.94	17.73	11.38	1.03	194.09	14.62
07	4.03	59.99	7.98	10.78	1.49	79791.25	17.61	11.63	0.99	191.81	14.28
08	3.46	59.79	6.83	10.80	1.52	80251.38	18.07	11.35	1.02	193.80	14.54
09	3.64	60.25	5.84	10.83	1.57	79750.51	17.24	11.13	1.05	192.89	14.32
10	3.87	58.65	6.49	10.73	1.56	79265.94	17.20	10.88	1.04	191.48	14.04
11	3.82	61.54	5.91	10.82	1.57	79601.73	17.76	11.29	1.04	193.97	14.40
12	4.10	59.62	6.29	10.90	1.54	78180.30	17.57	11.73	1.02	192.22	14.18
13	3.72	59.70	6.83	10.76	1.51	79551.63	18.24	11.07	1.01	192.60	14.35
14	4.24	59.27	5.92	10.65	1.48	79517.28	17.34	11.58	0.98	191.15	13.99
15	3.90	58.49	5.66	10.75	1.51	79956.55	17.54	11.24	1.00	193.64	14.31
16	3.74	57.59	7.76	10.85	1.56	79664.30	17.17	10.99	1.04	193.54	14.34
17	3.93	58.19	7.03	10.78	1.64	79177.22	17.40	11.43	1.10	191.95	14.15
18	3.92	58.27	8.82	10.87	1.68	78563.58	17.18	11.23	1.12	192.48	14.15
19	3.95	58.09	7.62	10.91	1.69	78633.97	17.11	11.26	1.13	192.27	14.19
20	4.03	56.31	6.87	10.84	1.65	79307.68	17.36	11.64	1.10	193.08	14.28
21	3.97	53.84	7.04	10.74	1.60	78994.23	17.36	11.22	1.07	191.71	14.03
22	3.43	54.77	6.84	10.83	1.61	78659.85	17.48	10.83	1.07	192.99	14.17
23	3.59	54.10	5.69	10.81	1.64	80001.90	17.46	11.05	1.09	193.54	14.40
24	3.94	54.78	6.56	10.80	1.63	79646.40	17.30	11.53	1.09	191.91	14.24
25	3.17	55.73	6.38	10.89	1.69	79010.11	17.80	11.36	1.13	194.14	14.41
26	3.18	56.78	5.16	10.93	1.69	79100.04	17.42	11.24	1.13	194.93	14.43
27	3.10	55.54	7.26	10.81	1.67	79091.76	17.98	11.13	1.12	193.58	14.32
28	3.52	54.17	6.33	10.76	1.72	78512.60	17.65	11.15	1.15	192.38	14.05
29	3.19	53.19	7.18	10.84	1.75	78526.45	17.83	11.28	1.17	193.30	14.23
30	3.64	50.93	7.11	10.86	1.75	79030.42	16.84	11.82	1.17	191.11	14.11
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.74	58.11	6.77	10.85	1.62	79386.10	17.52	11.34	1.08	193.04	14.33
最大值	4.26	63.87	8.82	11.10	1.75	81523.94	18.24	11.85	1.17	195.27	14.81
發生日期											
最小值	3.10	50.93	5.16	10.65	1.48	78180.30	16.84	10.83	0.98	191.11	13.99
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管