

連續自動監測紀錄月報表

中華民國113年2月29日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫 ppm	氮氧化物 ppm	一氧化碳 ppm	氧氣 %	粉塵濃度 mg/m ³	排放流率 Nm ³ /hr	水份 %	鹽酸 ppm	不透光率 %	溫度 ℃	流速 m/s
01	2.26	45.32	8.54	10.47	1.33	76360.77	19.17	10.45	1.03	180.75	13.20
02	2.30	45.49	8.92	10.57	1.37	76494.06	19.02	10.79	1.05	180.71	13.33
03	2.78	42.90	9.06	10.76	1.34	74944.07	18.46	10.88	1.03	179.49	13.17
04	2.70	42.44	8.12	10.66	1.34	75346.85	18.72	10.84	1.03	180.02	13.17
05	2.79	40.61	8.77	10.73	1.29	76335.92	18.06	10.82	1.00	179.45	13.31
06	2.67	43.21	9.40	10.84	1.32	77229.20	17.90	11.91	1.01	180.22	13.60
07	2.73	44.54	9.25	10.93	1.31	76302.57	17.74	11.74	1.01	180.14	13.52
08	2.95	35.69	10.47	11.16	1.26	76412.28	17.17	11.74	0.98	179.47	13.76
09	2.41	35.34	9.91	11.18	1.27	76862.11	17.57	10.99	0.98	179.23	13.92
10	2.73	36.74	8.21	11.25	1.27	75688.93	17.16	10.87	0.98	178.59	13.72
11	2.64	42.04	9.10	11.20	1.22	74742.56	16.39	11.22	0.94	178.64	13.36
12	2.48	40.28	6.60	10.77	1.21	77577.74	17.75	10.93	0.93	179.03	13.51
13	2.22	45.54	8.04	10.51	1.22	79855.07	18.53	9.90	0.94	181.71	13.77
14	1.68	40.21	8.94	10.45	1.22	80991.98	19.53	9.22	0.94	183.34	14.11
15	1.75	43.01	8.15	10.38	1.23	80041.13	19.94	9.03	0.95	182.57	13.92
16	2.09	45.31	8.86	10.51	1.22	80248.84	19.62	8.88	0.94	181.43	14.02
17	2.15	45.40	10.04	10.64	1.21	78558.65	19.43	9.27	0.94	181.18	13.85
18	1.93	45.41	8.89	10.40	1.29	79326.41	19.99	9.19	1.00	182.32	13.81
19	1.70	43.29	8.31	10.33	1.32	79398.36	20.03	9.57	1.02	182.00	13.73
20	1.00	45.80	9.79	10.41	1.33	78049.27	20.50	9.37	1.03	182.54	13.69
21	1.62	42.32	8.65	10.24	1.31	78042.38	20.03	9.92	1.01	180.65	13.34
22	1.27	42.08	8.03	10.31	1.29	79152.70	19.95	9.92	0.99	180.41	13.60
23	1.42	44.17	7.62	10.39	1.30	81360.25	19.79	9.83	1.00	182.09	14.11
24	1.37	37.87	9.00	10.81	1.32	77829.76	19.08	9.77	1.01	181.02	13.90
25	1.89	38.32	8.69	10.88	1.30	78623.72	18.66	9.82	1.00	180.75	14.05
26	2.10	35.50	8.89	11.13	1.29	77281.16	18.22	10.28	0.99	180.55	14.09
27	1.73	40.91	9.21	11.22	1.32	75400.39	18.62	9.66	1.01	180.42	13.92
28	1.26	43.49	8.35	10.73	1.32	77871.02	19.69	9.38	1.01	182.77	13.97
29	1.53	42.86	9.24	10.86	1.31	77022.04	19.42	9.58	1.01	182.20	13.90
監測日數	29	29	29	29	29	29	29	29	29	29	29
平均值	2.07	41.93	8.79	10.71	1.29	77701.73	18.83	10.20	0.99	180.82	13.70
最大值	2.95	45.80	10.47	11.25	1.37	81360.25	20.50	11.91	1.05	183.34	14.11
發生日期											
最小值	1.00	35.34	6.60	10.24	1.21	74742.56	16.39	8.88	0.93	178.59	13.17
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國113年2月29日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	2.57	39.31	8.62	11.13	1.04	74968.83	19.10	12.01	0.80	188.65	14.06
02	3.00	40.79	9.40	11.22	1.05	74865.82	18.96	13.07	0.81	188.30	14.14
03	3.33	42.64	9.45	11.39	1.04	74003.79	18.39	13.39	0.80	187.62	14.10
04	3.59	41.92	8.33	11.38	1.08	73362.74	18.49	12.48	0.83	187.30	13.97
05	3.51	41.69	8.78	11.20	1.12	75623.52	17.94	12.78	0.86	186.69	14.02
06	2.80	39.02	9.20	11.20	1.13	76666.88	17.98	13.75	0.87	188.15	14.26
07	3.23	32.65	9.87	11.22	1.11	76993.35	18.06	13.46	0.86	188.81	14.39
08	3.06	33.42	9.43	11.23	1.14	77813.88	17.69	14.46	0.88	188.88	14.49
09	2.85	34.15	9.55	11.05	1.19	79181.17	17.90	13.56	0.92	188.50	14.51
10	2.27	37.62	7.88	10.89	1.26	80526.71	18.37	12.79	0.97	190.33	14.66
11	2.82	36.21	10.01	10.84	1.24	80975.13	17.31	13.39	0.95	189.35	14.44
12	2.86	41.14	7.22	10.55	1.25	82039.52	18.12	12.26	0.97	189.79	14.38
13	1.72	41.76	8.93	10.40	1.30	82635.04	19.31	10.10	1.00	191.56	14.56
14	1.56	37.51	8.94	10.40	1.29	83440.63	20.44	6.53	1.00	194.20	14.99
15	1.91	36.70	8.35	10.39	1.24	82503.67	20.34	6.83	0.95	192.96	14.75
16	2.02	37.77	9.28	10.35	1.17	82861.92	19.96	8.75	0.90	191.28	14.64
17	2.18	40.52	9.06	10.37	1.14	82287.36	20.02	10.38	0.87	190.77	14.56
18	1.72	38.14	8.67	10.32	1.13	81776.31	20.35	9.82	0.87	191.22	14.48
19	1.54	36.04	9.12	10.40	1.11	81035.55	20.46	10.45	0.85	191.60	14.48
20	1.14	40.43	9.68	10.35	1.15	80210.32	21.03	10.16	0.88	191.75	14.39
21	1.75	40.90	9.28	10.39	1.16	80349.64	20.63	11.69	0.89	191.27	14.37
22	1.29	41.79	8.44	10.47	1.12	81218.10	20.46	10.77	0.86	191.08	14.60
23	1.63	43.08	8.50	10.56	1.09	82588.00	20.11	11.69	0.84	192.24	14.95
24	1.57	43.25	9.77	10.53	1.11	82300.99	19.92	11.69	0.86	191.20	14.77
25	1.95	43.91	9.68	10.55	1.17	83019.40	19.65	11.06	0.90	191.74	14.91
26	1.87	43.67	9.41	10.70	1.16	82071.26	19.45	11.25	0.89	191.42	14.90
27	1.66	42.56	9.21	10.81	1.17	80795.80	19.58	11.10	0.90	191.62	14.86
28	1.42	40.94	8.45	10.85	1.18	79840.38	20.18	9.94	0.91	192.78	14.88
29	1.47	44.31	9.39	10.90	1.20	79660.16	19.95	10.36	0.93	193.27	14.90
監測日數	29	29	29	29	29	29	29	29	29	29	29
平均值	2.22	39.79	9.03	10.76	1.16	79848.82	19.32	11.38	0.89	190.49	14.53
最大值	3.59	44.31	10.01	11.39	1.30	83440.63	21.03	14.46	1.00	194.20	14.99
發生日期											
最小值	1.14	32.65	7.22	10.32	1.04	73362.74	17.31	6.53	0.80	186.69	13.97
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管