

連續自動監測紀錄月報表

中華民國110年4月30日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	5.20	67.71	6.39	11.47	1.60	78203.59	16.34	12.41	1.07	169.40	14.06
02	5.59	68.93	4.99	11.37	1.59	78931.56	16.77	14.41	1.06	170.18	14.15
03	6.02	68.05	4.13	11.33	1.58	79313.93	16.81	14.69	1.05	170.47	14.17
04	5.74	69.02	4.24	11.57	1.54	79511.34	15.84	14.15	1.03	169.61	14.37
05	5.79	68.01	4.10	11.35	1.58	81908.60	15.78	12.83	1.05	170.93	14.51
06	4.97	68.20	6.47	11.42	1.59	81239.46	15.03	12.81	1.06	177.97	14.59
07	5.98	67.15	4.93	11.14	1.61	82728.28	15.78	12.92	1.07	170.31	14.31
08	5.61	66.57	5.25	11.07	1.63	82404.98	15.96	12.48	1.09	169.50	14.17
09	5.71	66.60	6.06	11.23	1.61	82731.80	15.94	10.34	1.08	170.09	14.46
10	6.00	67.24	6.93	11.10	1.60	83963.74	16.08	13.63	1.06	171.51	14.55
11	5.89	67.00	5.40	10.83	1.63	83541.00	17.17	12.74	1.09	173.26	14.35
12	5.89	66.98	6.29	10.79	1.63	83344.80	16.70	15.43	1.08	172.33	14.15
13	5.71	67.80	7.46	10.96	1.60	81739.92	16.55	17.11	1.07	172.17	14.08
14	5.60	68.41	9.58	10.82	1.60	83826.85	16.31	16.60	1.07	171.27	14.16
15	5.60	66.43	9.01	11.02	1.64	83773.94	16.15	16.22	1.09	169.88	14.39
16	5.76	67.81	7.52	11.03	1.63	82891.68	16.14	14.42	1.09	170.48	14.26
17	6.23	67.27	10.74	11.24	1.62	82022.98	15.44	14.24	1.08	169.58	14.26
18	6.47	67.15	8.85	11.17	1.58	82724.94	15.03	15.16	1.05	168.50	14.18
19	6.03	66.44	6.77	11.02	1.56	83177.58	15.52	12.60	1.04	169.51	14.14
20	6.27	66.55	10.98	11.21	1.56	81897.90	15.02	12.36	1.04	168.96	14.11
21	6.98	66.44	11.65	11.31	1.55	80729.31	14.85	15.57	1.03	168.86	14.02
22	6.57	66.31	10.28	10.91	1.54	81813.27	16.22	15.52	1.02	168.74	13.86
23	6.46	67.02	11.06	11.12	1.54	81496.54	15.97	14.44	1.03	169.54	14.09
24	6.57	68.10	7.67	10.98	1.54	81717.23	16.24	16.05	1.03	169.36	13.96
25	6.88	67.89	7.19	11.02	1.50	82051.22	15.87	15.96	1.00	169.75	14.04
26	7.09	68.64	7.97	11.02	1.48	82442.42	15.35	16.92	0.99	169.06	13.97
27	6.92	68.89	9.03	11.06	1.48	82271.12	15.61	16.78	0.99	169.79	14.07
28	6.32	68.38	9.90	11.14	1.47	80862.66	15.87	15.28	0.98	168.50	13.95
29	6.15	67.54	9.33	10.99	1.46	81767.21	15.92	16.38	0.97	167.18	13.87
30	5.45	67.00	8.17	11.03	1.49	81437.36	15.89	15.53	0.99	169.38	13.93
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	6.05	67.52	7.61	11.12	1.57	81882.24	15.94	14.53	1.05	170.20	14.17
最大值	7.09	69.02	11.65	11.57	1.64	83963.74	17.17	17.11	1.09	177.97	14.59
發生日期											
最小值	4.97	66.31	4.10	10.79	1.46	78203.59	14.85	10.34	0.97	167.18	13.86
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國110年4月30日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	6.04	64.01	10.01	11.13	1.35	78568.32	17.56	14.08	0.90	174.27	14.01
02	5.96	66.72	8.18	11.19	1.44	78503.43	17.99	14.78	0.96	175.71	14.19
03	6.05	65.86	8.02	11.18	1.48	78848.73	17.89	13.22	0.99	176.54	14.25
04	5.80	65.98	8.73	11.19	1.45	80516.88	17.28	14.12	0.97	179.18	14.54
05	5.89	64.96	7.93	11.09	1.44	82243.11	16.83	12.67	0.96	177.07	14.55
06	5.90	63.10	8.93	11.39	1.47	79742.01	16.29	11.94	0.98	176.70	14.46
07	4.91	64.85	10.17	11.52	1.45	79513.29	16.30	11.82	0.97	178.51	14.68
08	5.56	64.08	9.20	11.41	1.46	80301.72	16.40	11.18	0.97	179.41	14.69
09	6.06	65.35	9.18	11.48	1.52	80475.00	16.71	11.81	1.01	179.03	14.88
10	5.94	65.48	9.68	11.52	1.62	80470.84	16.45	12.68	1.08	180.86	14.95
11	6.31	65.73	9.59	11.29	1.62	80199.25	17.32	12.52	1.08	182.49	14.75
12	5.96	63.67	10.79	11.22	1.58	80309.90	17.17	14.13	1.05	181.70	14.61
13	6.12	64.78	11.53	11.28	1.57	79539.87	17.07	16.04	1.05	181.60	14.54
14	6.01	66.37	10.86	11.29	1.52	80413.93	16.90	15.28	1.01	181.17	14.67
15	5.82	66.11	12.43	11.27	1.44	80467.62	16.76	15.55	0.96	180.07	14.59
16	5.48	62.69	10.80	11.22	1.44	80702.56	17.25	13.81	0.96	181.31	14.70
17	5.73	63.02	12.26	11.44	1.45	79948.52	16.58	13.84	0.97	180.86	14.76
18	6.10	62.69	12.15	11.42	1.44	81309.16	16.09	14.70	0.96	180.40	14.87
19	5.92	60.67	12.17	11.40	1.47	80407.69	16.19	12.25	0.98	179.38	14.66
20	6.61	62.60	11.86	11.48	1.49	79807.13	16.03	13.05	0.99	180.51	14.69
21	7.99	58.51	13.63	11.51	1.49	79222.01	15.63	14.99	0.99	177.92	14.47
22	6.13	54.34	13.58	11.19	1.51	79353.50	17.35	14.93	1.00	179.41	14.36
23	6.87	56.13	11.59	11.31	1.57	79616.23	17.10	15.71	1.05	179.58	14.55
24	6.52	60.53	10.86	11.24	1.64	80528.26	17.22	15.81	1.10	180.89	14.68
25	6.77	61.18	10.98	11.29	1.62	80583.40	17.00	15.62	1.08	180.69	14.71
26	7.43	59.83	13.34	11.34	1.59	80702.91	16.19	16.34	1.06	179.95	14.65
27	7.25	60.78	10.84	11.31	1.58	80681.63	16.85	16.32	1.05	181.19	14.76
28	6.96	60.74	12.71	11.23	1.53	80445.67	17.07	15.60	1.02	179.98	14.60
29	6.11	62.73	11.26	11.28	1.54	80822.05	16.89	15.66	1.02	179.69	14.69
30	5.89	63.48	10.37	11.21	1.53	80056.24	16.87	15.08	1.02	180.41	14.47
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	6.20	62.90	10.79	11.31	1.51	80143.36	16.84	14.18	1.01	179.55	14.60
最大值	7.99	66.72	13.63	11.52	1.64	82243.11	17.99	16.34	1.10	182.49	14.95
發生日期											
最小值	4.91	54.34	7.93	11.09	1.35	78503.43	15.63	11.18	0.90	174.27	14.01
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管