

連續自動監測紀錄月報表

中華民國115年8月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂ 二氧化 硫	NO _x 氮氧化 物	CO 一氧化 碳	O ₂ 氧氣	DUST 粉塵濃 度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光 率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	2.92	50.30	12.85	11.61	1.07	67791.85	19.41	7.09	0.83	189.47	13.44
02	3.04	49.96	12.21	11.61	1.05	66811.87	19.59	6.14	0.81	185.14	13.14
03	2.56	50.56	11.89	11.58	1.03	67820.58	19.42	5.53	0.79	190.61	13.43
04	2.39	53.57	11.34	11.55	1.00	67701.76	19.59	6.06	0.77	193.80	13.49
05	2.04	55.10	12.08	11.31	1.01	68973.41	20.07	6.34	0.77	195.98	13.55
06	3.34	52.31	11.28	11.61	1.01	70409.23	19.59	7.61	0.78	182.85	13.83
07	2.87	52.01	11.05	11.62	1.04	71336.20	19.69	7.68	0.79	193.11	14.32
08	2.53	49.41	11.24	11.31	1.03	71171.64	19.87	7.78	0.79	193.78	13.89
09	2.57	45.49	10.91	11.17	1.03	72460.90	19.72	7.57	0.79	186.22	13.68
10	1.96	48.82	10.34	11.30	1.05	71881.79	19.78	6.15	0.81	194.89	14.00
11	1.86	53.43	14.22	11.61	1.02	69825.02	19.23	6.54	0.78	196.77	13.92
12	1.22	51.66	15.90	11.61	0.98	70342.32	19.92	7.74	0.76	195.74	14.20
13	1.46	57.30	11.06	11.52	0.97	70279.22	19.71	8.51	0.75	188.90	13.83
14	1.20	57.59	13.49	11.56	0.99	70091.78	19.68	7.61	0.76	193.95	14.00
15	1.34	50.97	11.87	11.40	0.97	70612.82	19.97	7.00	0.75	191.58	13.85
16	1.66	50.33	11.83	11.55	0.97	69440.93	19.49	7.77	0.75	186.84	13.61
17	1.46	52.97	9.63	11.30	1.00	70698.73	19.97	7.26	0.77	192.25	13.73
18	0.98	51.55	11.26	11.36	0.99	70649.42	20.26	6.55	0.77	197.58	14.02
19	1.23	54.04	11.77	11.37	1.01	70186.16	19.78	5.36	0.78	192.86	13.72
20	1.43	51.79	10.98	11.17	1.03	72619.63	20.26	6.31	0.79	187.14	13.82
21	1.07	49.86	11.27	11.30	1.03	71996.42	20.36	7.04	0.79	194.40	14.12
22	0.78	46.05	11.02	11.15	1.02	71957.39	20.71	6.02	0.78	192.65	13.89
23	1.03	45.80	11.06	11.28	1.02	71334.93	20.60	6.62	0.79	188.08	13.81
24	1.20	45.14	10.35	11.24	1.01	71915.54	20.00	7.32	0.77	191.89	13.88
25	0.58	40.43	11.47	11.10	1.00	72522.79	20.58	6.23	0.77	196.66	14.04
26	0.78	46.54	13.18	11.21	1.00	72140.02	20.26	6.66	0.77	196.05	14.09
27	1.26	58.28	11.72	11.38	0.99	70812.30	20.05	6.98	0.77	188.11	13.77
28	0.88	57.03	12.64	11.36	0.97	71429.51	20.20	7.25	0.75	195.16	14.09
29	1.25	56.29	12.25	11.25	0.95	71965.96	20.37	7.21	0.73	193.47	14.02
30	1.84	54.80	9.86	11.33	0.95	71565.16	19.98	7.06	0.74	189.84	13.87
31	1.20	52.12	9.64	11.44	0.94	69748.82	19.57	5.29	0.73	193.91	13.74
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	1.68	51.34	11.67	11.39	1.00	70596.58	19.93	6.85	0.77	191.93	13.83
最大值	3.34	58.28	15.90	11.62	1.07	72619.63	20.71	8.51	0.83	197.58	14.32
發生日期											
最小值	0.58	40.43	9.63	11.10	0.94	66811.87	19.23	5.29	0.73	182.85	13.14
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國115年8月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	2.67	57.63	12.48	10.87	1.18	68326.39	21.23	6.76	0.91	191.94	12.43
02	2.75	55.42	12.67	11.16	1.19	68270.91	21.20	5.42	0.92	190.34	12.75
03	3.16	59.43	12.03	11.26	1.16	69061.27	20.49	4.62	0.89	185.80	12.79
04	3.84	59.61	12.41	11.07	1.13	68602.79	20.89	6.03	0.87	189.58	12.65
05	2.90	59.20	11.69	10.34	1.10	68683.33	22.09	6.46	0.85	193.51	12.04
06	3.07	55.55	12.46	10.30	1.08	70516.88	22.31	6.37	0.83	186.90	12.20
07	2.19	58.83	11.24	10.83	1.12	71308.42	21.66	7.31	0.86	197.83	13.15
08	2.33	58.01	11.37	10.69	1.11	71046.95	21.77	6.88	0.86	190.66	12.73
09	2.40	48.48	13.41	10.76	1.11	70968.53	21.88	5.68	0.86	192.46	12.90
10	1.67	45.69	11.36	10.57	1.13	70260.58	22.95	5.76	0.87	198.68	12.86
11	1.27	48.48	13.96	10.95	1.17	69424.78	22.70	6.10	0.93	202.93	13.06
12	1.38	56.03	16.52	11.51	1.08	68952.97	21.61	5.13	0.83	196.87	13.61
13	1.50	59.54	12.68	11.15	1.09	70111.99	21.55	7.69	0.84	195.94	13.27
14	1.50	54.54	17.25	11.37	1.08	69197.54	20.97	6.82	0.83	200.98	13.46
15	1.35	52.77	14.90	11.16	1.08	69409.03	21.49	6.72	0.83	197.72	13.20
16	1.86	58.63	17.36	11.40	1.08	69119.43	20.77	7.15	0.83	191.81	13.17
17	1.58	59.87	14.31	11.26	1.06	70064.24	21.25	6.52	0.81	198.44	13.42
18	1.29	55.31	13.82	11.11	1.05	69535.31	21.57	5.64	0.80	202.21	13.30
19	1.65	53.93	17.63	11.05	1.06	69400.57	21.47	5.15	0.81	197.38	13.03
20	2.19	54.45	16.47	10.94	1.07	72113.31	21.80	6.69	0.82	191.54	13.28
21	1.49	54.29	15.27	11.15	1.10	71548.90	21.58	5.96	0.85	199.72	13.66
22	1.36	53.95	13.07	11.10	1.24	70996.58	22.01	5.73	0.98	198.38	13.51
23	1.70	54.20	13.05	11.13	1.11	70641.40	21.89	5.49	0.86	193.29	13.33
24	1.77	57.38	13.71	11.09	1.13	71838.18	21.56	6.36	0.87	199.14	13.61
25	0.89	54.24	12.13	10.97	1.13	71619.78	22.25	4.35	0.87	202.71	13..63
26	1.23	50.88	17.60	11.01	1.11	71165.64	21.53	6.40	0.86	198.59	13.36
27	2.15	62.92	14.50	10.95	1.13	70550.58	21.74	6.00	0.87	190.56	12.97
28	1.60	57.93	19.36	11.21	1.14	69986.44	21.51	5.07	0.88	199.65	13.44
29	1.99	57.72	13.74	11.09	1.15	71864.15	21.73	5.55	0.88	199.40	13.67
30	3.57	60.08	12.40	11.10	1.13	71127.16	21.22	6.17	0.87	194.56	13.30
31	2.15	60.58	16.44	11.13	1.11	70426.15	20.83	4.89	0.86	200.09	13.32
監測日數	31	31	31	31	31	31	31	31	31	31	30
平均值	2.01	55.99	14.11	11.02	1.12	70198.07	21.60	6.03	0.86	195.79	13.12
最大值	3.84	62.92	19.36	11.51	1.24	72113.31	22.95	7.69	0.98	202.93	13.67
發生日期											
最小值	0.89	45.69	11.24	10.30	1.05	68270.91	20.49	4.35	0.80	185.80	12.04
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管