

連續自動監測紀錄月報表

中華民國111年1月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	2.20	65.70	9.31	10.14	1.70	82832.78	16.55	11.64	1.14	179.65	13.42
02	2.29	64.96	8.42	10.08	1.70	82928.16	16.84	11.93	1.13	179.86	13.41
03	2.24	63.85	8.33	9.98	1.68	83110.51	16.81	11.90	1.12	178.26	13.27
04	1.91	65.14	7.86	9.99	1.72	83311.04	16.96	11.57	1.15	179.47	13.36
05	2.08	62.98	11.96	10.46	1.77	81106.28	17.22	11.71	1.18	179.78	13.64
06	2.55	62.28	8.64	10.49	1.72	80522.31	15.91	12.17	1.15	175.61	13.25
07	2.66	60.01	10.66	10.39	1.69	82792.36	16.42	12.40	1.13	177.48	13.64
08	1.98	58.96	7.54	10.46	1.70	82316.70	16.20	12.34	1.13	177.09	13.60
09	2.09	57.17	7.36	10.25	1.72	83043.12	16.50	12.18	1.14	177.26	13.51
10	2.11	59.34	9.06	10.56	1.70	82357.56	16.23	12.08	1.13	174.37	13.68
11	2.19	61.00	7.97	10.35	1.68	82100.85	16.00	11.72	1.12	178.25	13.43
12	2.25	58.95	8.32	10.46	1.72	82290.84	15.41	11.71	1.15	178.92	13.53
13	2.30	62.25	8.55	10.58	1.74	81725.17	15.36	12.67	1.16	179.22	13.58
14	1.96	61.86	7.40	10.49	1.81	82310.97	15.89	12.01	1.21	180.72	13.70
15	2.16	56.92	9.52	10.25	1.82	82005.68	16.24	12.75	1.22	179.38	13.37
16	2.23	55.78	7.91	10.11	1.79	81158.11	16.09	12.84	1.19	176.86	12.95
17	2.16	55.47	9.80	10.01	1.74	81635.17	16.45	12.63	1.16	177.55	13.05
18	1.82	57.52	7.64	10.22	1.68	80599.77	16.15	12.74	1.12	177.12	13.01
19	2.30	54.22	6.68	10.04	1.66	81505.72	16.78	12.29	1.11	177.33	13.05
20	2.72	58.19	7.90	10.09	1.67	80545.04	16.30	14.27	1.11	175.57	12.83
21	2.77	59.30	7.87	10.08	1.67	81801.25	17.17	14.34	1.11	178.20	13.23
22	2.58	59.96	10.20	10.13	1.68	81125.54	17.25	14.60	1.12	178.23	13.21
23	2.42	56.98	8.73	9.87	1.69	82872.94	17.98	14.67	1.13	179.34	13.31
24	3.14	60.56	9.03	10.53	1.62	81354.48	15.89	13.69	1.08	173.40	13.40
25	3.20	64.11	7.24	10.63	1.62	81215.27	15.52	14.49	1.08	173.97	13.46
26	2.43	60.28	7.10	10.12	1.63	80892.25	16.32	14.45	1.09	177.87	12.99
27	2.60	58.27	7.48	10.00	1.59	80769.35	16.66	14.27	1.06	176.79	12.85
28	2.59	60.56	6.08	10.12	1.59	81171.79	16.48	14.50	1.06	177.50	13.05
29	2.38	62.15	7.74	10.32	1.61	81064.23	16.00	14.43	1.07	177.60	13.20
30	2.51	63.83	7.99	10.39	1.65	81301.96	15.56	14.61	1.10	177.14	13.24
31	2.19	64.62	8.44	10.42	1.67	82360.74	15.46	14.98	1.12	178.19	13.47
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.36	60.42	8.35	10.26	1.69	81810.58	16.34	13.05	1.13	177.68	13.31
最大值	3.20	65.70	11.96	10.63	1.82	83311.04	17.98	14.98	1.22	180.72	13.70
發生日期											
最小值	1.82	54.22	6.08	9.87	1.59	80522.31	15.36	11.57	1.06	173.40	12.83
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國111年1月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	4.61	65.56	8.86	11.16	1.77	77452.26	16.00	11.83	1.18	193.81	14.19
02	4.90	64.69	9.67	11.04	1.71	78179.04	16.35	11.88	1.14	193.77	14.21
03	4.69	64.33	7.31	10.98	1.71	77642.29	16.30	11.84	1.14	193.01	13.99
04	4.56	64.39	11.81	11.10	1.68	77175.46	16.38	11.91	1.12	193.26	14.11
05	5.32	62.24	9.19	11.10	1.62	77140.09	15.98	12.42	1.08	191.12	13.96
06	4.79	60.59	12.78	11.10	1.60	76790.97	16.27	12.27	1.07	191.50	13.96
07	4.51	61.38	11.14	11.44	1.59	78022.97	16.10	11.91	1.06	187.82	14.52
08	4.85	57.18	10.61	11.17	1.62	77374.44	16.03	12.34	1.08	191.42	14.14
09	4.46	56.24	8.13	11.03	1.64	78316.12	16.29	11.77	1.09	192.62	14.18
10	4.49	57.65	8.45	11.08	1.65	77672.74	16.58	11.94	1.10	192.77	14.18
11	4.87	59.19	10.12	11.27	1.64	77534.03	15.68	12.40	1.09	192.64	14.27
12	4.82	57.03	9.48	11.33	1.61	77363.65	15.10	12.07	1.07	193.01	14.25
13	5.01	58.48	9.23	11.31	1.64	77575.23	15.04	12.50	1.09	193.52	14.26
14	4.23	60.83	7.00	11.24	1.65	78131.03	15.60	12.15	1.10	195.42	14.42
15	4.99	57.76	11.18	11.22	1.69	77514.73	15.65	12.45	1.12	194.60	14.25
16	5.11	56.38	9.18	11.32	1.69	76659.91	15.04	12.78	1.13	193.65	14.12
17	4.49	55.22	7.03	11.00	1.71	78124.69	16.01	12.51	1.14	194.49	14.16
18	4.38	57.70	8.13	11.20	1.76	77514.47	15.64	13.38	1.17	194.14	14.21
19	4.76	56.51	7.95	11.28	1.76	76335.30	15.50	12.15	1.17	192.96	14.05
20	4.77	57.47	7.85	11.28	1.66	76333.50	15.69	14.32	1.10	192.39	14.06
21	4.46	56.98	8.23	11.15	1.62	77522.06	16.32	14.59	1.08	195.08	14.29
22	4.39	57.56	10.32	11.20	1.62	76876.32	16.27	14.64	1.08	194.63	14.21
23	4.08	56.71	10.70	11.11	1.67	77216.47	16.78	14.69	1.11	195.23	14.25
24	5.02	56.90	9.92	11.17	1.70	77099.73	16.01	14.71	1.13	194.10	14.14
25	4.48	59.53	9.71	11.28	1.74	76914.13	15.73	14.50	1.16	195.05	14.24
26	4.43	60.01	8.66	11.31	1.76	76146.22	15.46	15.00	1.17	194.98	14.11
27	4.95	56.20	7.54	11.04	1.71	74724.28	15.98	14.32	1.14	189.31	13.39
28	4.78	57.14	8.06	10.80	1.68	74477.92	16.03	14.72	1.12	186.56	12.96
29	4.78	59.71	9.38	10.86	1.70	75028.67	15.78	14.88	1.13	187.15	13.12
30	4.72	63.05	9.71	11.01	1.71	75318.46	15.10	14.70	1.14	187.10	13.25
31	4.69	63.80	9.03	10.93	1.70	76201.20	15.40	15.30	1.13	187.49	13.36
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.69	59.30	9.24	11.15	1.68	76979.95	15.87	13.19	1.12	192.41	14.03
最大值	5.32	65.56	12.78	11.44	1.77	78316.12	16.78	15.30	1.18	195.42	14.52
發生日期											
最小值	4.08	55.22	7.00	10.80	1.59	74477.92	15.04	11.77	1.06	186.56	12.96
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管