

連續自動監測紀錄月報表

中華民國113年5月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	°C	m/s
01	2.31	30.21	11.54	11.07	1.18	75057.92	17.23	8.94	0.91	180.34	13.43
02	2.23	27.68	10.84	11.05	1.17	75405.19	17.11	8.37	0.90	180.54	13.44
03	2.06	29.96	11.28	11.05	1.19	74853.53	17.26	8.90	0.91	181.22	13.39
04	1.87	30.19	11.65	10.94	1.21	74519.48	17.56	8.45	0.94	180.99	13.22
05	3.01	32.76	11.50	11.07	1.19	72539.76	17.48	7.31	0.91	177.76	12.93
06	4.11	33.72	10.67	10.72	1.19	70459.69	17.47	6.32	0.92	180.03	12.20
07	2.33	39.81	10.14	10.31	1.19	75483.60	17.94	8.12	0.92	182.74	12.71
08	2.48	44.11	11.30	9.73	1.19	78877.28	18.47	8.64	0.92	182.68	12.68
09	1.89	43.75	11.19	9.53	1.19	83903.42	18.55	8.78	0.92	180.86	13.22
10	1.19	42.87	11.37	9.75	1.24	84156.87	18.75	8.12	0.96	182.98	13.61
11	1.05	39.74	11.04	9.78	1.25	82179.25	18.82	7.88	0.96	181.15	13.29
12	1.14	37.76	11.05	9.87	1.24	81870.18	19.19	7.86	0.96	181.96	13.43
13	1.57	32.47	11.44	9.85	1.23	81215.00	18.48	7.91	0.95	178.71	13.09
14	1.37	34.27	11.86	10.09	1.23	80508.54	18.20	7.92	0.95	179.69	13.23
15	1.76	36.59	12.60	10.25	1.23	80567.52	17.58	8.20	0.95	181.50	13.39
16	1.78	37.72	12.07	10.28	1.22	80176.03	17.25	8.33	0.94	180.90	13.31
17	1.59	37.14	10.86	10.39	1.24	79405.53	17.72	8.32	0.96	182.53	13.43
18	1.50	37.30	11.51	10.41	1.24	79078.57	17.89	7.90	0.96	182.56	13.43
19	1.59	34.23	11.09	10.30	1.25	78200.08	18.17	8.23	0.96	181.36	13.15
20	1.48	33.50	10.71	10.40	1.23	77476.02	18.11	7.84	0.95	181.73	13.15
21	1.27	33.47	11.19	10.46	1.24	78647.25	18.38	8.02	0.96	183.48	13.53
22	1.21	31.67	12.22	10.32	1.20	79023.46	18.62	7.83	0.93	182.82	13.43
23	1.26	31.42	14.55	10.23	1.19	78804.79	18.35	7.99	0.91	182.00	13.21
24	1.08	37.94	11.08	10.32	1.21	79566.93	18.71	10.16	0.93	185.54	13.63
25	0.89	37.78	10.54	10.34	1.20	80149.83	18.65	7.57	0.93	187.19	13.79
26	1.24	32.41	11.16	10.31	1.17	79084.51	18.66	7.50	0.90	185.01	13.51
27	1.22	28.63	11.39	10.28	1.15	77929.14	18.91	7.82	0.89	182.68	13.25
28	1.37	31.20	12.09	10.40	1.14	78981.96	18.29	8.17	0.88	183.87	13.52
29	1.45	32.78	11.40	10.43	1.19	78739.68	18.05	7.97	0.91	183.48	13.45
30	1.39	32.20	11.71	10.31	1.19	78264.42	18.23	8.53	0.92	183.50	13.25
31	1.21	33.11	11.65	10.39	1.18	77784.32	18.51	8.86	0.91	182.97	13.30
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	1.67	34.79	11.44	10.34	1.21	78480.96	18.15	8.15	0.93	182.09	13.28
最大值	4.11	44.11	14.55	11.07	1.25	84156.87	19.19	10.16	0.96	187.19	13.79
發生日期											
最小值	0.89	27.68	10.14	9.53	1.14	70459.69	17.11	6.32	0.88	177.76	12.20
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國113年5月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.63	36.33	10.92	11.99	0.97	75500.32	15.82	8.07	0.75	195.42	15.11
02	2.74	34.86	11.93	11.64	1.00	78002.93	16.37	7.12	0.77	195.08	15.13
03	2.73	32.71	13.56	11.62	1.03	76921.23	16.63	7.81	0.79	194.25	14.90
04	3.10	28.81	12.79	11.64	1.04	75237.37	16.67	7.49	0.79	193.53	14.59
05	3.57	28.32	11.87	11.69	1.02	73383.67	16.98	5.86	0.78	190.49	14.29
06	4.52	28.16	13.02	11.21	1.02	77191.21	17.16	5.81	0.78	190.69	14.32
07	2.59	39.03	12.43	11.26	1.05	79459.64	16.74	6.97	0.80	195.53	14.88
08	2.38	37.87	13.05	10.91	1.04	81465.89	17.22	8.57	0.80	195.08	14.80
09	1.70	35.57	11.40	10.58	1.06	82994.82	17.80	8.60	0.82	193.47	14.65
10	1.51	33.79	13.81	10.73	1.06	82068.35	18.10	8.62	0.82	195.78	14.83
11	1.39	32.80	13.28	11.01	1.05	79728.22	17.86	7.98	0.81	195.11	14.74
12	1.56	31.21	12.80	11.19	1.04	78454.92	17.91	7.91	0.80	196.50	14.82
13	2.17	29.92	12.84	11.31	1.01	78473.66	17.05	7.82	0.78	194.90	14.81
14	1.90	32.29	13.14	11.55	0.96	78095.34	16.72	7.94	0.74	196.10	15.08
15	2.49	29.93	14.17	11.60	0.98	77426.12	16.20	9.14	0.75	196.32	14.95
16	2.46	31.09	13.20	11.59	0.97	77411.70	15.89	9.52	0.75	195.14	14.85
17	2.08	31.00	13.67	11.66	0.96	76637.05	16.51	8.69	0.74	197.32	14.98
18	1.99	29.61	13.07	11.68	0.97	75831.63	16.70	8.36	0.75	196.70	14.87
19	2.03	28.76	12.66	11.63	1.00	75549.23	16.83	8.18	0.77	196.83	14.76
20	1.67	26.10	12.77	11.33	1.01	76720.47	17.43	7.93	0.78	195.25	14.59
21	1.88	23.46	12.56	11.49	1.00	76554.40	17.51	8.49	0.77	197.26	14.87
22	2.08	27.97	13.23	11.66	0.98	76059.92	16.72	8.74	0.76	197.07	14.91
23	1.82	27.26	14.52	11.62	0.99	75879.34	16.73	8.67	0.76	198.88	14.86
24	1.76	30.24	13.11	11.60	0.95	76158.53	17.09	8.84	0.73	198.10	14.93
25	1.40	29.54	12.73	11.58	0.92	76250.99	17.41	8.69	0.71	198.65	14.99
26	1.63	26.88	13.36	11.58	0.96	75331.79	17.30	8.24	0.74	197.18	14.74
27	1.57	23.67	13.51	11.65	1.00	75235.67	17.58	8.01	0.77	196.94	14.87
28	1.86	20.63	13.55	11.67	1.02	75176.91	17.37	7.17	0.78	196.47	14.87
29	2.03	24.24	13.92	11.70	0.99	75460.74	16.82	6.16	0.76	195.23	14.80
30	1.58	26.47	11.88	11.64	0.96	74279.66	17.14	7.02	0.75	194.87	14.53
31	1.47	24.89	12.18	11.64	1.00	74154.10	17.27	8.07	0.77	195.73	14.55
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.17	29.79	12.93	11.47	1.00	77003.09	17.02	7.95	0.77	195.67	14.80
最大值	4.52	39.03	14.52	11.99	1.06	82994.82	18.10	9.52	0.82	198.88	15.13
發生日期											
最小值	1.39	20.63	10.92	10.58	0.92	73383.67	15.82	5.81	0.71	190.49	14.29
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管