

連續自動監測紀錄月報表

中華民國108年10月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	10.03	59.18	6.25	10.52	2.20	81604.98	18.08	14.79	0.92	177.15	13.86
02	10.07	58.02	8.88	10.68	2.25	80772.53	18.49	13.39	0.94	179.91	14.11
03	10.00	62.53	8.90	10.61	2.18	79733.25	18.76	12.37	0.91	176.67	13.78
04	10.11	58.77	8.49	10.69	2.19	80435.55	18.35	13.62	0.91	181.31	14.07
05	10.49	57.65	9.85	10.79	2.27	80432.65	18.01	14.97	0.94	176.90	14.04
06	10.55	55.36	8.12	10.72	2.26	79665.46	18.04	14.68	0.94	175.53	13.75
07	10.50	52.66	8.31	10.56	2.21	80613.95	18.29	13.63	0.92	175.77	13.75
08	10.69	55.24	11.44	10.93	2.16	79054.67	17.33	13.67	0.90	175.82	13.82
09	10.72	58.99	15.52	10.90	2.16	78728.93	17.10	15.68	0.90	173.02	13.60
10	10.26	60.56	7.92	10.91	2.15	79831.52	17.41	14.49	0.90	176.42	13.96
11	10.53	60.48	9.97	11.06	2.18	79396.87	17.18	14.61	0.91	177.04	14.08
12	10.29	57.80	10.73	10.98	2.20	79025.44	17.22	13.91	0.92	175.27	13.83
13	10.08	57.91	6.11	10.77	2.17	79748.22	17.78	13.18	0.91	175.87	13.79
14	10.11	59.14	6.19	10.86	2.12	79252.67	17.12	12.73	0.88	175.06	13.69
15	10.19	59.49	7.03	11.17	2.11	77970.56	16.79	12.90	0.88	176.19	13.89
16	10.05	57.32	7.57	10.87	2.14	79749.43	17.90	13.41	0.89	176.66	13.98
17	10.39	57.77	8.70	10.93	2.18	78890.19	17.02	15.37	0.91	174.66	13.70
18	10.22	55.73	8.55	11.08	2.15	78459.47	16.62	13.44	0.89	174.15	13.76
19	10.60	58.18	8.86	10.94	2.19	79527.22	16.84	16.34	0.91	174.00	13.78
20	10.42	55.64	8.85	10.97	2.22	78797.34	16.63	16.19	0.93	174.25	13.67
21	9.72	54.97	4.64	10.85	2.24	78420.72	17.41	11.30	0.93	173.60	13.54
22	9.87	53.56	7.10	10.99	2.24	78500.66	17.15	11.42	0.93	174.72	13.74
23	10.10	48.73	8.97	11.06	2.22	77761.97	16.92	12.46	0.93	174.50	13.65
24	9.78	48.74	9.86	10.93	2.16	77886.03	16.77	11.32	0.90	173.18	13.44
25	10.15	51.58	12.03	10.98	2.11	78020.26	16.49	12.88	0.88	173.99	13.53
26	10.39	52.73	12.24	11.01	2.09	78903.52	15.93	14.63	0.87	174.16	13.62
27	10.03	50.71	7.94	10.88	2.14	79582.06	16.67	12.40	0.89	175.87	13.74
28	9.96	50.92	7.93	10.86	2.15	79468.38	17.02	12.59	0.90	176.09	13.74
29	10.09	51.52	8.64	11.09	2.08	77586.53	16.73	13.52	0.87	174.64	13.64
30	9.79	50.41	6.56	10.90	2.06	78216.12	17.03	11.77	0.86	173.13	13.50
31	9.53	48.10	7.25	10.86	2.11	78773.42	17.05	12.73	0.88	174.78	13.60
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	10.18	55.50	8.69	10.88	2.17	79187.44	17.29	13.56	0.90	175.49	13.76
最大值	10.72	62.53	15.52	11.17	2.27	81604.98	18.76	16.34	0.94	181.31	14.11
發生日期											
最小值	9.53	48.10	4.64	10.52	2.06	77586.53	15.93	11.30	0.86	173.02	13.44
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國108年10月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	13.40	70.22	10.82	11.26	2.65	77165.15	16.62	10.69	1.10	183.77	14.08
02	13.69	71.09	9.63	11.25	2.59	78787.88	17.25	12.36	1.08	188.30	14.62
03	13.72	67.88	12.21	11.21	2.58	78479.77	17.12	12.87	1.08	187.00	14.42
04	13.61	70.05	13.40	11.29	2.60	77614.77	17.09	12.08	1.08	185.89	14.35
05	14.26	74.34	12.78	11.40	2.57	77411.58	16.93	13.43	1.07	184.67	14.46
06	14.54	73.34	11.04	11.43	2.50	75385.93	16.80	13.01	1.04	182.89	13.99
07	14.35	70.09	11.18	11.34	2.53	75575.08	16.59	11.23	1.05	182.57	13.86
08	14.88	74.36	11.15	11.45	2.55	75464.82	16.48	10.82	1.06	182.41	13.98
09	14.93	71.61	13.68	11.52	2.48	74543.95	15.94	13.02	1.03	182.97	13.84
10	14.58	74.72	10.82	11.50	2.51	76267.67	16.05	11.90	1.05	184.15	14.18
11	15.04	75.64	10.96	11.57	2.51	76244.51	16.17	12.17	1.05	184.36	14.32
12	14.84	71.80	11.23	11.55	2.54	74761.83	16.24	12.68	1.06	181.79	13.93
13	14.67	67.89	9.29	11.49	2.64	75441.19	16.40	12.02	1.10	183.41	14.04
14	14.56	68.21	10.96	11.53	2.59	75130.81	15.72	10.87	1.08	181.86	13.89
15	14.54	68.34	9.68	11.52	2.50	74638.74	16.03	11.43	1.04	180.34	13.79
16	15.02	67.60	13.52	11.62	2.54	74795.91	15.59	12.39	1.06	180.78	13.90
17	14.84	68.00	10.17	11.57	2.52	75203.78	16.02	11.89	1.05	181.84	14.01
18	14.88	70.04	12.52	11.53	2.58	77142.21	16.42	11.70	1.07	184.40	14.46
19	15.81	69.60	12.81	11.67	2.64	74316.63	16.33	13.70	1.10	181.58	14.04
20	15.78	68.20	15.74	11.45	2.73	76058.35	16.25	13.87	1.14	182.30	14.03
21	14.94	68.91	13.75	11.36	2.66	76110.51	16.56	11.33	1.11	181.31	13.95
22	14.95	65.49	13.75	11.50	2.62	74185.93	16.41	11.71	1.09	180.22	13.73
23	15.55	70.58	14.51	11.53	2.65	73395.56	15.87	12.31	1.10	178.10	13.49
24	15.35	66.64	14.33	11.56	2.61	73665.46	15.49	12.07	1.09	178.22	13.52
25	15.48	67.88	15.57	11.63	2.54	73839.76	15.62	12.78	1.06	180.38	13.75
26	14.78	66.80	11.32	11.35	2.50	76414.72	15.53	12.42	1.04	180.64	13.75
27	14.37	63.33	13.75	10.67	2.50	82181.99	15.67	11.73	1.04	181.63	13.92
28	14.03	61.34	13.35	10.30	2.49	84864.15	16.07	11.18	1.04	182.02	13.94
29	11.45	64.12	13.41	11.05	2.57	80616.16	16.53	12.27	1.07	183.26	14.36
30	9.36	61.99	10.61	11.36	2.66	77257.13	16.50	11.91	1.11	183.90	14.23
31	9.35	62.98	11.10	11.42	2.75	76824.18	16.56	13.67	1.15	185.09	14.28
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	14.24	68.81	12.23	11.38	2.58	76444.71	16.29	12.18	1.07	182.65	14.04
最大值	15.81	75.64	15.74	11.67	2.75	84864.15	17.25	13.87	1.15	188.30	14.62
發生日期											
最小值	9.35	61.34	9.29	10.30	2.48	73395.56	15.49	10.69	1.03	178.10	13.49
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管