

連續自動監測紀錄月報表

中華民國112年2月28日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	3.08	50.41	7.44	10.67	2.05	79604.08	16.70	9.62	1.37	184.59	13.74
02	2.94	48.79	6.25	10.50	2.04	79840.97	16.88	9.51	1.36	186.11	13.62
03	2.58	55.23	10.05	10.69	1.99	80031.64	17.15	9.97	1.33	188.12	14.01
04	2.43	49.67	5.72	10.59	1.96	79909.24	17.25	9.38	1.31	186.65	13.83
05	2.51	48.05	4.95	10.45	1.95	79973.95	18.02	9.43	1.30	185.54	13.75
06	2.77	47.93	6.29	10.60	1.93	78868.98	17.09	9.30	1.28	183.00	13.53
07	2.55	50.37	6.66	10.60	1.94	79299.24	17.53	9.12	1.29	184.31	13.72
08	3.03	56.12	6.52	11.86	1.96	69500.14	17.88	10.59	1.31	183.51	13.69
09	3.30	46.93	6.94	9.80	1.92	84728.46	17.81	9.55	1.28	182.34	13.58
10	3.80	48.72	7.34	10.09	1.92	83871.88	17.66	9.93	1.28	183.43	13.81
11	3.79	46.80	8.29	9.91	1.90	85263.12	17.65	9.92	1.26	183.67	13.82
12	3.79	50.48	7.01	9.98	1.86	84524.09	18.14	9.54	1.24	184.34	13.90
13	4.34	54.51	6.83	10.49	1.89	82959.63	16.95	9.83	1.26	179.56	13.96
14	4.28	56.64	7.59	10.32	1.84	84855.58	16.97	10.31	1.23	182.62	14.14
15	4.25	56.81	8.02	10.69	1.87	85586.96	16.08	10.01	1.24	179.26	14.51
16	3.97	54.99	7.33	10.65	1.85	83246.64	16.01	9.63	1.23	179.28	14.05
17	3.85	57.63	8.14	11.05	1.89	77347.43	16.93	10.14	1.26	184.14	13.87
18	4.11	60.57	6.57	11.71	1.94	73776.25	16.71	10.75	1.29	184.44	14.08
19	4.34	51.11	6.18	10.42	1.92	83164.42	16.73	10.60	1.28	183.15	13.97
20	4.27	51.03	5.27	10.71	1.93	82217.21	15.86	9.87	1.28	183.10	14.03
21	4.62	51.53	5.59	11.12	1.94	80058.74	15.30	9.79	1.29	183.99	14.18
22	4.41	51.89	5.97	11.06	1.94	79973.00	15.63	9.88	1.94	184.39	14.14
23	4.45	49.84	7.70	10.95	1.90	78882.48	15.91	10.27	1.27	182.70	13.79
24	4.47	51.39	7.30	11.08	1.88	78622.27	15.94	10.49	1.25	182.34	13.91
25	4.05	52.03	7.01	11.04	1.92	80911.27	15.96	10.25	1.28	184.46	14.33
26	4.70	48.34	7.89	10.95	1.97	81181.94	15.50	10.52	1.32	184.37	14.18
27	4.68	46.67	7.89	10.92	1.99	80137.36	15.72	11.31	1.33	184.06	13.98
28	4.28	47.05	6.49	11.00	2.03	79029.89	16.29	10.20	1.30	185.36	14.03
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	3.77	51.48	6.97	10.71	1.93	80620.25	16.72	9.99	1.31	183.67	13.93
最大值	4.70	60.57	10.05	11.86	2.05	85586.96	18.14	11.31	1.94	188.12	14.51
發生日期											
最小值	2.43	46.67	4.95	9.80	1.84	69500.14	15.30	9.12	1.23	179.26	13.53
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主任

連續自動監測紀錄月報表

中華民國112年2月28日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.51	51.29	8.81	11.09	1.73	83425.96	17.25	9.94	1.16	196.55	15.53
02	3.32	52.32	7.48	11.26	1.72	82814.80	16.62	9.48	1.15	196.35	15.53
03	3.31	53.42	8.80	11.09	1.67	84185.42	17.46	11.22	1.11	196.47	15.66
04	3.42	50.37	8.32	11.05	1.65	83870.09	17.76	9.96	1.10	195.72	15.57
05	3.29	49.62	7.36	11.05	1.70	84280.67	18.22	9.45	1.14	195.99	15.85
06	2.73	49.20	10.97	10.94	1.68	83059.76	18.00	9.33	1.12	194.88	15.30
07	2.08	48.42	7.54	11.03	1.66	81346.66	18.20	10.30	1.11	195.31	15.16
08	1.87	53.36	7.70	11.13	1.60	80369.54	17.96	10.06	1.06	195.31	15.08
09	2.21	51.96	7.19	11.00	1.61	81889.62	17.90	9.43	1.07	194.53	15.12
10	2.28	50.73	7.22	11.10	1.63	81368.73	17.76	11.69	1.08	195.67	15.20
11	2.21	48.95	6.49	11.04	1.64	81710.25	17.92	11.70	1.09	195.81	15.19
12	2.04	46.14	7.39	10.83	1.65	82271.16	18.67	10.75	1.10	196.22	15.15
13	2.15	49.37	7.81	10.90	1.69	82229.40	18.12	10.04	1.13	195.63	15.12
14	2.37	56.33	6.37	11.32	1.68	82301.80	17.01	10.30	1.12	191.93	15.45
15	2.68	57.62	8.16	11.06	1.74	83406.15	17.20	11.32	1.17	195.01	15.39
16	2.67	56.21	7.83	11.08	1.75	83099.21	16.70	11.69	1.17	194.68	15.26
17	1.96	58.24	7.22	11.17	1.78	81801.85	17.17	10.17	1.19	196.38	15.31
18	2.26	59.78	8.06	11.09	1.80	84287.60	17.31	11.42	1.20	196.18	15.38
19	2.41	52.57	6.41	10.66	1.78	85972.57	17.51	12.30	1.19	195.33	15.32
20	2.04	56.62	6.45	11.02	1.70	83931.20	16.68	10.48	1.13	196.76	15.38
21	2.02	58.75	7.86	11.22	1.63	82568.29	16.61	9.87	1.08	195.35	15.38
22	2.05	57.57	6.48	11.17	1.63	82432.24	17.06	10.14	1.09	195.44	15.36
23	2.24	54.90	8.79	11.10	1.67	81935.16	17.20	11.58	1.11	194.61	15.15
24	2.35	58.16	8.02	11.28	1.66	81380.27	16.83	11.61	1.11	194.59	15.28
25	2.11	59.80	7.18	11.16	1.61	82993.18	17.17	11.19	1.07	195.66	15.47
26	2.54	55.98	7.73	11.07	1.54	83637.11	16.82	11.56	1.03	199.09	15.50
27	3.26	54.76	8.35	11.33	1.52	80896.53	16.67	12.30	1.01	193.91	15.20
28	2.73	56.62	8.57	11.31	1.50	80392.34	17.27	10.62	1.00	198.31	15.33
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	2.50	53.90	7.73	11.09	1.67	82637.77	17.39	10.71	1.11	195.63	15.34
最大值	3.51	59.80	10.97	11.33	1.80	85972.57	18.67	12.30	1.20	199.09	15.85
發生日期											
最小值	1.87	46.14	6.37	10.66	1.50	80369.54	16.61	9.33	1.00	191.93	15.08
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主任