

連續自動監測紀錄月報表

中華民國114年04月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	0.85	42.87	10.09	10.96	1.32	75891.05	19.96	8.38	1.01	179.61	13.86
02	1.41	50.15	9.79	10.99	1.33	75928.15	19.32	8.42	1.02	178.96	13.78
03	1.37	57.46	8.66	10.79	1.35	76388.94	19.10	8.52	1.04	180.21	13.58
04	1.16	55.67	8.48	10.60	1.38	76187.46	19.93	8.04	1.07	179.73	13.43
05	1.41	53.75	8.31	10.65	1.39	76047.93	19.93	7.62	1.07	178.84	13.45
06	1.49	51.22	7.97	10.59	1.37	76331.57	20.36	7.92	1.06	179.00	13.49
07	1.69	52.66	8.27	10.47	1.38	76722.90	19.89	8.08	1.07	180.30	13.37
08	1.51	55.95	8.54	10.39	1.35	77594.36	19.79	8.50	1.05	181.69	13.43
09	1.68	55.46	8.58	10.14	1.34	79120.87	19.52	8.31	1.03	181.24	13.34
10	1.30	54.59	8.38	10.13	1.33	78588.30	20.30	8.10	1.03	180.12	13.33
11	1.19	53.14	8.49	10.07	1.36	79735.34	20.58	8.21	1.05	182.97	13.58
12	1.30	55.63	9.13	10.14	1.37	79062.50	20.40	7.84	1.06	182.89	13.52
13	1.59	51.95	7.65	10.11	1.28	80203.08	20.04	7.89	0.99	180.91	13.56
14	1.52	47.69	9.09	10.07	1.29	79523.38	19.83	7.95	1.00	180.64	13.36
15	1.70	51.55	9.41	10.25	1.30	79129.99	19.51	7.73	1.01	180.42	13.45
16	3.13	56.08	10.07	10.20	1.32	79243.53	19.35	8.94	1.02	180.10	13.37
17	3.22	58.52	10.26	10.22	1.30	78956.32	19.37	8.35	1.00	179.89	13.33
18	2.33	57.38	11.19	10.31	1.31	78884.62	19.41	9.02	1.01	180.03	13.45
19	1.90	55.40	10.61	10.26	1.30	78792.96	19.48	9.39	1.00	178.28	13.34
20	1.93	55.00	9.83	10.09	1.30	79637.75	20.27	10.02	1.00	177.78	13.39
21	1.68	56.35	8.74	10.03	1.29	78708.55	20.54	8.64	1.00	178.90	13.23
22	1.58	58.12	9.23	10.16	1.31	78514.36	20.38	8.09	1.01	180.94	13.38
23	2.44	57.36	9.74	10.18	1.30	79174.14	20.05	8.79	1.00	180.55	13.46
24	2.73	56.64	9.47	10.07	1.27	78863.51	20.08	9.06	0.98	179.02	13.23
25	1.77	53.39	10.60	9.93	1.26	79052.87	20.67	8.75	0.98	178.72	13.18
26	1.80	54.29	9.67	9.88	1.27	79143.27	20.52	8.44	0.98	178.05	13.08
27	1.68	51.48	10.55	9.74	1.30	78977.23	21.27	8.40	1.01	180.19	13.09
28	1.90	55.11	8.61	9.80	1.27	79681.19	20.92	8.24	0.98	179.55	13.20
29	1.77	53.18	7.73	10.05	1.30	79750.62	20.15	8.76	1.00	180.84	13.42
30	2.13	52.25	8.67	10.02	1.31	79086.49	20.23	8.46	1.01	181.61	13.31
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	1.77	54.01	9.19	10.24	1.32	78430.77	20.04	8.43	1.02	180.07	13.40
最大值	3.22	58.52	11.19	10.99	1.39	80203.08	21.27	10.02	1.07	182.97	13.86
發生日期											
最小值	0.85	42.87	7.65	9.74	1.26	75891.05	19.10	7.62	0.98	177.78	13.08
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國114年04月30日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂ 二氧化 硫	NO _x 氮氧化 物	CO 一氧化 碳	O ₂ 氧氣	DUST 粉塵濃 度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光 率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	3.27	30.93	11.52	10.31	0.81	74131.15	17.30	7.61	0.62	175.64	12.20
02	4.30	34.76	12.17	10.47	0.82	74500.54	16.54	7.98	0.63	176.57	12.36
03	4.46	35.59	11.11	10.35	0.85	73784.82	16.20	8.02	0.65	176.84	12.06
04	3.76	39.67	10.60	9.54	0.86	77538.55	18.05	7.88	0.66	177.67	12.09
05	3.35	37.06	10.97	9.00	0.84	79942.81	19.03	7.79	0.64	176.33	11.99
06	3.23	34.44	12.09	8.78	0.86	81612.17	19.98	7.81	0.66	178.13	12.22
07	3.63	35.73	11.33	8.53	0.88	82002.10	19.76	8.14	0.67	177.51	11.98
08	3.18	37.69	11.68	8.92	0.94	79511.26	19.94	8.33	0.73	179.09	12.05
09	3.24	41.64	12.03	9.33	0.96	76310.40	19.78	7.79	0.74	178.19	11.94
10	3.06	38.81	12.67	9.34	0.90	75892.10	20.29	7.62	0.69	177.38	11.93
11	3.58	39.20	11.71	9.14	0.92	77577.41	20.83	7.84	0.70	179.73	12.13
12	3.14	38.68	12.28	9.20	0.92	76638.11	20.69	7.90	0.71	178.89	12.00
13	3.53	39.49	12.45	9.47	0.86	76983.32	19.87	8.18	0.66	178.68	12.21
14	3.25	39.19	11.06	9.43	0.87	76677.10	19.62	7.47	0.67	178.41	12.07
15	3.25	40.69	11.36	9.50	0.91	77061.96	19.80	7.54	0.70	179.96	12.29
16	5.18	43.26	11.56	9.66	0.92	76175.11	18.90	8.49	0.71	179.69	12.17
17	4.88	45.53	11.77	9.72	0.92	74694.53	19.22	8.35	0.71	178.74	12.01
18	4.66	48.69	12.07	10.11	0.92	72081.79	19.31	8.59	0.71	179.50	12.04
19	4.63	46.69	12.36	10.10	0.91	71173.29	19.15	7.84	0.70	178.00	11.82
20	4.37	41.08	12.05	9.91	0.90	71768.68	20.12	7.84	0.69	178.28	11.86
21	3.64	40.27	12.69	9.83	0.92	71697.94	20.49	8.21	0.71	178.70	11.83
22	3.44	44.80	12.19	9.99	0.93	71779.19	20.26	7.89	0.72	179.95	12.01
23	4.64	50.08	12.90	10.48	0.98	72384.43	18.98	8.58	0.76	183.27	12.58
24	4.42	49.77	13.13	10.47	1.05	72706.54	18.97	8.19	0.81	182.76	12.60
25	3.66	49.66	12.98	10.29	0.97	73147.69	19.85	8.19	0.75	182.85	12.61
26	3.82	50.80	12.10	10.33	0.87	72540.35	19.66	8.04	0.67	181.93	12.48
27	3.92	47.12	11.81	10.16	0.87	72670.87	20.19	7.50	0.66	182.70	12.41
28	3.59	47.42	11.72	10.26	0.89	72696.21	19.75	7.84	0.68	182.58	12.47
29	3.81	48.48	12.26	10.44	0.93	73134.30	19.18	7.76	0.71	183.89	12.70
30	4.07	50.62	12.70	10.50	0.98	73462.16	19.25	8.20	0.76	186.07	12.91
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.83	42.26	11.98	9.79	0.91	75075.90	19.37	7.98	0.70	179.60	12.20
最大值	5.18	50.80	13.13	10.50	1.05	82002.10	20.83	8.59	0.81	186.07	12.91
發生日期											
最小值	3.06	30.93	10.60	8.53	0.81	71173.29	16.20	7.47	0.62	175.64	11.82
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管