

連續自動監測紀錄月報表

中華民國113年9月30日

| 項目 日期 | 管制編號 | | | F0501686 | | 煙道排放口編 | | P001 | | | |
|----------|-----------------|-----------------|-------|----------------|-------------------|---------------------|------------------|------|------|--------|-------|
| | SO ₂ | NO _x | CO | O ₂ | DUST | MASS | H ₂ O | HCL | OPAC | TEMP | VEL |
| | 二氧化硫 | 氮氧化物 | 一氧化碳 | 氧氣 | 粉塵濃度 | 排放流率 | 水份 | 鹽酸 | 不透光率 | 溫度 | 流速 |
| | ppm | ppm | ppm | % | mg/m ³ | Nm ³ /hr | % | ppm | % | °C | m/s |
| 01 | 2.32 | 48.53 | 11.34 | 8.87 | 1.29 | 86319.17 | 20.14 | 7.91 | 0.99 | 183.90 | 13.20 |
| 02 | 2.00 | 48.58 | 9.25 | 8.69 | 1.27 | 86651.17 | 20.49 | 7.71 | 0.98 | 183.06 | 13.09 |
| 03 | 2.39 | 47.94 | 9.99 | 8.82 | 1.26 | 86937.19 | 19.97 | 7.82 | 0.97 | 182.89 | 13.19 |
| 04 | 2.78 | 48.90 | 9.84 | 8.97 | 1.24 | 86267.40 | 19.42 | 7.74 | 0.96 | 182.14 | 13.13 |
| 05 | 2.76 | 52.17 | 12.13 | 9.42 | 1.27 | 82915.54 | 19.56 | 7.39 | 0.98 | 182.01 | 13.14 |
| 06 | 2.64 | 57.12 | 12.99 | 10.01 | 1.26 | 79083.28 | 19.15 | 7.79 | 0.98 | 182.64 | 13.15 |
| 07 | 2.47 | 55.93 | 12.33 | 10.02 | 1.24 | 79323.22 | 19.49 | 7.86 | 0.96 | 182.57 | 13.25 |
| 08 | 2.46 | 52.67 | 13.34 | 9.97 | 1.25 | 79298.14 | 19.48 | 7.83 | 0.97 | 182.39 | 13.18 |
| 09 | 2.23 | 51.00 | 11.14 | 9.79 | 1.27 | 79571.50 | 20.32 | 7.56 | 0.98 | 182.51 | 13.16 |
| 10 | 2.44 | 49.59 | 11.31 | 9.99 | 1.29 | 78717.68 | 19.80 | 7.38 | 1.00 | 182.00 | 13.16 |
| 11 | 2.77 | 49.88 | 11.54 | 10.04 | 1.25 | 78817.82 | 19.32 | 8.78 | 0.97 | 182.28 | 13.16 |
| 12 | 2.81 | 51.88 | 11.51 | 9.95 | 1.25 | 79328.70 | 19.40 | 9.24 | 0.97 | 182.50 | 13.15 |
| 13 | 2.82 | 56.85 | 12.18 | 10.09 | 1.26 | 80100.74 | 18.94 | 8.48 | 0.97 | 183.17 | 13.40 |
| 14 | 2.66 | 54.61 | 11.76 | 10.18 | 1.23 | 79217.90 | 19.18 | 8.16 | 0.96 | 182.28 | 13.38 |
| 15 | 2.51 | 52.44 | 12.01 | 10.08 | 1.21 | 79407.39 | 19.54 | 7.75 | 0.94 | 182.84 | 13.36 |
| 16 | 2.34 | 51.99 | 12.42 | 9.90 | 1.25 | 80385.05 | 19.86 | 8.25 | 0.97 | 183.67 | 13.38 |
| 17 | 2.15 | 52.19 | 10.53 | 9.82 | 1.27 | 79428.24 | 20.09 | 7.83 | 0.98 | 182.50 | 13.14 |
| 18 | 2.18 | 49.30 | 10.75 | 9.87 | 1.30 | 79315.66 | 20.31 | 7.43 | 1.00 | 182.97 | 13.21 |
| 19 | 1.93 | 48.72 | 9.01 | 9.87 | 1.29 | 79404.09 | 20.25 | 7.34 | 1.00 | 184.03 | 13.26 |
| 20 | 1.78 | 49.05 | 10.56 | 9.89 | 1.31 | 79984.43 | 20.50 | 7.64 | 1.01 | 185.68 | 13.47 |
| 21 | 2.18 | 49.83 | 11.32 | 10.04 | 1.32 | 79628.03 | 20.02 | 8.36 | 1.01 | 184.72 | 13.48 |
| 22 | 1.97 | 51.74 | 11.88 | 9.98 | 1.30 | 80511.40 | 20.33 | 7.64 | 1.00 | 185.66 | 13.64 |
| 23 | 1.74 | 48.01 | 11.15 | 9.78 | 1.27 | 80304.22 | 20.77 | 7.76 | 0.98 | 185.33 | 13.44 |
| 24 | 0.92 | 50.41 | 11.67 | 9.90 | 1.28 | 80487.02 | 20.84 | 3.60 | 0.99 | 186.54 | 13.65 |
| 25 | 1.56 | 48.33 | 11.32 | 9.94 | 1.28 | 79654.18 | 20.74 | 6.04 | 0.99 | 185.73 | 13.50 |
| 26 | 1.95 | 47.21 | 11.37 | 9.87 | 1.29 | 80324.76 | 20.50 | 7.90 | 1.00 | 184.94 | 13.48 |
| 27 | 2.30 | 46.64 | 10.78 | 10.01 | 1.32 | 79656.09 | 19.90 | 8.22 | 1.02 | 183.77 | 13.41 |
| 28 | 2.31 | 47.92 | 11.55 | 10.07 | 1.32 | 80381.05 | 19.99 | 9.30 | 1.01 | 184.84 | 13.65 |
| 29 | 2.20 | 54.84 | 11.86 | 10.14 | 1.29 | 81594.63 | 20.13 | 8.49 | 1.00 | 187.42 | 14.04 |
| 30 | 1.92 | 53.96 | 11.62 | 10.09 | 1.29 | 81531.77 | 20.39 | 7.49 | 0.99 | 188.02 | 14.03 |
| 監測日數 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 |
| 平均值 | 2.25 | 50.94 | 11.35 | 9.80 | 1.27 | 80818.25 | 19.96 | 7.76 | 0.98 | 183.83 | 13.36 |
| 最大值 | 2.82 | 57.12 | 13.34 | 10.18 | 1.32 | 86937.19 | 20.84 | 9.30 | 1.02 | 188.02 | 14.04 |
| 發生日期 | | | | | | | | | | | |
| 最小值 | 0.92 | 46.64 | 9.01 | 8.69 | 1.21 | 78717.68 | 18.94 | 3.60 | 0.94 | 182.00 | 13.09 |
| 發生日期 | | | | | | | | | | | |
| 超標準時數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 標準值 | 150 | 220 | 150 | ----- | ----- | ----- | ----- | 60 | 20 | ----- | ----- |
| 備註 | | | | | | | | | | | |

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國113年9月30日

| | | | | 管制編號 | | F0501686 | | 煙道排放口編 | | P002 | |
|----------|-----------------|-----------------|-------|----------------|-------------------|---------------------|------------------|--------|------|--------|-------|
| 項目 日期 | SO ₂ | NO _x | CO | O ₂ | DUST | MASS | H ₂ O | HCL | OPAC | TEMP | VEL |
| | 二氧化硫 | 氮氧化物 | 一氧化碳 | 氧氣 | 粉塵濃度 | 排放流率 | 水份 | 鹽酸 | 不透光率 | 溫度 | 流速 |
| | ppm | ppm | ppm | % | mg/m ³ | Nm ³ /hr | % | ppm | % | °C | m/s |
| 01 | 1.99 | 36.87 | 10.73 | 8.92 | 1.04 | 89077.17 | 20.44 | 8.21 | 0.80 | 192.97 | 14.00 |
| 02 | 1.29 | 34.99 | 10.96 | 8.81 | 1.06 | 89305.40 | 20.88 | 6.67 | 0.81 | 192.85 | 13.98 |
| 03 | 1.53 | 35.62 | 10.66 | 8.93 | 1.06 | 90091.11 | 20.37 | 6.64 | 0.81 | 193.08 | 14.17 |
| 04 | 2.19 | 35.21 | 10.67 | 9.00 | 1.05 | 88736.04 | 19.82 | 7.41 | 0.80 | 191.30 | 13.89 |
| 05 | 2.14 | 36.20 | 12.43 | 9.20 | 1.06 | 86564.53 | 19.89 | 7.25 | 0.81 | 190.39 | 13.76 |
| 06 | 1.85 | 42.06 | 12.18 | 9.60 | 1.09 | 84352.83 | 19.33 | 7.11 | 0.83 | 191.47 | 13.82 |
| 07 | 1.48 | 39.33 | 11.72 | 9.52 | 1.13 | 85332.73 | 19.93 | 7.25 | 0.87 | 191.88 | 13.99 |
| 08 | 1.71 | 35.91 | 11.63 | 9.50 | 1.16 | 85059.43 | 19.77 | 6.25 | 0.89 | 191.33 | 13.88 |
| 09 | 1.33 | 35.78 | 11.13 | 9.35 | 1.10 | 85179.71 | 20.70 | 6.63 | 0.85 | 191.67 | 13.89 |
| 10 | 1.65 | 39.09 | 12.40 | 9.56 | 1.15 | 86007.66 | 19.87 | 6.63 | 0.89 | 192.98 | 14.18 |
| 11 | 1.99 | 38.11 | 11.29 | 9.55 | 1.20 | 85596.72 | 19.74 | 7.63 | 0.92 | 191.92 | 14.05 |
| 12 | 1.88 | 36.27 | 12.06 | 9.44 | 1.16 | 85763.79 | 20.10 | 7.64 | 0.90 | 191.29 | 13.98 |
| 13 | 2.26 | 38.81 | 12.41 | 9.52 | 1.12 | 86488.43 | 19.68 | 7.52 | 0.86 | 191.90 | 14.14 |
| 14 | 1.69 | 40.56 | 11.44 | 9.64 | 1.08 | 87231.13 | 19.65 | 7.51 | 0.83 | 193.40 | 14.45 |
| 15 | 1.75 | 37.66 | 11.68 | 9.52 | 1.07 | 86763.69 | 20.07 | 7.08 | 0.83 | 194.02 | 14.32 |
| 16 | 1.21 | 36.35 | 10.86 | 9.41 | 1.07 | 86370.09 | 20.40 | 6.88 | 0.82 | 193.20 | 14.16 |
| 17 | 1.16 | 35.94 | 11.02 | 9.40 | 1.04 | 86763.19 | 20.63 | 6.80 | 0.80 | 194.58 | 14.28 |
| 18 | 1.26 | 35.09 | 10.66 | 9.41 | 1.04 | 86408.78 | 20.91 | 6.63 | 0.80 | 195.14 | 14.32 |
| 19 | 1.25 | 35.64 | 10.06 | 9.53 | 1.04 | 86267.69 | 20.56 | 7.01 | 0.80 | 194.64 | 14.34 |
| 20 | 0.91 | 36.51 | 10.77 | 9.59 | 1.03 | 86707.63 | 20.85 | 6.55 | 0.79 | 197.08 | 14.63 |
| 21 | 1.21 | 37.04 | 11.10 | 9.65 | 0.97 | 86817.15 | 20.48 | 6.77 | 0.75 | 196.02 | 14.63 |
| 22 | 1.30 | 35.62 | 11.17 | 9.49 | 0.94 | 87208.12 | 20.96 | 7.63 | 0.73 | 196.30 | 14.59 |
| 23 | 0.98 | 34.07 | 11.92 | 9.36 | 0.99 | 87093.74 | 21.24 | 6.99 | 0.76 | 195.42 | 14.43 |
| 24 | 0.90 | 34.21 | 10.50 | 9.41 | 1.02 | 87816.81 | 21.52 | 6.99 | 0.78 | 197.21 | 14.72 |
| 25 | 1.35 | 35.30 | 11.97 | 9.38 | 1.03 | 87712.49 | 21.27 | 9.40 | 0.79 | 195.83 | 14.58 |
| 26 | 1.09 | 35.70 | 12.01 | 9.41 | 1.06 | 87634.52 | 21.09 | 8.19 | 0.81 | 196.01 | 14.57 |
| 27 | 1.42 | 36.33 | 11.13 | 9.53 | 1.05 | 87201.12 | 20.39 | 7.19 | 0.81 | 194.77 | 14.48 |
| 28 | 1.42 | 36.20 | 12.05 | 9.54 | 1.00 | 87192.81 | 20.48 | 9.10 | 0.77 | 194.65 | 14.50 |
| 29 | 1.42 | 37.16 | 13.23 | 9.54 | 1.00 | 87602.62 | 20.75 | 8.09 | 0.77 | 195.61 | 14.66 |
| 30 | 1.44 | 34.94 | 12.83 | 9.44 | 0.97 | 87948.46 | 21.09 | 8.30 | 0.75 | 195.36 | 14.64 |
| 監測日數 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 |
| 平均值 | 1.50 | 36.62 | 11.49 | 9.41 | 1.06 | 86943.19 | 20.43 | 7.33 | 0.81 | 193.81 | 14.27 |
| 最大值 | 2.26 | 42.06 | 13.23 | 9.65 | 1.20 | 90091.11 | 21.52 | 9.40 | 0.92 | 197.21 | 14.72 |
| 發生日期 | | | | | | | | | | | |
| 最小值 | 0.90 | 34.07 | 10.06 | 8.81 | 0.94 | 84352.83 | 19.33 | 6.25 | 0.73 | 190.39 | 13.76 |
| 發生日期 | | | | | | | | | | | |
| 超標準時數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 標準值 | 150 | 220 | 150 | ----- | ----- | ----- | ----- | 60 | 20 | ----- | ----- |

備註

廠長

維修組長

操作組長

值班主管