

# 連續自動監測紀錄月報表

中華民國108年9月30日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO <sub>2</sub> 二氧化硫	NO <sub>x</sub> 氮氧化物	CO 一氧化碳	O <sub>2</sub> 氧氣	DUST 粉塵濃度	MASS 排放流率	H <sub>2</sub> O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	℃	m/s
01	11.16	105.48	6.29	10.84	2.07	83475.50	15.88	12.79	0.86	178.25	14.28
02	11.18	96.51	7.03	10.93	2.07	82193.65	15.70	11.44	0.86	177.63	14.13
03	12.40	70.62	10.46	11.08	2.16	83018.98	15.71	13.08	0.90	178.71	14.57
04	12.20	69.32	15.35	11.10	2.29	83553.37	15.80	12.66	0.96	179.64	14.71
05	11.96	69.79	12.32	11.19	2.31	82579.63	15.72	13.58	0.96	178.34	14.63
06	11.79	82.06	11.65	11.21	2.36	81533.06	16.35	12.38	0.98	178.77	14.60
07	11.69	70.69	7.62	11.27	2.35	80922.68	16.29	14.83	0.98	177.90	14.52
08	11.50	69.20	6.46	11.08	2.33	82262.52	16.19	13.55	0.97	177.91	14.47
09	11.07	70.96	7.54	10.92	2.37	83565.85	16.62	13.52	0.99	179.54	14.60
10	11.48	71.23	7.76	11.02	2.41	82485.67	16.48	14.93	1.00	179.79	14.53
11	11.61	70.72	9.11	10.97	2.41	83196.57	16.40	13.97	1.00	182.34	14.66
12	11.65	71.94	9.69	10.85	2.39	83341.57	16.39	15.18	1.00	181.21	14.46
13	11.83	73.70	8.56	11.12	2.39	79784.13	16.63	14.32	1.00	178.62	14.17
14	11.42	71.26	6.86	11.03	2.38	81748.50	16.65	12.58	0.99	179.76	14.44
15	11.34	69.98	6.15	11.06	2.36	79721.47	17.08	12.95	0.98	178.99	14.16
16	10.71	79.45	4.75	10.73	2.40	81860.87	17.61	10.90	1.00	180.93	14.24
17	10.68	81.37	5.28	10.98	2.45	80092.77	17.43	11.93	1.02	180.56	14.26
18	10.57	91.86	4.79	11.10	2.48	81097.65	17.13	12.47	1.03	179.60	14.50
19	10.25	80.02	7.05	11.18	2.50	80734.94	16.95	12.56	1.04	178.74	14.51
20	10.58	75.73	6.58	11.46	2.41	79234.20	16.68	12.39	1.01	177.88	14.57
21	11.01	73.85	8.46	11.32	2.40	80834.66	16.52	14.53	1.00	177.62	14.62
22	11.45	72.46	7.77	11.25	2.40	81347.12	16.15	12.16	1.00	178.69	14.58
23	10.34	67.46	4.89	11.01	2.34	80637.38	16.47	10.62	0.98	176.95	14.08
24	11.00	68.70	8.38	11.07	2.26	81076.16	16.36	13.31	0.94	176.49	14.24
25	10.72	67.98	8.06	10.92	2.21	80858.84	16.56	13.55	0.92	176.26	14.01
26	10.78	68.02	8.19	10.68	2.21	80745.25	17.08	15.52	0.92	175.31	13.72
27	11.38	69.46	8.03	10.95	2.17	79768.74	17.09	15.37	0.91	176.91	13.96
28	11.12	63.69	8.70	10.94	2.13	80475.49	17.07	15.04	0.89	177.08	14.06
29	10.79	61.01	7.85	10.69	2.16	81527.89	17.78	15.13	0.90	177.35	14.03
30	10.42	58.63	7.44	10.59	2.14	81497.23	17.75	13.82	0.89	175.94	13.84
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	11.20	73.77	7.97	11.02	2.31	81505.74	16.62	13.37	0.96	178.46	14.34
最大值	12.40	105.48	15.35	11.46	2.50	83565.85	17.78	15.52	1.04	182.34	14.71
發生日期											
最小值	10.25	58.63	4.75	10.59	2.07	79234.20	15.70	10.62	0.86	175.31	13.72
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國108年9月30日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	13.48	117.13	15.97	11.00	2.87	78521.56	16.16	11.55	1.19	189.65	14.07
02	13.37	100.91	15.72	10.91	2.88	79070.99	16.05	10.27	1.20	191.00	14.06
03	14.19	71.58	14.41	11.15	2.74	78038.20	16.10	11.75	1.14	190.20	14.21
04	14.54	70.04	20.18	11.07	2.61	78494.98	16.24	12.28	1.09	188.06	14.15
05	14.39	69.93	13.10	11.28	2.73	77342.54	15.41	11.90	1.14	185.50	13.98
06	14.37	86.68	13.26	11.28	2.74	77148.33	16.29	13.07	1.14	188.09	14.18
07	14.52	69.86	13.08	11.32	2.67	76988.20	15.94	13.71	1.11	188.06	14.15
08	14.14	69.21	18.01	11.20	2.68	78079.65	16.45	13.14	1.11	188.94	14.29
09	13.80	70.97	13.82	11.07	2.71	78370.97	16.38	12.56	1.13	187.86	14.12
10	14.26	72.65	15.08	11.23	2.76	77707.13	16.31	13.34	1.15	189.77	14.28
11	14.36	73.64	14.32	11.35	2.72	77699.39	15.59	12.65	1.14	189.80	14.32
12	14.93	79.31	14.72	11.21	2.68	78412.48	15.81	13.39	1.12	189.48	14.29
13	14.31	78.04	10.52	11.38	2.73	75893.76	15.96	11.58	1.13	186.83	13.99
14	14.06	78.38	13.93	11.48	2.65	74938.87	15.68	9.83	1.11	186.23	13.91
15	14.19	74.41	12.22	11.29	2.59	76017.22	16.45	10.90	1.08	186.28	13.96
16	13.54	90.35	8.65	11.25	2.56	76417.99	16.70	10.03	1.07	187.39	14.05
17	13.88	81.87	12.34	11.46	2.60	75679.35	16.86	9.63	1.08	187.48	14.23
18	13.72	85.71	8.67	11.55	2.65	74721.12	16.11	10.71	1.10	189.87	14.14
19	13.65	83.49	11.13	11.59	2.78	75416.38	15.38	11.93	1.16	189.95	14.21
20	13.48	75.66	11.26	11.75	2.79	74293.29	15.98	11.75	1.16	190.66	14.37
21	14.19	72.17	12.17	11.67	2.78	75595.97	16.17	12.60	1.16	190.50	14.55
22	13.89	69.31	11.26	11.51	2.83	75752.62	15.87	12.59	1.18	190.46	14.28
23	13.69	72.58	9.92	11.38	2.89	75677.43	15.70	10.95	1.20	187.65	13.95
24	13.81	80.59	11.90	11.32	2.86	76306.79	16.20	11.70	1.19	188.67	14.09
25	13.93	78.33	11.34	11.40	2.80	74906.90	15.55	11.82	1.17	187.07	13.79
26	13.74	76.52	9.92	10.90	2.81	75599.99	16.74	13.70	1.17	184.88	13.37
27	14.40	74.76	9.79	10.88	2.77	75276.42	17.39	14.40	1.16	185.13	13.39
28	14.06	71.40	11.30	11.18	2.74	74233.30	16.37	13.78	1.14	185.71	13.53
29	14.46	70.31	10.46	10.97	2.77	75913.50	16.60	13.71	1.16	185.43	13.51
30	14.33	67.47	11.72	11.24	2.63	77922.63	16.18	11.50	1.09	184.99	14.15
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	14.06	77.78	12.67	11.28	2.73	76547.93	16.15	12.09	1.14	188.05	14.05
最大值	14.93	117.13	20.18	11.75	2.89	79070.99	17.39	14.40	1.20	191.00	14.55
發生日期											
最小值	13.37	67.47	8.65	10.88	2.56	74233.30	15.38	9.63	1.07	184.88	13.37
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管