

# 連續自動監測紀錄月報表

中華民國106年07月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	9.56	83.71	21.67	14.95	1.33	60744.54	23.44	13.22	0.67	119.66	11.1
02	9.71	81.69	21.56	14.89	1.29	61391.74	23.61	13.25	0.64	120.00	11.11
03	9.59	84.36	19.44	14.94	1.32	60815.23	23.73	13.25	0.66	120.06	11.11
04	9.47	85.84	18.07	15.17	1.35	58742.08	23.31	13.02	0.68	120.09	11.14
05	10.01	85.38	23.88	15.14	1.24	59036.48	23.22	13.91	0.62	120.30	11.13
06	10.37	87.35	22.05	14.96	1.28	61090.42	23.56	13.72	0.64	120.91	11.2
07	9.89	87.02	19.02	14.99	1.40	60985.18	23.60	13.13	0.70	120.27	11.24
08	9.76	89.60	17.68	15.05	1.29	60451.83	23.40	13.14	0.64	119.99	11.24
09	9.98	86.11	23.15	15.02	1.28	61093.49	23.72	13.06	0.64	120.08	11.29
10	9.46	70.63	28.91	14.42	1.30	67433.77	24.60	12.27	0.65	121.16	11.38
11	10.28	78.00	24.46	14.77	1.34	63952.47	23.85	13.24	0.67	120.89	11.37
12	10.73	89.48	19.46	15.13	1.29	59145.99	23.54	13.09	0.64	120.57	11.17
13	11.28	91.73	19.76	15.10	1.26	60380.43	23.74	13.40	0.63	121.13	11.35
14	10.57	79.84	27.73	14.69	1.30	64667.44	24.09	12.80	0.65	121.09	11.38
15	11.02	76.74	31.74	14.55	1.39	65855.06	24.42	13.02	0.70	121.45	11.34
16	11.47	72.18	24.89	14.40	1.36	67758.46	24.55	13.81	0.68	121.75	11.43
17	10.84	75.44	21.91	14.62	1.44	65446.45	23.83	13.37	0.72	120.99	11.37
18	10.89	69.66	30.89	14.55	1.47	65827.83	24.34	12.39	0.73	121.52	11.33
19	10.61	68.14	34.33	14.55	1.47	65851.32	23.88	12.14	0.74	121.10	11.33
20	11.01	73.65	28.49	14.52	1.50	65958.12	24.33	12.34	0.75	121.39	11.31
21	11.52	67.47	28.46	14.41	1.48	67546.14	24.55	13.84	0.74	121.75	11.39
22	11.26	70.61	22.38	14.34	1.53	67886.51	24.79	13.43	0.76	121.82	11.34
23	10.64	68.13	25.65	14.21	1.37	69042.82	25.47	13.33	0.69	121.87	11.31
24	10.40	67.75	27.23	14.34	1.31	67612.65	25.23	13.63	0.66	121.54	11.29
25	10.06	64.76	25.38	14.36	1.62	67568.96	24.90	12.84	0.81	121.00	11.31
26	9.27	71.71	22.55	14.50	1.63	67592.89	24.57	11.24	0.81	120.43	11.53
27	9.63	77.66	19.90	14.45	1.60	67904.68	24.68	7.18	0.80	120.41	11.49
28	10.87	71.42	21.76	14.61	1.51	65814.46	24.64	7.83	0.75	121.04	11.44
29	9.72	64.49	24.72	14.42	1.59	66882.31	25.13	9.22	0.79	120.52	11.26
30	28.11	28.28	48.21	12.71	1.72	80000.20	32.17	7.70	0.86	121.34	10.7
31	10.17	58.19	29.71	14.13	1.66	69984.87	26.08	8.05	0.83	119.52	11.29
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	10.91	75.07	25.00	14.61	1.42	64982.74	24.48	12.25	0.71	120.83	11.28
最大值	28.11	91.73	48.21	15.17	1.72	80000.20	32.17	13.91	0.86	121.87	11.53
發生日期	30	13	30	4	30	30	30	5	30	23	26
最小值	9.27	28.28	17.68	12.71	1.24	58742.08	23.22	7.18	0.62	119.52	10.70
發生日期	26	30	8	30	5	4	5	27	5	31	30
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國106年07月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	℃	m/s
01	7.43	74.85	15.77	14.49	3.95	61605.23	20.62	7.47	1.97	128.15	10.97
02	7.70	76.94	12.27	14.42	3.85	63693.00	20.23	7.67	1.92	128.31	11.24
03	7.50	82.55	9.57	14.50	3.87	63892.35	19.51	7.25	1.93	127.98	11.43
04	7.36	85.32	11.56	14.82	4.05	60309.71	20.18	7.17	2.02	128.12	11.32
05	7.74	80.12	11.52	14.42	3.29	63685.88	20.26	8.21	1.64	128.37	11.26
06	7.74	82.73	10.46	14.48	2.04	61699.27	20.23	8.58	1.02	128.57	11
07	7.40	81.08	13.92	14.49	2.06	63205.99	20.01	7.17	1.03	128.30	11.28
08	7.77	81.15	12.88	14.52	2.10	62077.31	20.31	7.15	1.05	127.97	11.13
09	7.94	78.58	12.33	14.36	2.11	63761.37	19.53	7.32	1.05	128.26	11.14
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.06	0.00	0
11	8.11	81.34	24.65	14.52	2.17	59274.93	20.48	7.12	1.08	128.60	10.66
12	8.64	85.85	19.50	14.79	2.12	57651.34	21.49	8.01	1.06	128.98	10.81
13	8.76	80.04	14.52	14.40	2.07	62389.29	20.18	7.56	1.04	129.39	11.02
14	8.57	66.09	20.62	13.88	2.08	69981.12	19.50	6.98	1.04	129.59	11.45
15	8.22	60.36	17.60	13.59	2.05	72078.10	18.34	7.44	1.02	129.93	11.34
16	8.35	60.80	20.83	13.71	2.02	70318.29	18.89	6.94	1.01	129.76	11.25
17	7.86	64.74	17.28	13.86	2.05	68372.38	19.88	6.22	1.03	129.41	11.16
18	8.15	67.08	13.87	13.92	2.05	69515.35	19.14	6.75	1.02	129.86	11.46
19	8.44	64.72	19.04	13.85	1.99	69372.36	19.81	7.07	0.99	129.59	11.29
20	8.32	62.50	15.59	13.70	2.01	71802.11	18.85	6.76	1.00	129.93	11.45
21	8.67	61.24	17.79	13.62	2.02	73266.81	18.19	6.90	1.01	130.26	11.6
22	8.42	58.75	22.40	13.62	1.98	71949.66	18.79	6.76	0.99	130.12	11.38
23	8.19	56.71	22.26	13.53	1.99	72893.65	17.65	6.65	0.99	130.13	11.39
24	8.34	60.19	18.95	13.67	2.05	72771.50	18.06	8.00	1.02	130.15	11.59
25	8.76	73.30	16.06	13.95	2.02	70813.65	19.12	7.71	1.01	130.23	11.73
26	7.94	75.49	15.71	13.91	2.00	72439.78	18.02	6.99	1.00	129.61	11.92
27	7.96	71.54	12.03	13.81	2.01	71845.08	18.60	4.63	1.01	129.32	11.63
28	8.56	75.88	12.32	14.09	2.03	71452.55	18.67	4.09	1.01	130.20	12.08
29	8.40	70.58	14.98	14.01	2.07	73194.63	17.79	3.94	1.04	129.63	12.21
30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
31	8.68	93.24	25.99	15.20	2.09	57537.74	21.82	4.01	1.05	129.00	11.57
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	7.61	68.19	15.23	13.23	2.20	62672.59	18.20	6.40	1.13	120.89	10.64
最大值	8.76	93.24	25.99	15.20	4.05	73266.81	21.82	8.58	2.02	130.26	12.21
發生日期	13	31	31	31	4	21	31	6	4	21	29
最小值	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
發生日期	10	10	10	10	10	10	10	10	30	10	10
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管