

連續自動監測紀錄月報表

中華民國113年10月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	1.78	48.84	12.97	10.00	1.28	81038.83	20.71	6.47	0.99	187.52	13.88
02	2.28	46.64	12.94	10.02	1.26	81269.18	20.17	8.18	0.97	185.94	13.80
03	1.93	47.45	10.99	10.00	1.22	81116.18	20.28	7.29	0.94	184.86	13.74
04	1.65	47.83	9.97	9.93	1.24	80618.40	20.69	7.34	0.96	185.57	13.66
05	1.54	43.49	11.22	9.86	1.25	80845.04	21.37	7.51	0.97	186.11	13.75
06	1.69	45.79	10.17	9.86	1.27	80973.67	20.91	7.57	0.98	186.16	13.68
07	1.63	47.61	11.01	10.11	1.26	80362.57	20.83	6.60	0.98	187.63	13.92
08	1.88	43.66	11.12	10.17	1.23	80212.77	20.44	7.29	0.95	185.75	13.85
09	2.31	32.87	11.11	10.17	1.24	79592.15	20.24	8.06	0.96	185.21	13.69
10	2.09	31.28	8.91	10.16	1.27	78808.17	19.91	7.38	0.98	184.00	13.45
11	2.79	33.20	8.46	10.60	1.28	80289.01	19.23	7.99	0.99	180.84	14.07
12	2.56	34.66	9.58	10.26	1.33	78133.51	19.67	8.52	1.02	183.92	13.42
13	2.40	33.07	10.28	10.15	1.34	77935.67	20.01	8.06	1.04	183.89	13.30
14	2.48	38.23	7.98	10.21	1.32	78820.04	19.94	7.96	1.02	185.49	13.57
15	2.34	39.31	9.01	10.36	1.28	79132.41	19.52	7.76	0.99	185.82	13.75
16	2.45	38.29	8.54	10.35	1.33	78925.21	19.61	8.07	1.03	185.06	13.69
17	2.54	38.14	8.31	10.21	1.32	77856.07	19.89	9.46	1.02	182.81	13.32
18	2.11	39.71	7.77	10.31	1.34	78771.21	19.81	6.16	1.03	185.29	13.65
19	2.08	42.21	8.11	10.35	1.35	78553.54	19.82	7.77	1.05	185.69	13.69
20	2.20	40.98	8.11	10.39	1.30	78931.35	19.58	7.90	1.00	185.74	13.76
21	1.81	42.02	7.06	10.22	1.32	79528.45	20.31	7.26	1.02	186.88	13.81
22	1.97	38.93	8.46	10.34	1.35	78776.28	20.00	7.25	1.05	186.08	13.75
23	2.31	40.33	8.77	10.45	1.30	79465.39	19.49	7.56	1.00	186.02	13.93
24	2.01	44.86	6.93	10.49	1.33	79796.78	19.66	8.19	1.02	186.55	14.08
25	1.58	41.26	8.03	10.26	1.33	79953.95	21.00	9.44	1.03	188.38	14.10
26	1.78	41.21	9.38	10.58	1.31	75805.31	20.16	7.75	1.02	183.94	13.49
27	1.96	37.49	9.00	10.21	1.27	78019.80	20.45	8.11	0.98	184.41	13.48
28	2.07	42.75	7.00	10.38	1.25	78524.28	20.08	8.23	0.96	185.74	13.76
29	2.21	39.62	9.49	10.46	1.28	78663.52	19.58	9.21	0.98	184.54	13.76
30	2.38	35.35	8.76	10.37	1.21	78322.06	19.77	9.36	0.94	183.32	13.59
31	2.73	37.77	9.35	10.65	1.18	74113.23	19.57	8.95	0.91	178.82	13.01
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.11	40.48	9.32	10.25	1.29	79134.00	20.09	7.89	0.99	185.10	13.69
最大值	2.79	48.84	12.97	10.65	1.35	81269.18	21.37	9.46	1.05	188.38	14.10
發生日期											
最小值	1.54	31.28	6.93	9.86	1.18	74113.23	19.23	6.16	0.91	178.82	13.01
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國113年10月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	2.09	32.11	13.05	9.50	1.00	87701.00	21.34	8.24	0.77	196.73	14.77
02	1.47	32.94	11.78	9.60	1.01	87675.00	20.46	8.85	0.78	195.55	14.70
03	1.19	31.14	12.01	9.48	1.03	87952.59	20.97	7.91	0.79	195.00	14.65
04	1.14	30.81	10.98	9.68	1.06	87787.97	20.58	6.56	0.81	190.61	14.68
05	0.96	27.90	12.32	9.45	1.03	87222.77	21.66	6.75	0.79	197.77	14.72
06	1.19	28.90	11.47	9.42	1.05	87439.98	21.41	7.29	0.81	197.41	14.65
07	1.47	30.52	11.32	9.39	1.10	87868.98	21.60	7.71	0.84	197.23	14.72
08	1.07	36.35	13.15	10.35	1.06	81213.91	21.45	7.07	0.82	197.50	14.83
09	2.03	27.84	11.78	11.09	1.02	75370.30	20.70	8.21	0.78	195.68	14.58
10	1.74	27.98	11.35	11.13	1.07	75392.11	20.39	8.07	0.82	195.13	14.56
11	1.76	29.56	11.09	11.19	1.07	75421.07	20.28	8.42	0.82	196.32	14.68
12	2.09	30.77	11.23	11.28	1.09	74170.78	19.91	8.28	0.84	194.85	14.45
13	2.29	27.32	11.22	11.10	1.08	74660.23	20.58	8.09	0.83	195.39	14.43
14	1.68	29.22	11.21	10.99	1.03	74696.87	20.74	8.30	0.79	194.47	14.27
15	2.62	32.98	10.95	11.09	0.98	74867.81	20.33	8.74	0.76	194.43	14.37
16	1.93	36.70	11.76	11.07	1.01	75487.81	20.42	8.26	0.77	195.18	14.50
17	2.21	34.21	10.58	11.02	1.02	74600.21	20.45	10.31	0.79	193.51	14.21
18	1.65	33.19	11.42	11.06	1.05	74659.26	20.51	8.00	0.81	194.51	14.33
19	1.48	34.52	11.19	11.14	1.02	74493.59	20.41	8.19	0.79	194.44	14.38
20	1.78	31.57	10.83	11.23	0.98	74183.91	20.09	8.00	0.76	194.42	14.41
21	1.35	28.08	11.11	10.96	0.96	75543.99	21.13	7.36	0.96	195.35	14.49
22	1.11	30.49	13.10	11.02	0.97	75617.26	21.29	7.03	0.75	199.21	14.74
23	2.02	37.32	13.09	11.30	0.94	74745.52	19.82	8.11	0.73	196.51	14.63
24	1.73	46.91	14.52	11.40	0.99	75011.84	19.94	9.01	0.76	196.16	14.85
25	1.23	39.99	13.62	11.24	1.03	74787.46	20.82	10.30	0.79	198.76	14.80
26	1.10	43.89	13.77	11.40	1.06	71326.04	20.29	6.15	0.81	193.11	14.09
27	1.31	39.32	12.18	10.96	1.06	74899.05	20.98	7.89	0.81	195.08	14.33
28	1.58	37.52	12.92	10.79	1.06	77982.74	20.41	9.11	0.81	195.63	14.58
29	1.59	31.41	11.11	10.58	1.07	79620.80	20.29	9.05	0.82	195.43	14.57
30	1.81	27.86	12.18	10.56	1.06	79602.68	20.24	9.02	0.82	194.73	14.50
31	2.30	29.84	12.70	10.88	1.10	75004.48	20.07	8.58	0.85	188.97	13.86
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	1.64	32.88	11.97	10.69	1.03	78290.58	20.63	8.16	0.80	195.32	14.53
最大值	2.62	46.91	14.52	11.40	1.10	87952.59	21.66	10.31	0.96	199.21	14.85
發生日期											
最小值	0.96	27.32	10.58	9.39	0.94	71326.04	19.82	6.15	0.73	188.97	13.86
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管