

連續自動監測紀錄月報表

中華民國113年7月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	2.06	41.42	12.13	10.15	1.09	79063.23	18.97	9.14	0.84	185.94	13.37
02	1.86	39.22	11.63	10.21	1.07	78763.24	19.25	8.86	0.82	186.40	13.46
03	2.36	42.45	12.27	10.22	1.09	79310.52	18.88	8.34	0.84	184.87	13.46
04	2.31	43.49	12.22	10.20	1.14	77976.58	18.45	8.98	0.88	184.45	13.13
05	2.53	47.43	11.84	10.15	1.13	78381.09	18.67	9.39	0.87	184.42	13.18
06	2.86	46.97	12.33	10.13	1.11	78070.69	18.32	9.60	0.85	182.16	12.97
07	2.46	45.73	11.72	10.02	1.11	78774.06	19.18	9.09	0.86	182.50	13.11
08	2.05	45.26	11.30	9.93	1.10	79859.90	18.86	7.89	0.85	185.99	13.22
09	1.89	43.70	11.25	9.84	1.09	80545.99	19.15	7.99	0.84	183.00	13.19
10	2.50	49.96	11.78	9.58	1.01	82151.78	19.25	8.28	0.78	182.39	13.16
11	2.34	57.26	12.33	9.10	1.13	88725.66	20.18	6.32	0.87	181.92	13.78
12	2.57	59.37	12.46	8.82	1.28	87465.01	20.39	8.05	0.99	185.54	13.41
13	3.00	56.95	11.74	8.65	1.29	88701.48	20.38	8.92	1.00	183.70	13.36
14	2.53	54.10	11.34	8.54	1.32	88950.26	21.06	8.49	1.02	184.90	13.43
15	2.42	52.39	11.22	8.54	1.26	87158.38	20.47	8.71	0.97	181.87	12.98
16	2.25	55.13	11.28	8.57	1.22	87949.70	21.10	8.57	0.94	183.45	13.27
17	2.65	55.78	11.70	8.63	1.28	88043.05	20.21	8.74	0.99	183.24	13.20
18	2.22	53.39	11.34	8.56	1.31	86571.99	20.35	8.65	1.02	182.94	12.92
19	1.70	55.15	11.59	8.64	1.32	87490.78	20.91	8.53	1.02	187.24	13.36
20	1.93	53.41	12.44	8.64	1.34	86183.84	20.63	8.67	1.04	181.23	12.95
21	2.07	45.58	11.57	8.64	1.37	86081.26	20.51	8.39	1.06	181.04	12.90
22	1.91	44.57	11.41	8.51	1.38	86251.23	21.00	8.23	1.07	181.54	12.89
23	1.90	44.67	11.93	8.66	1.38	86873.85	21.10	8.48	1.06	182.82	13.19
24	1.99	42.97	11.99	8.68	1.37	85964.35	21.20	8.57	1.06	179.20	12.98
25	1.68	36.20	12.26	8.61	1.32	85508.45	21.26	7.97	1.02	178.31	12.85
26	1.22	37.57	10.83	8.66	1.31	86016.03	21.65	8.02	1.01	181.21	13.10
27	1.37	42.22	12.87	8.70	1.30	86519.60	21.03	7.96	1.00	182.72	13.16
28	1.33	41.52	12.73	8.58	1.32	86952.25	21.63	7.71	1.02	183.97	13.24
29	1.48	41.87	11.41	8.49	1.32	87164.91	21.35	7.80	1.02	183.14	13.10
30	1.44	41.31	10.53	8.47	1.35	86306.77	21.50	8.04	1.04	182.02	12.95
31	1.67	40.40	11.34	8.62	1.36	85962.73	21.03	8.12	1.05	182.02	12.97
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.08	47.01	11.77	9.09	1.24	84507.70	20.26	8.40	0.96	183.10	13.17
最大值	3.00	59.37	12.87	10.22	1.38	88950.26	21.65	9.60	1.07	187.24	13.78
發生日期											
最小值	1.22	36.20	10.53	8.47	1.01	77976.58	18.32	6.32	0.78	178.31	12.85
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國113年7月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.71	45.28	13.63	11.81	0.91	69389.86	17.39	8.92	0.70	196.51	13.91
02	3.21	43.98	13.65	11.82	0.91	69979.75	17.89	8.32	0.69	198.62	14.19
03	3.54	44.97	13.52	11.83	0.88	70502.08	17.25	8.42	0.68	199.08	14.22
04	3.29	38.87	14.08	11.22	0.87	75056.16	17.05	8.32	0.66	200.08	14.18
05	3.46	30.53	12.61	10.50	0.83	80016.36	17.11	9.55	0.63	198.45	14.05
06	3.55	30.18	12.51	10.51	0.84	80182.95	16.98	9.40	0.64	196.32	14.01
07	3.05	30.69	11.34	10.43	0.83	81115.41	17.76	9.03	0.63	198.02	14.24
08	2.35	26.82	12.32	10.07	1.01	83760.14	17.86	7.14	0.78	200.27	14.31
09	2.51	22.54	11.92	9.93	1.25	84454.20	17.91	7.54	0.97	198.33	14.20
10	3.03	30.10	12.13	10.51	1.22	81147.91	17.05	7.42	0.94	197.80	14.31
11	2.69	39.58	14.00	9.89	1.24	83669.50	19.30	11.19	0.96	197.68	14.26
12	1.94	47.00	12.06	9.33	1.17	89286.94	20.25	8.02	0.90	194.82	14.56
13	1.99	42.87	12.31	8.94	1.20	89378.66	20.74	9.01	0.93	199.14	14.32
14	1.45	39.14	11.61	8.91	1.24	89451.65	21.15	7.93	0.96	200.45	14.41
15	1.31	41.60	12.47	8.94	1.20	88499.33	20.71	7.44	0.92	199.03	14.16
16	1.22	40.40	12.65	8.96	1.14	88844.18	21.07	7.75	0.88	199.90	14.33
17	1.56	41.56	12.76	9.00	1.12	89093.79	20.30	8.58	0.86	199.01	14.26
18	0.87	38.64	11.94	8.87	1.12	88624.66	20.72	8.12	0.86	196.95	14.04
19	0.93	36.07	12.06	8.92	1.14	88177.53	21.34	6.90	0.88	198.11	14.18
20	0.83	37.51	12.04	8.99	1.17	88233.54	20.77	8.46	0.90	197.10	14.14
21	0.96	36.39	11.47	8.94	1.16	87416.32	20.74	7.59	0.89	195.91	13.91
22	1.10	41.33	11.67	8.89	1.14	87379.56	20.87	7.49	0.87	195.29	13.84
23	0.93	43.15	12.16	8.98	1.12	87992.98	21.17	7.66	0.86	196.63	14.15
24	1.01	40.96	12.79	9.11	1.10	87581.90	21.33	8.32	0.84	196.24	14.25
25	0.93	35.19	11.74	8.98	1.08	87364.08	21.58	7.44	0.83	194.96	14.08
26	0.43	37.56	11.75	8.92	1.13	88429.01	21.98	7.23	0.87	197.76	14.33
27	0.54	41.79	11.72	8.97	1.14	87957.32	21.08	7.18	0.88	196.79	14.11
28	0.67	41.63	11.53	8.84	1.14	88364.42	21.79	7.13	0.88	198.35	14.21
29	0.54	40.29	11.77	8.84	1.12	88099.18	21.25	7.41	0.86	197.30	14.03
30	0.46	41.34	11.97	8.91	1.11	88365.28	21.28	7.17	0.86	197.53	14.16
31	0.72	37.38	12.43	9.00	1.13	87383.24	20.74	7.41	0.87	196.78	13.99
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	1.77	38.24	12.34	9.61	1.09	84683.80	19.82	8.05	0.83	197.72	14.17
最大值	3.71	47.00	14.08	11.83	1.25	89451.65	21.98	11.19	0.97	200.45	14.56
發生日期											
最小值	0.43	22.54	11.34	8.84	0.83	69389.86	16.98	6.90	0.63	194.82	13.84
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管