

連續自動監測紀錄月報表

中華民國113年8月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	1.72	42.21	11.07	8.96	1.36	87827.18	20.70	10.00	1.05	179.13	13.52
02	1.73	42.52	12.22	9.03	1.35	88110.13	20.70	10.74	1.05	178.53	13.60
03	1.54	41.18	11.47	8.69	1.35	86519.48	20.96	11.29	1.04	182.26	13.13
04	1.55	43.34	12.26	8.74	1.35	86748.37	20.73	10.38	1.04	182.55	13.18
05	1.23	44.72	11.84	8.65	1.37	87169.93	21.09	7.22	1.06	185.67	13.30
06	1.34	44.49	11.03	8.71	1.42	87572.32	21.06	6.27	1.09	187.52	13.48
07	1.28	43.24	10.50	8.57	1.36	87643.90	21.59	6.24	1.05	185.37	13.38
08	1.26	44.94	11.50	8.68	1.30	87063.65	20.95	6.28	1.01	183.88	13.24
09	1.50	43.81	12.48	8.68	1.31	87378.61	21.33	7.13	1.01	185.05	13.40
10	1.46	39.24	12.16	8.70	1.35	87035.10	20.96	6.55	1.04	183.63	13.26
11	1.52	41.60	11.04	8.71	1.34	87773.64	21.23	6.58	1.03	185.47	13.48
12	1.58	47.98	12.56	8.80	1.32	88149.78	20.90	6.85	1.02	185.60	13.59
13	1.67	46.64	11.85	8.94	1.30	88103.82	20.76	6.34	1.00	186.52	13.74
14	2.02	45.06	11.60	8.90	1.28	89009.81	20.54	7.06	0.99	186.70	13.80
15	2.41	43.40	12.03	8.82	1.25	87712.21	20.24	7.70	0.96	183.71	13.38
16	2.43	44.07	11.86	8.92	1.23	87373.21	20.42	8.39	0.95	183.90	13.47
17	2.24	45.69	10.86	8.90	1.24	87345.31	20.48	7.88	0.96	183.72	13.45
18	2.47	41.91	11.17	8.89	1.24	87112.23	20.34	7.84	0.96	183.46	13.37
19	2.34	41.63	12.11	8.79	1.21	86104.07	20.45	7.93	0.94	181.91	13.08
20	2.07	44.65	12.47	8.84	1.21	87523.63	20.87	7.84	0.93	183.63	13.47
21	2.35	44.52	11.82	8.94	1.23	87930.64	20.11	8.18	0.95	184.59	13.54
22	2.16	53.32	11.40	9.06	1.24	88105.34	19.75	7.66	0.96	185.42	13.67
23	2.10	52.93	10.99	8.97	1.22	87676.26	20.40	8.38	0.94	185.26	13.61
24	2.86	49.31	11.92	8.96	1.26	87108.56	20.22	8.58	0.98	184.59	13.46
25	2.08	48.05	10.29	8.83	1.28	86993.50	20.61	8.13	0.99	184.27	13.36
26	2.36	50.70	11.15	8.90	1.30	87172.06	20.27	7.91	1.00	182.90	13.36
27	2.00	48.47	11.64	8.91	1.30	87342.78	20.23	7.77	1.00	184.71	13.44
28	2.36	49.30	12.24	9.01	1.29	86940.90	19.76	7.66	0.99	183.40	13.38
29	2.21	50.49	12.12	8.93	1.27	86674.82	20.21	8.03	0.98	182.25	13.29
30	2.15	52.08	12.61	8.98	1.29	87541.39	20.05	8.37	1.00	185.01	13.53
31	2.09	50.28	10.02	9.03	1.30	87045.32	19.78	7.92	1.01	184.48	13.44
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	1.94	45.86	11.62	8.85	1.29	87413.16	20.57	7.91	1.00	184.04	13.43
最大值	2.86	53.32	12.61	9.06	1.42	89009.81	21.59	11.29	1.09	187.52	13.80
發生日期											
最小值	1.23	39.24	10.02	8.57	1.21	86104.07	19.75	6.24	0.93	178.53	13.08
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國113年8月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	0.56	35.90	11.61	8.94	1.10	86942.46	20.99	7.25	0.84	196.34	13.89
02	0.75	37.17	12.24	8.99	1.08	87487.84	21.11	8.24	0.83	198.00	14.11
03	0.80	37.10	11.93	9.03	1.12	86518.73	20.67	8.13	0.86	196.22	13.87
04	0.90	36.85	12.60	9.00	1.13	86490.26	20.72	8.26	0.87	195.66	13.81
05	0.64	34.83	11.45	8.95	1.16	86343.19	20.84	6.47	0.89	195.14	13.74
06	0.75	35.05	11.44	9.02	1.16	87149.15	20.89	5.69	0.89	197.22	14.02
07	0.49	33.05	11.46	8.88	1.13	87177.21	21.25	6.04	0.87	196.64	13.91
08	0.60	33.58	12.01	8.92	1.12	86935.85	21.00	5.52	0.87	195.08	13.82
09	0.92	35.78	11.47	9.01	1.10	87370.99	20.95	6.24	0.85	196.79	14.04
10	1.04	36.12	11.30	9.06	1.10	87149.07	20.44	6.59	0.85	196.13	13.95
11	0.86	35.69	11.03	8.98	1.08	87914.50	21.13	5.73	0.83	197.67	14.15
12	1.30	36.98	12.02	9.25	1.06	88591.59	20.63	6.16	0.81	191.19	14.32
13	0.88	37.37	11.88	9.17	1.06	88398.16	21.22	6.16	0.81	193.84	14.36
14	1.55	39.25	12.16	9.11	1.07	88364.11	20.60	6.48	0.82	196.74	14.26
15	1.82	39.11	11.01	9.05	1.08	87330.79	20.15	7.30	0.83	193.46	13.84
16	1.36	41.75	11.15	9.09	1.08	87705.12	20.66	7.80	0.83	196.22	14.12
17	1.50	40.93	11.20	9.08	1.15	87645.37	20.49	6.86	0.89	195.92	14.07
18	1.74	37.23	11.50	9.00	1.18	87876.16	20.72	6.84	0.91	196.25	14.05
19	1.51	36.94	11.77	8.92	1.16	86573.22	20.69	6.70	0.89	194.11	13.69
20	1.47	39.45	11.65	9.01	1.19	87644.67	20.95	7.39	0.92	196.44	14.08
21	1.92	36.34	11.67	9.04	1.18	87441.77	20.18	7.32	0.91	195.22	13.91
22	1.78	39.07	11.04	8.98	1.18	87263.88	20.17	6.92	0.91	194.09	13.77
23	1.44	41.33	10.96	9.01	1.19	88263.55	20.53	7.39	0.92	196.50	14.11
24	2.61	39.84	10.63	9.09	1.12	88736.11	20.32	8.01	0.86	194.97	14.19
25	1.39	39.22	10.65	9.05	1.06	89680.51	20.67	6.67	0.81	194.86	14.35
26	1.92	38.76	10.87	9.09	1.02	89856.10	20.12	6.09	0.78	194.21	14.31
27	1.60	35.36	11.26	9.04	1.03	89682.15	20.37	6.40	0.79	194.34	14.27
28	1.83	36.95	11.20	9.15	1.05	88953.28	19.81	6.30	0.81	192.44	14.13
29	1.60	36.59	12.09	9.06	1.04	89162.78	20.23	6.72	0.80	192.61	14.14
30	1.77	36.87	11.29	8.99	1.05	90225.54	20.48	7.23	0.81	194.50	14.33
31	1.60	37.73	10.70	9.06	1.05	89871.12	20.21	7.49	0.81	194.21	14.29
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	1.32	37.36	11.46	9.03	1.11	87959.52	20.62	6.85	0.85	195.26	14.06
最大值	2.61	41.75	12.60	9.25	1.19	90225.54	21.25	8.26	0.92	198.00	14.36
發生日期											
最小值	0.49	33.05	10.63	8.88	1.02	86343.19	19.81	5.52	0.78	191.19	13.69
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管