

連續自動監測紀錄月報表

中華民國108年11月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	9.08	45.38	10.28	10.07	2.05	85647.28	17.47	13.99	0.85	179.59	13.94
02	9.31	49.22	7.57	10.61	2.09	80685.87	16.87	11.51	0.87	178.49	13.67
03	9.53	50.62	5.25	10.71	2.13	80140.60	17.19	11.07	0.89	177.25	13.71
04	9.23	65.59	3.38	10.66	2.11	79843.55	17.42	9.70	0.88	175.03	13.58
05	9.74	51.63	6.27	10.75	2.08	79978.16	17.13	10.75	0.87	173.68	13.64
06	9.96	53.38	6.86	10.63	2.12	80086.73	16.91	10.99	0.88	171.32	13.40
07	9.86	53.85	7.95	10.99	2.21	79834.80	16.38	11.33	0.92	174.54	13.84
08	9.73	51.46	6.65	10.92	2.22	79712.69	16.57	11.77	0.93	174.71	13.76
09	9.91	49.30	7.86	11.01	2.21	78479.51	15.53	13.26	0.92	170.87	13.37
10	9.92	51.89	8.02	11.12	2.22	80710.13	15.80	12.42	0.92	175.85	14.12
11	9.31	47.76	8.02	10.73	2.22	79625.30	16.39	12.38	0.93	171.99	13.38
12	9.49	47.79	7.18	10.90	2.23	78554.06	16.31	12.86	0.93	172.39	13.41
13	7.75	44.88	7.91	11.00	2.11	77290.47	16.57	13.63	1.02	172.18	13.35
14	10.00	54.52	4.38	10.96	2.11	77857.56	15.98	14.12	0.88	170.41	13.27
15	10.32	58.96	4.27	10.98	2.17	78014.66	16.28	13.86	0.90	171.68	13.40
16	9.96	58.87	4.27	10.84	2.22	79356.71	16.62	14.83	0.93	173.13	13.54
17	9.63	58.81	3.48	10.92	2.23	78440.27	16.38	15.13	0.93	172.35	13.43
18	8.84	58.72	3.17	10.58	2.20	79605.12	17.12	9.69	0.91	172.17	13.30
19	9.61	59.59	4.72	11.02	2.16	78940.20	15.87	10.31	0.90	171.40	13.55
20	9.59	58.83	4.09	11.04	2.14	78930.55	16.08	14.84	0.89	172.41	13.62
21	9.08	58.47	2.60	10.68	2.20	79775.66	17.24	13.64	0.92	172.61	13.48
22	9.41	58.12	5.68	10.87	2.19	78270.94	17.42	14.89	0.91	173.36	13.54
23	9.54	58.73	4.20	10.89	2.15	77553.47	17.42	15.72	0.89	172.54	13.42
24	9.42	59.11	3.19	10.80	2.12	79173.92	16.85	14.27	0.88	173.19	13.50
25	9.44	59.28	2.13	10.90	2.09	78307.69	17.04	12.94	0.87	173.24	13.52
26	9.58	60.88	2.52	11.01	2.10	78037.12	16.76	13.33	0.88	172.56	13.55
27	9.40	62.57	3.37	10.89	2.12	79352.16	16.89	13.34	0.89	174.36	13.69
28	9.25	62.52	4.29	10.95	2.16	79281.77	16.29	13.09	0.90	174.18	13.65
29	9.32	62.36	4.31	11.01	2.19	79201.55	16.34	13.61	0.91	174.29	13.74
30	9.52	58.99	4.83	11.04	2.14	78106.22	15.97	15.76	0.89	172.29	13.47
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	9.49	55.74	5.29	10.85	2.16	79293.16	16.64	12.97	0.90	173.47	13.56
最大值	10.32	65.59	10.28	11.12	2.23	85647.28	17.47	15.76	1.02	179.59	14.12
發生日期											
最小值	7.75	44.88	2.13	10.07	2.05	77290.47	15.53	9.69	0.85	170.41	13.27
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國108年11月30日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	9.12	61.54	11.92	10.79	2.65	81252.22	16.48	13.32	1.10	186.57	14.21
02	8.37	61.33	14.02	11.04	2.65	79634.60	16.32	11.62	1.10	187.06	14.23
03	8.43	62.74	13.52	11.11	2.63	78290.07	17.08	11.52	1.10	185.97	14.21
04	8.08	78.03	10.74	11.07	2.61	78166.58	17.08	10.14	1.09	184.56	14.08
05	8.86	65.59	11.69	11.36	2.56	77368.01	16.84	11.09	1.07	184.88	14.32
06	9.47	66.08	10.77	11.62	2.44	77190.75	15.60	10.32	1.02	185.98	14.51
07	9.16	62.56	10.47	11.44	2.36	76464.92	15.78	11.10	0.98	182.77	14.02
08	8.97	60.65	9.47	11.36	2.42	77192.78	16.19	12.21	1.01	183.37	14.14
09	9.21	60.29	11.23	11.58	2.48	76627.18	15.10	12.48	1.03	183.16	14.18
10	9.22	58.74	11.11	11.40	2.50	77524.67	15.63	12.25	1.04	182.77	14.14
11	8.99	56.93	9.63	11.33	2.50	77437.68	15.76	11.54	1.04	183.27	14.07
12	9.17	57.81	11.16	11.49	2.59	76780.64	15.51	12.72	1.08	185.25	14.21
13	9.12	57.20	13.83	11.43	2.62	76634.01	15.30	14.11	1.17	189.17	14.17
14	6.81	54.66	11.87	11.36	2.59	76015.54	15.69	13.53	1.08	186.35	13.93
15	9.65	64.02	10.10	11.31	2.65	76760.16	15.74	13.66	1.10	183.97	13.94
16	9.31	64.11	9.93	11.39	2.70	76200.60	15.96	14.36	1.12	184.48	13.99
17	9.17	60.78	9.39	11.45	2.65	75025.64	15.64	14.32	1.10	182.21	13.74
18	8.27	61.26	8.25	11.32	2.64	76740.15	16.32	9.01	1.10	184.73	14.06
19	8.91	63.06	8.99	11.55	2.70	78222.89	15.47	9.93	1.12	187.81	14.63
20	9.35	63.24	9.93	11.54	2.76	77427.51	15.44	14.03	1.15	185.71	14.40
21	8.73	64.95	11.36	11.33	2.83	78055.26	16.44	13.62	1.18	185.49	14.36
22	8.84	64.66	9.54	11.41	2.78	76671.05	16.69	13.89	1.16	184.85	14.24
23	8.90	64.23	9.57	11.39	2.61	76412.66	16.56	14.44	1.09	183.46	14.10
24	9.13	62.97	9.50	11.40	2.50	75993.71	15.89	13.69	1.04	182.68	13.91
25	9.14	64.07	7.18	11.44	2.55	77049.73	16.07	12.38	1.06	184.82	14.25
26	9.02	66.94	6.65	11.44	2.55	77769.42	16.05	12.81	1.06	186.70	14.45
27	9.06	65.71	9.13	11.47	2.58	78196.76	15.62	13.22	1.07	189.63	14.58
28	8.23	62.24	10.16	11.39	2.59	78945.30	15.84	12.11	1.08	195.54	14.83
29	8.76	63.72	10.01	11.38	2.61	79269.14	16.24	13.46	1.09	190.54	14.79
30	8.44	60.79	11.55	11.43	2.61	78092.32	16.14	13.25	1.09	194.51	14.76
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	8.86	62.70	10.42	11.37	2.60	77447.07	16.02	12.54	1.08	185.94	14.25
最大值	9.65	78.03	14.02	11.62	2.83	81252.22	17.08	14.44	1.18	195.54	14.83
發生日期											
最小值	6.81	54.66	6.65	10.79	2.36	75025.64	15.10	9.01	0.98	182.21	13.74
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管