

連續自動監測紀錄月報表

中華民國109年12月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	4.65	61.18	5.31	10.34	2.45	81689.00	17.21	15.49	1.02	175.25	13.44
02	4.74	60.39	3.81	10.22	2.44	81694.94	17.33	15.88	1.02	175.47	13.33
03	5.18	61.19	6.58	10.31	2.50	81803.33	16.62	16.55	1.04	173.26	13.29
04	4.49	62.10	5.31	10.38	2.64	81029.87	17.01	16.28	1.10	174.45	13.34
05	4.27	60.83	4.96	10.36	2.64	80216.08	17.40	16.14	1.10	173.35	13.21
06	4.46	62.23	3.45	10.26	2.59	81404.57	17.87	16.98	1.08	175.39	13.42
07	4.81	61.96	3.83	10.26	2.53	81531.07	17.33	16.86	1.05	175.28	13.34
08	4.41	60.00	3.53	10.25	2.54	81872.28	17.49	16.13	1.06	175.03	13.41
09	4.30	58.82	4.48	10.49	2.57	80098.97	16.91	17.07	1.07	174.16	13.30
10	3.80	56.36	5.97	10.29	2.62	80093.05	17.68	17.46	1.09	173.89	13.17
11	3.67	52.87	6.41	10.40	2.57	79601.69	17.83	16.80	1.07	174.67	13.27
12	3.41	54.84	4.15	10.43	2.51	79225.38	17.45	16.85	1.04	172.90	13.13
13	2.93	53.99	3.95	10.29	2.51	79552.65	17.98	16.87	1.04	172.84	13.09
14	3.27	52.89	3.43	10.35	2.51	80522.49	17.76	16.49	1.04	174.26	13.32
15	3.50	55.82	3.89	10.57	2.46	79857.33	17.24	16.71	1.03	174.04	13.40
16	3.42	53.20	4.53	10.42	2.46	80386.95	17.62	16.28	1.02	174.09	13.37
17	3.42	51.62	2.82	10.24	2.48	81567.46	17.95	15.78	1.03	174.99	13.42
18	3.08	51.96	4.17	10.47	2.53	79243.69	18.24	14.57	1.05	175.30	13.38
19	3.15	52.89	4.87	10.33	2.51	80181.45	17.86	15.76	1.05	173.81	13.24
20	3.29	52.03	3.30	10.37	2.44	81186.69	17.69	14.85	1.02	175.94	13.51
21	3.38	54.11	4.35	10.32	2.38	80966.59	17.75	16.13	0.99	173.78	13.35
22	3.54	52.33	5.97	10.54	2.43	79109.95	17.81	15.00	1.01	174.11	13.34
23	3.27	52.75	4.64	10.35	2.52	80961.48	17.92	15.63	1.05	175.92	13.48
24	3.29	53.80	6.21	10.51	2.58	79065.21	17.24	15.85	1.08	173.87	13.20
25	3.01	54.53	4.10	10.44	2.63	79704.23	17.39	15.38	1.09	173.92	13.24
26	2.94	56.18	5.37	10.38	2.63	80747.20	17.48	15.43	1.09	175.35	13.38
27	3.38	58.12	5.67	10.70	2.50	78101.51	16.32	14.99	1.04	173.09	13.10
28	3.40	56.73	3.85	10.48	2.39	78944.82	16.95	15.57	0.99	172.38	13.05
29	3.67	58.54	4.98	10.31	2.52	79853.12	17.40	15.80	1.05	173.38	13.09
30	4.11	60.33	4.46	10.30	2.58	81799.41	16.86	16.54	1.07	172.79	13.29
31	4.11	59.60	3.27	10.62	2.57	81206.20	15.52	15.13	1.13	172.69	13.38
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.75	56.59	4.57	10.39	2.52	80426.41	17.39	16.04	1.05	174.18	13.30
最大值	5.18	62.23	6.58	10.70	2.64	81872.28	18.24	17.46	1.13	175.94	13.51
發生日期											
最小值	2.93	51.62	2.82	10.22	2.38	78101.51	15.52	14.57	0.99	172.38	13.05
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國109年12月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	4.35	60.98	7.82	10.76	2.41	79583.35	16.73	14.86	1.00	182.52	13.78
02	3.75	58.68	8.27	10.49	2.45	80282.60	17.30	14.14	1.02	182.09	13.63
03	4.35	62.01	8.89	10.86	2.45	78279.37	16.57	15.43	1.02	181.69	13.65
04	4.03	59.69	9.01	10.86	2.29	79120.96	16.80	16.42	0.96	182.60	13.86
05	3.98	60.94	6.05	10.97	2.27	77966.26	16.73	16.34	0.95	181.94	13.77
06	3.99	59.79	6.81	10.82	2.34	78267.24	17.27	16.65	0.97	182.17	13.72
07	4.09	57.63	9.98	10.74	2.40	78747.07	16.94	16.04	1.00	182.32	13.63
08	3.91	59.68	8.30	10.92	2.59	78626.11	17.05	15.61	1.08	183.97	13.94
09	4.45	55.24	9.53	10.97	2.59	78085.93	16.65	16.82	1.08	182.88	13.80
10	3.58	50.75	9.71	10.80	2.66	77594.19	17.73	16.80	1.11	181.15	13.61
11	3.43	49.75	9.74	10.85	2.76	78064.55	17.99	16.93	1.15	182.62	13.85
12	3.20	49.40	9.15	10.99	2.70	77177.27	17.62	16.67	1.13	181.69	13.80
13	3.00	49.60	10.03	10.97	2.73	77359.31	17.78	16.78	1.14	182.45	13.85
14	3.30	48.88	9.03	10.92	2.66	78348.75	17.69	16.01	1.11	182.19	13.94
15	3.58	51.53	7.98	10.97	2.72	78676.33	17.45	16.22	1.13	182.87	14.04
16	3.32	48.88	9.26	10.94	2.77	78547.19	17.78	15.85	1.15	183.42	14.05
17	3.24	49.12	8.54	10.84	2.73	78974.15	17.93	15.20	1.14	183.25	14.00
18	2.89	47.98	8.53	10.87	2.76	77209.97	18.42	14.11	1.15	182.16	13.79
19	3.28	52.48	8.66	10.93	2.81	78717.07	17.66	15.86	1.17	183.60	14.05
20	3.52	52.05	8.51	10.96	2.77	78884.21	17.31	15.28	1.15	183.16	14.05
21	3.40	56.60	7.70	11.01	2.74	78345.01	17.52	16.49	1.14	183.52	14.07
22	4.03	52.35	10.86	11.00	2.76	77617.11	17.86	15.62	1.15	183.25	13.97
23	3.39	49.62	9.32	10.90	2.75	76886.04	17.86	15.64	1.15	181.57	13.66
24	3.36	50.78	9.54	10.99	2.72	77247.79	17.43	15.65	1.13	181.61	13.77
25	3.30	56.19	6.73	11.06	2.55	76012.64	17.04	16.18	1.06	179.47	13.51
26	3.20	59.34	7.70	10.91	2.53	77473.43	17.31	15.34	1.05	181.16	13.67
27	3.57	55.70	8.74	11.04	2.45	76683.69	16.63	15.86	1.02	180.26	13.57
28	3.45	60.48	9.14	11.06	2.45	76228.44	16.64	14.91	1.02	179.54	13.49
29	3.63	62.49	8.85	11.02	2.58	76946.38	16.81	15.95	1.08	180.95	13.65
30	4.01	63.94	7.70	10.98	2.65	78749.49	16.25	16.48	1.10	180.47	13.80
31	3.98	62.83	8.70	11.21	2.59	78858.24	15.14	15.44	1.12	179.77	13.93
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.63	55.33	8.67	10.92	2.60	78050.33	17.22	15.86	1.08	182.01	13.80
最大值	4.45	63.94	10.86	11.21	2.81	80282.60	18.42	16.93	1.17	183.97	14.07
發生日期											
最小值	2.89	47.98	6.05	10.49	2.27	76012.64	15.14	14.11	0.95	179.47	13.49
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管