

連續自動監測紀錄月報表

中華民國112年4月30日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	5.68	61.11	8.06	11.57	1.36	77590.31	15.84	11.58	0.91	185.81	14.56
02	6.14	60.99	7.60	11.41	1.31	78371.95	16.29	11.70	0.88	185.98	14.55
03	5.43	58.69	7.87	11.22	1.26	79096.58	16.29	10.45	0.85	186.19	14.39
04	5.34	62.39	7.25	11.49	1.30	78309.40	16.24	10.51	0.87	188.19	14.73
05	5.77	62.28	7.33	11.54	1.36	77095.79	16.31	10.81	0.91	187.07	14.55
06	6.07	59.51	8.29	11.36	1.39	77691.65	16.56	11.59	0.93	186.13	14.39
07	5.20	63.74	10.42	11.64	1.41	76959.84	15.97	11.12	0.94	186.92	14.60
08	7.18	64.15	8.11	11.61	1.45	77880.01	15.14	13.05	0.96	186.18	14.58
09	7.21	62.31	6.74	11.41	1.45	78228.86	16.17	13.31	0.97	186.40	14.51
10	5.67	60.87	7.68	11.42	1.42	76983.06	16.06	10.49	0.95	185.63	14.24
11	4.62	60.13	7.30	11.62	1.45	76883.15	16.54	10.00	0.97	183.83	14.59
12	6.06	58.47	10.04	11.42	1.58	76500.61	16.36	12.29	1.05	187.26	14.26
13	4.79	58.88	11.31	11.53	1.61	75120.89	16.57	10.62	1.07	185.82	14.17
14	5.78	57.57	9.30	11.51	1.54	74798.14	16.84	12.30	1.02	185.70	14.11
15	5.06	56.68	9.06	11.57	1.51	73579.49	17.15	12.12	1.01	183.45	13.95
16	6.34	55.52	10.24	11.35	1.55	76157.17	16.87	14.07	1.03	185.90	14.15
17	4.75	54.45	8.36	11.23	1.54	76347.26	17.16	11.89	1.03	184.76	14.02
18	4.80	54.06	7.73	11.49	1.50	75520.19	17.08	10.25	1.00	187.33	14.30
19	5.72	56.21	9.74	11.76	1.41	74099.36	16.41	12.23	0.94	185.81	14.28
20	5.24	55.10	8.66	11.66	1.36	75079.21	16.27	12.90	0.91	184.87	14.28
21	5.44	56.78	8.59	11.77	1.45	75106.28	16.58	11.72	0.96	187.22	14.58
22	5.70	57.12	9.28	11.81	1.47	75283.30	16.05	11.98	0.98	186.91	14.56
23	5.81	55.94	7.82	11.88	1.47	73346.29	16.98	12.23	0.98	187.34	14.47
24	5.76	59.58	8.07	12.90	1.47	65503.23	16.87	12.37	0.98	187.10	14.51
25	4.51	56.53	8.61	12.60	1.49	68380.65	17.08	11.03	0.99	189.16	14.71
26	4.39	54.07	5.71	11.43	1.54	78395.42	16.77	10.83	1.03	188.69	14.73
27	4.59	52.74	6.69	11.03	1.68	81046.91	16.71	10.54	1.12	189.11	14.63
28	5.63	56.72	8.65	13.52	1.63	62545.93	17.17	10.75	1.08	189.56	14.71
29	4.99	50.54	6.41	11.02	1.57	80051.50	16.86	10.03	1.05	189.33	14.48
30	5.15	50.39	6.17	11.02	1.53	81170.50	16.81	10.44	1.02	189.06	14.65
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	5.49	57.78	8.24	11.63	1.47	75770.76	16.53	11.51	0.98	186.76	14.44
最大值	7.21	64.15	11.31	13.52	1.68	81170.50	17.17	14.07	1.12	189.56	14.73
發生日期											
最小值	4.39	50.39	5.71	11.02	1.26	62545.93	15.14	10.00	0.85	183.45	13.95
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管