

# 連續自動監測紀錄月報表

中華民國111年7月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	2.10	46.37	6.87	9.61	1.33	81713.16	17.76	11.80	0.89	180.20	12.83
02	2.10	45.75	8.17	9.67	1.33	81632.50	17.91	11.83	0.89	179.43	12.88
03	2.15	46.45	8.95	9.60	1.32	82285.57	18.15	11.73	0.89	180.58	12.97
04	1.98	45.45	6.55	9.32	1.35	82566.70	18.64	12.11	0.90	180.15	12.77
05	1.85	48.67	6.63	9.80	1.33	82286.91	18.18	11.89	0.89	178.34	13.15
06	2.05	48.19	7.22	9.50	1.30	82603.55	18.30	11.76	0.87	181.55	12.96
07	2.04	48.77	6.38	9.48	1.22	81808.54	18.50	12.08	0.81	179.06	12.78
08	1.97	50.74	14.73	9.68	1.25	81802.76	18.34	12.22	0.83	181.31	13.04
09	2.01	48.85	8.96	9.44	1.21	82450.89	18.97	12.15	0.80	181.33	12.98
10	2.22	48.12	6.26	9.41	1.19	82857.16	19.10	11.80	0.79	181.63	13.03
11	2.49	48.14	7.37	9.48	1.21	81496.26	18.12	11.81	0.80	180.14	12.70
12	2.19	49.78	8.13	9.51	1.24	81086.53	18.47	11.79	0.82	180.54	12.73
13	2.75	46.91	9.01	9.54	1.25	81835.62	17.93	11.65	0.84	179.86	12.79
14	2.71	44.56	7.65	9.51	1.27	81437.86	17.78	11.82	0.85	178.80	12.63
15	2.19	49.02	9.20	9.55	1.26	81897.19	18.18	11.87	0.84	179.84	12.84
16	2.19	46.20	7.07	9.65	1.27	80950.84	17.77	11.55	0.85	178.97	12.72
17	2.18	45.62	9.01	9.53	1.23	81478.71	18.19	12.05	0.82	179.64	12.76
18	1.98	48.43	7.55	9.52	1.22	82197.37	18.22	11.62	0.81	180.23	12.87
19	1.84	47.70	8.96	9.60	1.21	81913.90	18.20	11.29	0.81	180.84	12.93
20	2.15	48.60	7.23	9.57	1.19	81564.88	17.66	11.28	0.79	179.54	12.73
21	1.99	47.23	6.96	9.47	1.22	81752.20	18.00	11.77	0.81	179.26	12.68
22	2.04	49.27	7.99	9.53	1.23	81626.52	18.12	11.50	0.82	180.24	12.78
23	2.76	50.17	6.60	9.47	1.25	81359.92	17.85	11.99	0.83	178.82	12.59
24	2.47	47.68	8.02	9.50	1.27	81611.08	18.43	11.96	0.84	179.92	12.77
25	2.03	45.28	7.49	9.42	1.25	81130.38	18.14	11.21	0.84	178.99	12.54
26	1.85	47.16	10.05	9.57	1.19	81639.74	18.27	11.33	0.79	180.27	12.84
27	2.66	48.28	8.50	9.64	1.15	81008.39	17.72	11.40	0.76	179.67	12.72
28	2.24	48.41	8.31	9.48	1.17	81464.83	17.95	11.52	0.78	179.14	12.64
29	2.04	47.13	7.70	9.61	1.20	80635.86	17.90	11.68	0.80	179.16	12.65
30	1.79	46.78	7.29	9.56	1.21	81147.21	18.27	11.76	0.81	179.35	12.73
31	1.98	47.43	8.15	9.48	1.17	81799.42	18.25	11.87	0.78	179.86	12.76
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.16	47.65	8.03	9.54	1.24	81711.05	18.17	11.74	0.83	179.89	12.80
最大值	2.76	50.74	14.73	9.80	1.35	82857.16	19.10	12.22	0.90	181.63	13.15
發生日期											
最小值	1.79	44.56	6.26	9.32	1.15	80635.86	17.66	11.21	0.76	178.34	12.54
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國111年7月31日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO <sub>2</sub> 二氧化硫	NO <sub>x</sub> 氮氧化物	CO 一氧化碳	O <sub>2</sub> 氧氣	DUST 粉塵濃度	MASS 排放流率	H <sub>2</sub> O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	3.02	51.24	8.38	10.70	1.32	81850.16	17.40	12.26	0.88	191.94	14.52
02	3.23	49.97	9.39	10.58	1.34	81829.93	17.71	12.50	0.89	190.02	14.34
03	2.90	49.85	8.96	10.55	1.39	82549.26	17.82	12.22	0.93	191.41	14.49
04	3.08	49.83	7.71	10.71	1.37	82763.77	17.51	12.34	0.92	188.28	14.59
05	2.40	51.34	7.47	10.62	1.31	82765.01	18.18	12.37	0.87	192.99	14.74
06	2.74	56.92	7.41	10.80	1.33	82960.47	17.87	12.09	0.89	190.79	14.90
07	2.73	56.33	8.06	10.73	1.33	83150.96	17.62	12.20	0.89	190.22	14.78
08	2.46	56.96	11.21	10.61	1.38	83111.13	18.39	13.05	0.92	194.30	14.86
09	2.57	51.77	8.09	10.43	1.47	83526.17	18.66	12.46	0.98	193.91	14.72
10	2.97	48.59	9.12	10.27	1.46	83592.36	18.78	12.18	0.97	193.05	14.50
11	2.90	49.66	10.24	10.14	1.45	83743.44	18.32	12.53	0.97	191.69	14.23
12	2.48	50.03	9.19	10.32	1.45	82343.78	18.42	12.45	0.97	193.73	14.31
13	2.97	55.17	11.76	10.59	1.43	82352.48	18.06	12.65	0.96	194.28	14.62
14	3.02	54.38	9.23	10.33	1.44	82500.42	17.83	12.10	0.96	191.64	14.18
15	2.47	54.79	7.27	10.53	1.44	82428.30	17.86	12.39	0.96	193.14	14.50
16	3.10	53.73	7.21	10.64	1.46	81416.54	17.28	12.29	0.97	191.43	14.31
17	2.94	50.29	8.28	10.42	1.41	82614.01	17.96	12.35	0.94	191.87	14.35
18	2.50	54.77	8.61	10.41	1.38	82549.68	17.88	12.17	0.92	191.67	14.31
19	2.47	53.98	8.54	10.53	1.42	82753.25	17.96	12.04	0.95	193.11	14.57
20	2.84	53.31	9.47	10.59	1.37	81929.15	17.15	11.93	0.91	190.89	14.30
21	2.56	53.78	6.76	10.48	1.35	82716.08	17.44	11.89	0.90	192.30	14.37
22	2.50	54.95	9.64	10.45	1.34	82329.42	17.68	12.04	0.89	194.34	14.38
23	3.06	51.31	7.48	10.37	1.36	82014.75	17.81	12.33	0.91	191.85	14.15
24	2.91	52.43	10.17	10.30	1.37	83121.52	18.42	12.24	0.91	192.46	14.37
25	2.87	50.73	8.99	10.28	1.39	82880.76	17.96	12.50	0.93	192.09	14.23
26	2.70	51.60	8.46	10.47	1.37	82093.62	17.92	12.19	0.92	192.08	14.33
27	3.35	51.51	9.05	10.49	1.36	81601.61	17.44	12.48	0.91	191.50	14.18
28	3.40	51.46	8.40	10.44	1.32	82206.43	17.52	12.73	0.88	191.18	14.21
29	3.26	50.05	8.34	10.48	1.28	81351.58	17.51	12.01	0.86	190.61	14.10
30	2.59	47.66	8.41	10.39	1.31	81565.19	17.92	12.07	0.88	189.92	14.06
31	2.72	47.27	8.04	10.36	1.34	81912.27	18.03	12.21	0.90	190.74	14.13
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.83	52.12	8.69	10.48	1.38	82468.50	17.88	12.30	0.92	191.92	14.41
最大值	3.40	56.96	11.76	10.80	1.47	83743.44	18.78	13.05	0.98	194.34	14.90
發生日期											
最小值	2.40	47.27	6.76	10.14	1.28	81351.58	17.15	11.89	0.86	188.28	14.06
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管