

# 連續自動監測紀錄月報表

中華民國107年4月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	10.88	73.37	21.93	14.99	2.13	65884.57	6.38	8.84	1.07	116.43	11.99
02	9.64	69.20	20.98	14.98	2.00	66122.00	6.38	4.31	1.00	115.44	11.98
03	10.52	71.39	20.64	15.01	1.89	65834.18	5.83	6.96	0.95	115.30	11.98
04	10.02	68.68	22.37	14.90	1.87	66863.26	5.88	4.18	0.94	115.49	11.95
05	9.09	65.85	22.62	14.93	2.03	66427.75	5.75	9.51	1.01	115.60	11.95
06	8.23	70.31	17.59	15.04	2.16	66123.76	6.59	8.16	1.08	112.98	12.02
07	4.37	69.89	14.30	15.08	1.89	66126.17	7.96	10.03	0.94	110.66	12.03
08	7.35	71.24	16.03	15.05	1.86	65746.70	7.25	9.88	0.93	112.50	11.97
09	7.08	71.46	21.91	15.06	2.23	65246.97	6.70	8.95	1.11	112.93	11.89
10	7.78	68.52	21.82	15.03	1.93	65592.43	6.52	9.21	0.96	113.76	11.94
11	10.62	67.77	27.21	14.89	2.18	66705.12	5.90	14.13	1.09	115.35	11.89
12	9.64	66.66	16.22	14.93	2.43	66012.15	6.09	10.82	1.21	115.14	11.86
13	10.96	66.99	20.14	14.93	2.53	65938.88	5.99	16.74	1.26	116.00	11.86
14	9.09	64.51	18.71	14.90	2.50	65368.50	5.69	11.16	1.25	115.33	11.67
15	9.11	71.90	14.38	15.06	1.79	66022.58	7.57	9.73	0.90	112.39	12.03
16	9.40	73.03	15.21	15.05	1.49	66070.17	7.68	11.26	0.74	112.04	12.01
17	7.18	71.40	16.20	15.15	1.71	65028.98	6.95	10.67	0.85	111.49	12.00
18	7.83	67.12	14.97	15.01	1.81	66126.63	6.65	10.19	0.90	112.99	11.97
19	10.28	67.64	18.02	14.94	1.87	66124.62	6.62	11.24	0.93	114.77	11.88
20	10.30	68.15	15.90	14.95	2.05	66245.30	6.77	8.92	1.02	115.56	11.94
21	10.36	66.67	17.82	14.97	2.12	65824.87	6.66	10.68	1.06	115.27	11.90
22	10.17	68.09	15.73	14.95	2.11	65907.46	6.17	9.95	1.06	115.27	11.88
23	10.48	62.97	17.22	14.88	2.24	66297.09	5.76	10.17	1.12	115.96	11.84
24	9.38	63.86	14.94	14.92	2.34	66325.64	5.91	8.22	1.17	114.12	11.86
25	10.29	69.09	23.56	15.06	1.91	65195.21	7.11	11.29	0.96	112.08	11.86
26	10.09	67.84	26.69	15.02	1.64	65510.13	6.93	10.93	0.82	113.40	11.89
27	11.00	66.77	22.13	14.96	1.86	66514.14	6.88	12.08	0.93	113.84	11.82
28	10.73	67.41	16.66	14.97	1.90	65700.27	6.78	10.70	0.95	114.62	11.79
29	9.89	54.60	25.40	14.71	2.08	68100.66	5.74	8.93	1.04	114.86	11.73
30	9.95	42.80	22.39	14.23	2.06	73003.29	4.73	8.46	1.03	115.31	11.68
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	9.39	67.17	19.32	14.95	2.02	66266.32	6.46	9.88	1.01	114.23	11.90
最大值	11.00	73.37	27.21	15.15	2.53	73003.29	7.96	16.74	1.26	116.43	12.03
發生日期											
最小值	4.37	42.80	14.30	14.23	1.49	65028.98	4.73	4.18	0.74	110.66	11.67
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國107年4月30日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	℃	m/s
01	8.35	56.26	17.79	14.12	2.94	78036.98	19.62	15.06	1.47	123.65	12.41
02	7.57	55.58	20.22	14.13	2.95	78412.97	18.82	2.54	1.47	122.75	12.44
03	7.72	59.43	23.62	14.16	2.97	79120.96	18.59	7.87	1.48	122.73	12.63
04	7.36	62.62	27.02	14.14	3.01	79574.82	18.01	5.99	1.50	122.38	12.66
05	7.35	60.89	18.99	14.22	2.99	78997.48	18.77	6.21	1.49	122.74	12.72
06	7.55	63.40	17.57	14.35	2.97	77437.75	19.73	5.73	1.49	120.80	12.65
07	6.36	70.40	18.92	14.48	3.07	76743.60	20.97	9.75	1.54	118.82	12.72
08	7.93	66.74	15.92	14.45	3.10	77389.70	20.71	11.36	1.55	120.72	12.83
09	7.08	61.88	14.22	14.14	3.06	78611.71	19.65	3.34	1.53	120.76	12.44
10	7.24	58.04	14.39	14.02	3.00	77627.05	19.20	7.44	1.50	120.96	12.10
11	7.28	57.17	20.42	13.94	2.99	78980.14	18.30	13.40	1.49	122.52	12.20
12	6.95	52.94	20.94	13.87	3.02	78667.97	18.18	11.28	1.51	122.54	12.04
13	7.59	52.90	25.07	13.92	3.01	77760.57	18.56	9.77	1.51	122.95	11.99
14	6.99	62.17	20.85	14.15	3.03	77763.17	18.21	5.82	1.51	123.05	12.37
15	7.93	58.20	16.10	14.07	2.99	77503.12	20.15	5.94	1.50	120.25	12.10
16	8.26	59.93	13.73	14.11	3.06	76764.33	20.31	6.28	1.53	119.85	12.07
17	6.73	67.40	12.02	14.29	3.11	77091.24	19.15	5.25	1.56	119.55	12.43
18	7.77	57.07	14.92	14.18	3.12	77996.09	19.16	9.73	1.56	120.63	12.42
19	8.26	54.26	16.40	14.10	3.10	78709.28	19.03	11.59	1.55	122.16	12.43
20	7.41	52.77	21.44	14.05	3.05	78432.29	19.18	8.79	1.52	122.39	12.31
21	7.50	51.40	28.28	13.95	3.00	78439.87	18.99	10.89	1.50	122.07	12.12
22	7.36	52.30	16.75	14.01	2.96	77249.94	18.91	14.32	1.48	122.20	12.04
23	7.31	50.65	16.31	14.00	2.92	77457.01	18.17	7.44	1.46	122.54	12.08
24	7.43	50.16	15.38	14.04	2.94	77803.53	18.22	3.35	1.47	121.19	12.15
25	9.31	54.55	19.40	14.06	3.03	78705.88	19.50	10.74	1.51	120.18	12.29
26	8.17	58.40	12.68	14.15	3.07	78051.53	19.29	7.93	1.53	120.95	12.38
27	9.51	61.09	16.74	14.28	3.08	77952.81	19.84	11.86	1.54	121.55	12.62
28	7.57	56.61	13.39	14.09	3.01	78611.98	19.37	10.27	1.50	121.94	12.39
29	7.62	56.41	17.55	14.26	3.05	76665.37	19.10	7.16	1.52	120.98	12.35
30	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機
監測日數	29	29	29	29	29	29	29	29	29	29	29
平均值	7.64	57.99	18.17	14.13	3.02	78019.28	19.16	8.52	1.51	121.58	12.36
最大值	9.51	70.40	28.28	14.48	3.12	79574.82	20.97	15.06	1.56	123.65	12.83
發生日期											
最小值	6.36	50.16	12.02	13.87	2.92	76665.37	18.01	2.54	1.46	118.82	11.99
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管