

連續自動監測紀錄月報表

中華民國112年6月30日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	4.41	43.41	8.01	11.24	1.68	74134.06	16.51	10.69	1.12	178.16	13.31
02	3.95	45.96	9.95	11.06	1.75	75330.84	17.11	10.59	1.17	179.83	13.42
03	3.96	46.93	8.60	10.92	1.84	76237.17	17.06	10.04	1.22	179.83	13.39
04	4.24	46.95	8.60	10.98	1.79	75553.14	17.12	10.17	1.19	179.54	13.36
05	4.54	45.15	7.94	11.03	1.76	74802.49	16.40	10.09	1.17	178.38	13.13
06	4.24	49.22	8.69	11.02	1.81	75470.52	16.78	9.80	1.21	180.04	13.34
07	4.50	50.14	7.15	10.99	1.79	75239.49	16.82	10.62	1.19	179.59	13.26
08	4.26	49.53	6.98	10.88	1.76	75516.40	17.00	9.94	1.17	179.52	13.19
09	4.36	50.18	7.31	11.05	1.69	75101.53	17.14	9.90	1.13	179.73	13.37
10	4.73	51.51	8.15	11.17	1.68	74554.29	16.58	9.97	1.12	178.93	13.33
11	4.58	55.07	8.75	11.02	1.65	75971.11	17.11	10.31	1.10	179.73	13.48
12	4.74	50.19	8.73	10.99	1.67	75393.41	17.02	9.51	1.12	179.44	13.32
13	4.77	43.63	8.63	11.23	1.72	74093.34	16.52	10.38	1.15	179.74	13.34
14	4.80	36.50	7.03	11.08	1.71	75101.38	16.93	9.84	1.14	180.35	13.40
15	4.90	39.20	6.85	11.08	1.67	75045.87	16.14	10.15	1.12	179.26	13.23
16	4.23	40.39	6.53	11.07	1.71	75206.67	17.00	9.99	1.14	180.47	13.41
17	4.51	43.74	7.17	11.02	1.68	74998.45	16.91	10.81	1.12	179.65	13.28
18	4.00	46.37	7.14	10.90	1.66	75004.43	17.49	9.54	1.11	179.75	13.22
19	4.39	48.09	7.77	10.82	1.66	75327.78	17.17	9.63	1.11	179.23	13.10
20	3.98	51.04	7.53	10.97	1.67	75265.33	17.24	9.44	1.12	181.18	13.35
21	4.25	45.01	7.52	11.08	1.66	74985.55	16.89	10.03	1.11	181.32	13.40
22	4.36	41.04	6.60	11.01	1.67	74962.04	16.75	9.30	1.11	180.64	13.26
23	4.69	43.84	7.10	11.16	1.65	75618.29	16.29	9.92	1.10	180.92	13.52
24	4.42	43.58	7.03	11.06	1.66	75962.95	16.70	10.22	1.11	180.73	13.50
25	4.00	41.86	7.91	10.92	1.71	76505.62	17.73	9.38	1.14	182.28	13.61
26	4.44	43.38	7.40	10.99	1.75	75882.01	16.80	9.38	1.17	181.61	13.44
27	4.37	48.32	7.97	10.95	1.75	76091.18	16.80	10.17	1.17	181.40	13.42
28	3.99	51.93	9.27	10.80	1.70	77095.24	17.22	9.64	1.14	181.92	13.46
29	4.34	53.53	8.69	10.81	1.73	76544.09	16.60	10.10	1.16	180.11	13.23
30	4.20	54.11	9.75	11.10	1.72	75034.49	16.49	9.77	1.15	180.25	13.35
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	4.37	46.66	7.89	11.01	1.71	75400.97	16.88	9.98	1.14	180.12	13.35
最大值	4.90	55.07	9.95	11.24	1.84	77095.24	17.73	10.81	1.22	182.28	13.61
發生日期											
最小值	3.95	36.50	6.53	10.80	1.65	74093.34	16.14	9.30	1.10	178.16	13.10
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國112年6月30日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	4.10	50.47	8.87	10.98	1.40	77621.89	17.51	11.24	0.94	185.59	13.97
02	3.14	52.60	10.16	10.78	1.49	79847.80	18.52	10.90	0.99	187.48	14.33
03	3.23	53.83	8.06	10.83	1.57	79450.86	18.03	10.75	1.05	187.06	14.23
04	3.42	51.20	9.79	10.69	1.62	80024.54	18.57	10.33	1.08	187.54	14.24
05	4.00	42.54	7.87	10.72	1.66	79232.92	17.77	10.29	1.10	186.40	13.97
06	3.52	45.08	9.53	10.85	1.62	78730.30	17.99	9.57	1.08	187.72	14.14
07	3.15	47.29	7.46	10.72	1.54	79771.81	17.99	11.49	1.03	193.36	14.31
08	3.30	49.93	7.31	10.62	1.50	80393.31	18.27	10.96	1.00	190.43	14.25
09	3.30	50.01	8.64	10.84	1.48	78692.80	18.39	10.35	0.98	188.34	14.20
10	4.03	50.67	9.17	10.86	1.49	78396.45	18.12	11.29	0.99	187.04	14.09
11	4.23	50.48	8.15	10.71	1.48	79383.10	18.49	11.16	0.99	187.34	14.14
12	4.32	48.62	9.87	10.66	1.53	79944.65	18.06	10.01	1.01	187.42	14.10
13	4.25	47.99	8.63	10.96	1.57	78496.83	17.58	11.05	1.05	187.89	14.18
14	4.42	42.62	9.12	10.83	1.59	78301.86	17.75	10.46	1.06	187.31	13.98
15	3.89	41.81	7.60	10.71	1.59	78988.22	17.86	10.06	1.06	186.38	13.92
16	3.13	43.94	7.65	10.79	1.61	79161.09	18.49	10.66	1.08	188.55	14.24
17	2.84	43.44	8.98	10.70	1.59	79155.47	18.87	10.51	1.06	188.41	14.17
18	2.76	44.94	7.65	10.62	1.58	79151.24	19.39	10.43	1.06	188.73	14.16
19	3.03	44.33	8.79	10.47	1.57	79898.81	19.00	9.31	1.04	187.88	14.00
20	2.97	43.94	8.20	10.47	1.56	79771.63	19.20	9.36	1.04	188.33	14.03
21	2.75	45.49	8.19	10.66	1.55	79465.34	18.68	9.34	1.03	189.10	14.17
22	2.84	40.52	6.37	10.60	1.48	79001.41	18.75	9.41	0.98	187.60	13.96
23	3.23	42.64	8.11	10.75	1.44	80052.59	18.39	10.19	0.96	189.85	14.37
24	2.75	44.20	7.61	10.76	1.48	80259.35	18.61	10.35	0.98	189.64	14.45
25	2.49	42.31	8.99	10.64	1.50	80180.07	19.35	9.28	1.00	190.51	14.43
26	3.20	40.86	9.20	10.56	1.43	80166.66	18.71	9.58	0.96	189.22	14.16
27	2.83	45.27	9.75	10.67	1.42	79540.40	18.36	9.77	0.95	189.13	14.13
28	2.71	46.44	10.56	10.62	1.44	79772.94	18.56	9.63	0.96	188.96	14.13
29	3.70	47.17	8.04	10.74	1.44	78972.54	17.62	10.99	0.96	187.37	13.95
30	3.24	50.01	9.71	10.93	1.38	78304.86	17.87	10.37	0.92	188.23	14.17
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.36	46.35	8.60	10.72	1.52	79337.72	18.36	10.30	1.01	188.29	14.15
最大值	4.42	53.83	10.56	10.98	1.66	80393.31	19.39	11.49	1.10	193.36	14.45
發生日期											
最小值	2.49	40.52	6.37	10.47	1.38	77621.89	17.51	9.28	0.92	185.59	13.92
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管