

連續自動監測紀錄月報表

中華民國112年7月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	4.31	49.44	9.12	11.03	1.71	74895.68	16.60	10.30	1.14	179.83	13.24
02	4.14	50.85	8.42	10.98	1.63	75631.19	17.07	10.09	1.08	180.99	13.39
03	4.14	51.56	10.83	11.03	1.66	75089.56	16.55	9.91	1.11	183.91	13.37
04	4.33	51.30	9.12	11.26	1.64	73964.91	16.19	9.73	1.10	182.38	13.39
05	3.71	52.55	11.29	10.85	1.64	76655.57	16.75	8.36	1.09	184.10	13.45
06	4.37	53.41	10.58	11.10	1.54	74422.22	16.06	8.65	1.03	180.80	13.17
07	4.85	56.80	8.51	11.55	1.39	74542.36	15.60	9.78	0.99	179.37	13.73
08	4.26	56.26	8.63	11.10	1.23	74129.63	16.21	9.79	0.96	180.45	13.14
09	4.23	56.31	6.56	10.95	1.27	74941.67	16.78	9.23	0.99	180.47	13.18
10	4.27	56.11	7.96	11.01	1.37	76832.02	16.60	8.96	0.98	189.19	14.60
11	4.54	50.27	9.61	11.40	1.22	73901.44	16.26	9.18	1.40	182.06	13.58
12	4.44	45.15	9.72	11.29	1.22	73510.58	16.50	10.16	2.04	180.31	13.34
13	4.32	49.78	9.95	11.14	1.20	74216.62	16.47	10.10	1.99	179.94	13.25
14	4.30	53.03	8.71	11.22	1.22	74116.66	16.69	10.02	2.04	180.56	13.38
15	4.56	53.75	9.40	11.41	1.26	73192.29	16.17	9.80	2.09	180.84	13.40
16	4.46	53.89	8.28	11.33	1.27	73474.11	16.41	9.94	2.12	180.73	13.37
17	4.57	51.75	8.41	11.06	1.25	74088.09	16.46	10.21	2.08	179.29	13.09
18	4.25	52.62	8.67	11.21	1.19	74035.72	16.67	9.77	1.99	180.76	13.35
19	3.65	45.68	8.73	11.45	1.19	73652.12	16.55	9.46	1.98	184.63	13.70
20	4.47	50.08	8.82	11.42	1.17	73288.61	16.26	10.28	1.95	182.31	13.50
21	3.89	51.26	9.21	11.34	1.16	74446.91	16.75	9.70	1.92	186.55	13.81
22	4.21	50.90	8.58	11.22	1.16	74514.70	16.60	10.41	1.93	183.33	13.52
23	4.46	55.44	7.34	11.29	1.13	74517.24	16.77	10.21	1.88	182.81	13.62
24	4.60	55.14	7.51	11.26	1.14	74339.39	16.39	10.02	1.90	182.46	13.48
25	4.49	55.68	6.89	11.17	1.17	74564.48	16.71	10.06	1.95	182.46	13.45
26	4.27	52.73	7.90	11.25	1.23	74196.05	16.64	9.67	2.05	181.79	13.46
27	4.44	53.85	8.69	11.36	1.26	71818.87	16.13	8.56	2.10	179.86	13.05
28	4.56	54.37	8.44	11.40	1.21	73626.76	16.34	8.64	2.03	180.44	13.48
29	4.44	55.97	8.49	11.22	1.19	74394.45	16.32	8.58	1.99	180.71	13.38
30	4.43	56.02	8.07	11.04	1.16	75694.21	16.69	8.80	1.94	181.00	13.43
31	4.29	55.63	7.75	11.10	1.20	75287.48	16.56	8.61	2.00	181.34	13.45
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.33	52.83	8.72	11.21	1.30	74386.50	16.48	9.58	1.67	181.80	13.44
最大值	4.85	56.80	11.29	11.55	1.71	76832.02	17.07	10.41	2.12	189.19	14.60
發生日期											
最小值	3.65	45.15	6.56	10.85	1.13	71818.87	15.60	8.36	0.96	179.29	13.05
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國112年7月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.52	43.42	8.77	10.75	1.39	79163.05	18.37	9.95	0.93	188.34	14.15
02	3.04	43.19	9.40	10.61	1.36	80176.91	18.88	10.10	0.91	189.24	14.26
03	3.62	42.42	10.12	10.72	1.32	79734.00	18.09	9.80	0.88	189.13	14.20
04	2.82	45.77	9.41	10.83	1.37	79551.56	18.25	9.11	0.92	193.01	14.47
05	3.07	45.43	10.09	10.83	1.42	79434.79	18.28	9.54	0.94	190.43	14.38
06	2.56	46.76	13.17	10.88	1.41	78914.08	18.06	9.53	0.94	192.49	14.37
07	2.79	52.24	12.44	11.31	1.41	75687.29	18.09	10.88	1.01	191.02	14.36
08	3.06	49.78	9.04	11.29	1.38	75251.66	17.46	9.74	1.06	190.19	14.11
09	2.72	48.92	7.71	11.09	1.37	76267.88	18.61	9.17	1.06	190.24	14.21
10	3.02	51.67	9.87	11.40	1.37	76832.02	17.65	8.76	1.06	189.19	14.60
11	3.22	43.14	10.43	11.15	1.36	77130.08	18.19	8.95	1.55	191.09	14.42
12	3.33	34.33	11.43	11.21	1.38	78718.43	17.75	8.73	2.29	186.47	14.57
13	2.72	42.09	9.56	11.18	1.37	77684.73	17.89	9.43	2.28	189.70	14.45
14	2.70	43.80	8.57	11.00	1.43	77497.90	18.49	9.96	2.38	191.17	14.32
15	2.87	44.15	10.38	11.17	1.43	76749.82	17.86	9.35	2.39	189.21	14.25
16	2.60	43.39	9.16	11.10	1.41	77115.18	18.20	10.43	2.35	188.43	14.25
17	3.21	42.59	9.56	10.88	1.45	77428.32	18.26	9.58	2.42	186.58	13.95
18	2.91	42.82	9.27	10.97	1.40	77707.83	18.56	9.46	2.34	188.61	14.23
19	1.91	37.02	10.37	10.99	1.40	77648.52	18.47	9.28	2.33	190.69	14.31
20	2.48	42.09	9.19	11.02	1.39	77043.87	18.01	10.82	2.32	188.21	14.08
21	1.98	41.39	10.28	10.92	1.41	78221.05	18.70	10.58	2.36	192.84	14.42
22	2.55	45.41	9.72	10.90	1.46	78362.57	18.58	10.96	2.44	192.14	14.38
23	2.87	49.95	7.77	10.97	1.46	78297.40	18.70	9.96	2.44	191.23	14.46
24	3.06	47.08	9.26	10.89	1.48	78573.00	18.13	9.90	2.46	190.18	14.26
25	3.01	49.90	8.17	10.97	1.49	77622.69	18.47	10.23	2.48	190.41	14.26
26	2.86	45.47	9.06	11.01	1.45	77396.81	18.36	10.81	2.42	189.89	14.25
27	3.18	46.02	9.35	10.86	1.45	78272.85	18.24	9.15	2.43	189.06	14.15
28	3.68	52.48	8.94	11.16	1.46	77084.31	17.78	8.09	2.43	189.28	14.29
29	2.89	53.35	9.14	10.92	1.48	78446.25	18.22	8.53	2.46	189.20	14.27
30	3.01	51.06	9.35	10.85	1.47	78531.69	18.51	8.26	2.44	189.55	14.26
31	3.48	50.98	10.14	10.91	1.48	78170.33	18.12	8.12	2.47	189.31	14.20
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.93	45.75	9.65	10.99	1.42	77894.09	18.23	9.59	1.91	189.89	14.29
最大值	3.68	53.35	13.17	11.40	1.49	80176.91	18.88	10.96	2.48	193.01	14.60
發生日期											
最小值	1.91	34.33	7.71	10.61	1.32	75251.66	17.46	8.09	0.88	186.47	13.95
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管