

# 連續自動監測紀錄月報表

中華民國113年12月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO <sub>2</sub> 二氧化硫	NO <sub>x</sub> 氮氧化物	CO 一氧化碳	O <sub>2</sub> 氧氣	DUST 粉塵濃度	MASS 排放流率	H <sub>2</sub> O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	3.80	41.71	8.97	10.80	1.31	79481.58	17.62	8.92	1.01	185.84	14.07
02	3.60	43.90	8.92	10.69	1.31	79101.24	18.12	9.56	1.01	185.58	13.92
03	3.47	44.35	8.88	10.69	1.33	78931.15	18.30	8.58	1.02	185.82	13.93
04	4.00	45.69	11.36	10.75	1.28	79876.02	17.57	9.38	0.99	186.15	14.07
05	3.92	45.50	9.51	10.61	1.25	79408.96	17.68	9.16	0.96	184.44	13.77
06	3.71	49.46	10.40	10.81	1.27	79833.52	17.63	9.27	0.98	186.84	14.17
07	3.96	48.64	10.34	10.91	1.26	79907.10	17.22	8.88	0.98	186.79	14.27
08	4.11	45.45	9.03	10.81	1.29	81250.10	17.24	8.73	0.99	186.90	14.36
09	3.54	41.58	8.76	10.54	1.29	80599.40	18.07	8.42	0.99	184.74	13.96
10	3.82	45.55	8.79	10.75	1.27	80152.72	17.97	8.82	0.98	186.97	14.21
11	4.07	45.51	9.65	10.70	1.26	80331.20	17.76	8.99	0.97	188.16	14.18
12	4.08	43.27	10.68	10.74	1.27	80151.63	17.41	9.21	0.98	185.72	14.07
13	4.00	45.84	8.41	10.80	1.31	81310.77	17.67	8.83	1.01	187.69	14.47
14	4.40	46.54	9.25	10.90	1.35	82862.49	16.81	8.84	1.05	187.94	14.73
15	4.40	44.29	9.74	10.99	1.37	82255.29	16.52	8.66	1.06	188.30	14.72
16	4.20	43.81	5.71	10.81	1.34	81602.33	17.02	8.74	1.03	187.13	14.40
17	3.91	41.30	10.25	10.93	1.32	81609.77	17.18	8.88	1.01	188.67	14.65
18	4.05	44.76	9.15	10.87	1.31	82561.77	16.91	8.64	1.00	188.79	14.69
19	4.16	41.03	8.38	10.88	1.31	82142.36	16.65	8.60	1.01	187.15	14.52
20	4.02	38.33	9.79	10.94	1.30	81333.51	17.35	8.86	1.00	188.16	14.63
21	4.05	40.76	8.23	10.88	1.29	82058.64	17.35	8.80	1.00	188.49	14.68
22	4.15	39.78	7.01	10.72	1.29	83575.71	17.69	8.66	1.00	189.23	14.80
23	4.02	39.43	6.76	10.80	1.30	82601.78	17.74	8.84	1.00	189.44	14.76
24	4.24	40.21	9.90	11.02	1.31	82342.13	17.10	9.04	1.01	189.56	14.92
25	3.97	44.36	9.36	10.90	1.30	82304.38	17.50	9.01	1.00	190.56	14.84
26	4.22	50.66	8.20	10.90	1.29	82904.90	16.96	8.82	0.99	189.91	14.84
27	4.04	50.24	8.82	10.84	1.26	82868.02	17.44	8.84	0.98	190.26	14.84
28	4.36	46.65	10.10	10.85	1.29	82694.75	16.58	8.83	1.00	187.76	14.59
29	4.11	45.39	10.16	10.80	1.26	83069.93	17.09	8.66	0.97	188.37	14.70
30	4.13	44.94	9.03	10.74	1.26	82455.56	17.54	8.80	0.97	189.20	14.60
31	4.26	48.79	7.49	10.91	1.25	82109.66	16.80	8.80	0.96	188.75	14.65
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.02	44.44	9.07	10.82	1.29	81409.30	17.37	8.87	1.00	187.72	14.45
最大值	4.40	50.66	11.36	11.02	1.37	83575.71	18.30	9.56	1.06	190.56	14.92
發生日期											
最小值	3.47	38.33	5.71	10.54	1.25	78931.15	16.52	8.42	0.96	184.44	13.77
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國113年12月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	3.04	30.08	14.34	10.71	0.93	80006.44	18.47	8.16	0.72	191.61	14.36
02	2.37	33.30	13.87	10.51	0.96	80755.25	19.27	7.99	0.74	192.07	14.38
03	2.04	36.74	14.34	10.46	0.97	80163.63	19.33	7.50	0.75	193.18	14.25
04	2.82	37.44	15.06	10.67	0.97	79352.02	18.01	7.07	0.75	190.80	14.09
05	2.81	40.17	13.87	10.65	0.96	80421.45	18.07	8.20	0.74	191.11	14.27
06	2.81	41.93	16.03	10.59	0.98	79074.42	18.31	8.34	0.75	189.48	13.95
07	2.67	41.12	13.48	10.70	0.97	79708.59	18.15	8.09	0.75	190.44	14.21
08	3.15	45.60	11.57	10.71	0.98	81042.70	17.92	8.15	0.76	192.05	14.47
09	2.51	38.36	13.05	10.57	0.93	81092.65	18.54	7.33	0.71	191.75	14.38
10	2.57	48.00	14.11	11.01	0.90	79043.74	18.27	7.91	0.69	194.46	14.67
11	3.05	49.38	12.52	10.97	0.90	79116.66	17.85	8.03	0.69	193.86	14.54
12	3.01	46.62	14.18	10.71	0.92	80203.73	18.04	8.93	0.70	191.89	14.34
13	2.15	44.39	13.49	10.77	0.96	80585.32	18.39	8.63	0.74	193.46	14.57
14	2.49	54.84	10.86	10.88	1.03	82042.11	17.45	8.76	0.79	193.99	14.86
15	2.67	53.58	10.53	10.84	1.02	82751.85	17.71	8.48	0.79	195.76	15.04
16	2.92	47.60	10.64	10.74	1.04	81605.25	17.75	8.29	0.80	194.00	14.64
17	2.49	46.30	12.30	10.79	1.08	81200.67	17.94	8.41	0.83	193.96	14.67
18	2.26	47.41	12.10	10.73	1.07	81835.92	17.95	8.03	0.82	194.01	14.70
19	2.30	46.41	11.50	10.77	1.03	81247.53	17.33	7.78	0.79	194.82	14.57
20	2.38	41.20	14.93	10.53	1.02	78236.75	18.70	8.11	0.78	190.07	13.80
21	2.52	50.38	11.04	10.87	1.05	80341.92	17.84	8.73	0.80	193.67	14.60
22	2.81	51.29	9.49	10.67	1.06	81670.74	18.34	8.78	0.81	193.75	14.64
23	2.69	44.13	12.34	10.59	1.07	80721.92	18.56	9.29	0.83	193.00	14.39
24	2.47	47.12	11.82	10.69	1.08	79828.36	18.46	9.24	0.83	192.24	14.32
25	2.27	48.47	12.53	10.61	1.01	80239.93	18.64	8.97	0.78	193.16	14.35
26	2.50	51.28	10.99	10.66	0.95	79633.19	18.11	8.79	0.73	193.45	14.22
27	2.50	51.06	11.31	10.70	0.92	80893.35	18.04	8.62	0.71	194.65	14.53
28	2.77	48.33	11.33	10.64	0.94	81788.45	17.45	9.06	0.73	192.75	14.44
29	2.33	46.88	11.32	10.55	0.94	81947.75	18.07	8.85	0.73	193.48	14.50
30	2.70	49.13	11.03	10.60	0.97	80143.40	18.23	8.86	0.75	192.54	14.23
31	2.74	45.57	10.56	10.74	0.96	80079.14	17.65	8.77	0.74	192.68	14.32
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.61	45.29	12.47	10.70	0.99	80541.12	18.16	8.39	0.76	192.84	14.43
最大值	3.15	54.84	16.03	11.01	1.08	82751.85	19.33	9.29	0.83	195.76	15.04
發生日期											
最小值	2.04	30.08	9.49	10.46	0.90	78236.75	17.33	7.07	0.69	189.48	13.80
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管