

連續自動監測紀錄月報表

中華民國110年6月30日

| 項目 日期 | 管制編號 | | | F0501686 | | 煙道排放口編 | | P001 | | | |
|----------|-------------------------|-------------------------|------------|----------------------|-------------------|---------------------|------------------------|-----------|--------------|------------|-----------|
| | SO ₂ 二氧化硫 | NO _x 氮氧化物 | CO 一氧化碳 | O ₂ 氧氣 | DUST 粉塵濃度 | MASS 排放流率 | H ₂ O 水份 | HCL 鹽酸 | OPAC 不透光率 | TEMP 溫度 | VEL 流速 |
| | ppm | ppm | ppm | % | mg/m ³ | Nm ³ /hr | % | ppm | % | °C | m/s |
| 01 | 3.80 | 64.22 | 6.98 | 10.67 | 1.39 | 81970.71 | 17.88 | 16.14 | 0.93 | 171.59 | 13.96 |
| 02 | 4.01 | 59.70 | 8.95 | 10.00 | 1.41 | 83037.49 | 18.70 | 16.18 | 0.94 | 176.22 | 13.55 |
| 03 | 3.56 | 57.15 | 7.90 | 9.55 | 1.39 | 82759.83 | 19.07 | 16.48 | 0.93 | 178.89 | 13.08 |
| 04 | 3.08 | 58.39 | 8.74 | 9.81 | 1.35 | 82286.69 | 18.88 | 15.85 | 0.90 | 179.29 | 13.29 |
| 05 | 2.49 | 57.72 | 7.89 | 9.78 | 1.28 | 81971.79 | 18.40 | 16.54 | 0.85 | 179.75 | 13.15 |
| 06 | 2.40 | 56.92 | 6.64 | 9.76 | 1.29 | 83208.15 | 18.39 | 16.18 | 0.86 | 183.97 | 13.43 |
| 07 | 3.05 | 60.49 | 8.25 | 9.88 | 1.29 | 82091.68 | 18.76 | 16.41 | 0.86 | 180.93 | 13.38 |
| 08 | 2.53 | 60.33 | 8.82 | 9.89 | 1.28 | 82545.11 | 18.85 | 15.65 | 0.85 | 181.03 | 13.48 |
| 09 | 3.93 | 57.72 | 7.67 | 9.83 | 1.30 | 82943.22 | 18.69 | 15.96 | 0.87 | 181.00 | 13.45 |
| 10 | 3.23 | 62.13 | 8.01 | 9.77 | 1.32 | 81931.66 | 18.93 | 16.49 | 0.88 | 179.18 | 13.18 |
| 11 | 4.27 | 64.32 | 8.07 | 9.72 | 1.37 | 82824.20 | 18.74 | 16.43 | 0.92 | 180.38 | 13.28 |
| 12 | 4.20 | 63.01 | 7.88 | 9.64 | 1.38 | 83004.00 | 18.69 | 14.55 | 0.92 | 180.11 | 13.20 |
| 13 | 4.34 | 62.57 | 6.62 | 9.63 | 1.33 | 83225.50 | 18.73 | 16.11 | 0.89 | 179.96 | 13.22 |
| 14 | 3.93 | 62.28 | 8.01 | 9.53 | 1.35 | 83709.20 | 19.33 | 16.20 | 0.90 | 180.83 | 13.32 |
| 15 | 3.65 | 62.98 | 6.32 | 9.71 | 1.40 | 82958.39 | 18.96 | 15.84 | 0.94 | 181.26 | 13.36 |
| 16 | 3.74 | 60.28 | 7.08 | 9.52 | 1.39 | 84215.48 | 19.16 | 15.11 | 0.93 | 181.61 | 13.37 |
| 17 | 3.85 | 58.85 | 7.64 | 9.53 | 1.37 | 82724.87 | 18.27 | 14.93 | 0.91 | 179.48 | 12.95 |
| 18 | 3.67 | 62.35 | 6.94 | 9.63 | 1.36 | 82634.69 | 18.35 | 14.51 | 0.91 | 179.22 | 13.06 |
| 19 | 3.31 | 62.70 | 8.25 | 9.73 | 1.36 | 82782.50 | 18.28 | 14.06 | 0.90 | 180.21 | 13.20 |
| 20 | 3.43 | 60.63 | 7.39 | 9.44 | 1.34 | 84514.72 | 19.04 | 14.02 | 0.89 | 180.97 | 13.30 |
| 21 | 3.56 | 62.37 | 6.89 | 9.61 | 1.33 | 83692.95 | 18.84 | 12.97 | 0.89 | 181.03 | 13.32 |
| 22 | 3.09 | 65.19 | 6.97 | 10.09 | 1.27 | 82409.31 | 18.22 | 13.66 | 0.85 | 177.40 | 13.51 |
| 23 | 3.30 | 63.37 | 8.04 | 10.56 | 1.25 | 83795.31 | 17.68 | 15.74 | 0.91 | 173.52 | 14.12 |
| 24 | 2.86 | 61.75 | 7.65 | 10.23 | 1.24 | 83575.66 | 18.04 | 14.35 | 0.88 | 174.14 | 13.73 |
| 25 | 3.23 | 62.54 | 7.06 | 9.57 | 1.23 | 83224.22 | 18.93 | 13.17 | 0.82 | 181.32 | 13.23 |
| 26 | 3.49 | 63.30 | 7.85 | 9.55 | 1.28 | 82948.92 | 18.65 | 12.95 | 0.85 | 181.09 | 13.12 |
| 27 | 2.99 | 64.11 | 6.93 | 9.49 | 1.34 | 83650.18 | 19.05 | 13.30 | 0.89 | 181.90 | 13.24 |
| 28 | 2.88 | 62.03 | 7.21 | 9.45 | 1.36 | 83975.93 | 18.99 | 12.68 | 0.91 | 182.12 | 13.24 |
| 29 | 2.83 | 64.22 | 5.90 | 9.60 | 1.38 | 83096.25 | 18.40 | 12.32 | 0.92 | 181.71 | 13.18 |
| 30 | 3.21 | 64.39 | 7.39 | 9.50 | 1.38 | 83033.40 | 18.53 | 12.32 | 0.92 | 181.40 | 13.06 |
| 監測日數 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 |
| 平均值 | 3.40 | 61.60 | 7.53 | 9.76 | 1.33 | 83024.73 | 18.65 | 14.90 | 0.89 | 179.72 | 13.33 |
| 最大值 | 4.34 | 65.19 | 8.95 | 10.67 | 1.41 | 84514.72 | 19.33 | 16.54 | 0.94 | 183.97 | 14.12 |
| 發生日期 | | | | | | | | | | | |
| 最小值 | 2.40 | 56.92 | 5.90 | 9.44 | 1.23 | 81931.66 | 17.68 | 12.32 | 0.82 | 171.59 | 12.95 |
| 發生日期 | | | | | | | | | | | |
| 超標準時數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 標準值 | 150 | 220 | 150 | ----- | ----- | ----- | ----- | 60 | 20 | ----- | ----- |

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國110年6月30日

| 項目 日期 | 管制編號 | | | F0501686 | | 煙道排放口編 | | P002 | | | |
|----------|-----------------|-----------------|-------|----------------|-------------------|---------------------|------------------|-------|------|--------|-------|
| | SO ₂ | NO _x | CO | O ₂ | DUST | MASS | H ₂ O | HCL | OPAC | TEMP | VEL |
| | 二氧化硫 | 氮氧化物 | 一氧化碳 | 氧氣 | 粉塵濃度 | 排放流率 | 水份 | 鹽酸 | 不透光率 | 溫度 | 流速 |
| | ppm | ppm | ppm | % | mg/m ³ | Nm ³ /hr | % | ppm | % | °C | m/s |
| 01 | 3.86 | 59.55 | 10.91 | 10.12 | 1.58 | 80995.71 | 20.00 | 16.27 | 1.06 | 190.34 | 13.98 |
| 02 | 4.72 | 57.29 | 10.77 | 9.97 | 1.59 | 80550.04 | 19.73 | 16.50 | 1.06 | 188.60 | 13.62 |
| 03 | 4.12 | 57.10 | 10.16 | 9.80 | 1.64 | 79139.65 | 19.74 | 16.67 | 1.09 | 185.25 | 13.08 |
| 04 | 4.11 | 60.14 | 11.46 | 10.37 | 1.71 | 78680.29 | 18.87 | 16.41 | 1.14 | 188.21 | 13.69 |
| 05 | 停爐 | 停爐 | 停爐 | 停爐 | 停爐 | 停爐 | 停爐 | 停爐 | 停爐 | 停爐 | 停爐 |
| 06 | 3.65 | 60.58 | 10.84 | 10.64 | 1.50 | 80116.12 | 18.05 | 16.62 | 1.00 | 191.23 | 14.20 |
| 07 | 3.41 | 60.30 | 11.42 | 10.33 | 1.50 | 80578.95 | 19.00 | 16.33 | 1.00 | 191.12 | 14.03 |
| 08 | 3.21 | 57.61 | 10.32 | 10.22 | 1.49 | 80725.80 | 19.78 | 15.79 | 0.99 | 191.79 | 14.08 |
| 09 | 4.86 | 53.64 | 10.35 | 10.03 | 1.54 | 81228.61 | 19.76 | 15.96 | 1.03 | 191.69 | 13.92 |
| 10 | 4.18 | 60.81 | 10.70 | 9.96 | 1.59 | 81420.58 | 19.93 | 16.57 | 1.06 | 190.14 | 13.86 |
| 11 | 5.37 | 59.92 | 10.13 | 9.88 | 1.56 | 82478.20 | 19.56 | 16.32 | 1.04 | 191.68 | 13.91 |
| 12 | 5.21 | 58.92 | 10.14 | 9.85 | 1.58 | 82703.50 | 19.56 | 15.97 | 1.06 | 191.92 | 13.92 |
| 13 | 5.17 | 55.60 | 10.31 | 9.76 | 1.61 | 83337.69 | 19.99 | 16.15 | 1.07 | 192.81 | 14.01 |
| 14 | 4.50 | 55.66 | 10.16 | 9.66 | 1.53 | 83488.42 | 20.55 | 16.59 | 1.02 | 193.10 | 14.01 |
| 15 | 4.85 | 54.11 | 10.20 | 9.71 | 1.47 | 83186.12 | 20.32 | 15.91 | 0.98 | 193.28 | 14.00 |
| 16 | 4.40 | 57.64 | 9.81 | 9.85 | 1.46 | 84486.55 | 20.00 | 15.14 | 0.97 | 195.07 | 14.38 |
| 17 | 4.16 | 58.59 | 10.71 | 9.80 | 1.48 | 84010.17 | 19.34 | 15.42 | 0.99 | 193.32 | 14.05 |
| 18 | 4.04 | 58.84 | 10.11 | 9.99 | 1.53 | 83603.91 | 19.01 | 14.87 | 1.02 | 194.50 | 14.22 |
| 19 | 4.44 | 58.27 | 9.84 | 10.17 | 1.54 | 82536.82 | 18.73 | 13.91 | 1.03 | 193.56 | 14.20 |
| 20 | 4.26 | 57.40 | 9.33 | 9.95 | 1.53 | 84524.58 | 19.64 | 14.08 | 1.02 | 195.26 | 14.45 |
| 21 | 3.64 | 61.24 | 9.43 | 10.17 | 1.52 | 84466.09 | 19.30 | 13.23 | 1.01 | 197.78 | 14.75 |
| 22 | 4.00 | 62.82 | 9.19 | 10.49 | 1.49 | 83386.25 | 18.89 | 13.86 | 0.99 | 192.21 | 14.78 |
| 23 | 4.38 | 63.24 | 10.54 | 10.94 | 1.62 | 84442.07 | 18.34 | 15.84 | 1.12 | 187.86 | 15.36 |
| 24 | 3.74 | 61.08 | 9.97 | 10.70 | 1.56 | 84405.48 | 18.55 | 15.28 | 1.10 | 189.15 | 15.08 |
| 25 | 3.66 | 61.77 | 10.34 | 10.04 | 1.62 | 84014.99 | 19.71 | 13.37 | 1.08 | 195.93 | 14.53 |
| 26 | 4.01 | 64.30 | 10.20 | 10.06 | 1.69 | 83986.15 | 19.40 | 13.14 | 1.12 | 195.57 | 14.48 |
| 27 | 3.45 | 63.70 | 9.20 | 10.04 | 1.66 | 84113.56 | 19.71 | 13.25 | 1.10 | 196.17 | 14.55 |
| 28 | 3.39 | 58.86 | 9.36 | 9.88 | 1.59 | 85367.98 | 19.72 | 12.69 | 1.06 | 196.77 | 14.57 |
| 29 | 3.78 | 60.20 | 9.38 | 10.07 | 1.62 | 84289.70 | 19.00 | 12.43 | 0.92 | 196.40 | 14.50 |
| 30 | 4.46 | 61.50 | 10.57 | 10.04 | 1.65 | 84129.55 | 19.07 | 12.56 | 1.10 | 196.14 | 14.44 |
| 監測日數 | 29 | 29 | 29 | 29 | 29 | 29 | 29 | 29 | 29 | 29 | 29 |
| 平均值 | 4.17 | 59.33 | 10.20 | 10.09 | 1.57 | 82772.19 | 19.42 | 15.07 | 1.04 | 192.65 | 14.23 |
| 最大值 | 5.37 | 64.30 | 11.46 | 10.94 | 1.71 | 85367.98 | 20.55 | 16.67 | 1.14 | 197.78 | 15.36 |
| 發生日期 | | | | | | | | | | | |
| 最小值 | 3.21 | 53.64 | 9.19 | 9.66 | 1.46 | 78680.29 | 18.05 | 12.43 | 0.92 | 185.25 | 13.08 |
| 發生日期 | | | | | | | | | | | |
| 超標準時數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 標準值 | 150 | 220 | 150 | ----- | ----- | ----- | ----- | 60 | 20 | ----- | ----- |
| 備註 | | | | | | | | | | | |

廠長

維修組長

操作組長

值班主管