

連續自動監測紀錄月報表

中華民國113年11月30日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	2.03	43.92	8.25	10.33	1.17	74194.08	20.18	10.17	0.90	183.52	12.85
02	1.64	45.32	7.58	10.01	1.18	74007.38	20.81	9.97	0.91	184.85	12.62
03	1.40	45.96	7.92	10.15	1.16	75629.83	21.10	9.17	0.90	186.99	13.18
04	2.15	47.40	6.63	10.26	1.17	74956.94	20.01	9.10	0.90	185.66	12.97
05	2.49	48.80	7.57	10.37	1.17	79334.06	20.17	9.16	0.90	185.72	13.91
06	2.70	49.58	7.54	10.40	1.15	80994.95	19.66	9.52	0.88	186.58	14.18
07	2.94	46.91	10.42	10.42	1.20	80814.74	19.55	9.34	0.93	185.98	14.13
08	3.25	49.33	8.18	10.48	1.21	80395.18	19.51	8.70	0.94	187.13	14.16
09	4.36	51.65	8.02	10.39	1.21	80246.12	19.81	9.16	0.94	187.70	14.08
10	4.07	49.42	8.36	10.22	1.23	81370.57	20.22	8.87	0.95	188.25	14.16
11	3.34	49.65	7.66	10.32	1.25	79910.16	19.74	9.16	0.96	186.66	13.90
12	2.57	47.77	7.89	10.39	1.25	80048.39	20.30	9.20	0.97	188.15	14.16
13	2.58	49.28	8.51	10.36	1.25	80566.34	20.20	8.57	0.97	188.50	14.21
14	2.73	46.07	8.81	10.21	1.26	79578.29	20.32	8.92	0.97	187.01	13.81
15	2.50	41.29	10.01	10.25	1.24	78936.51	20.21	8.67	0.96	188.16	13.76
16	2.87	47.40	9.27	10.56	1.24	78623.85	19.62	8.79	0.96	187.09	13.98
17	2.87	48.94	6.53	10.45	1.17	79169.26	19.95	8.94	0.90	186.85	13.98
18	2.86	45.50	7.66	10.23	1.15	80970.75	20.25	8.74	0.89	187.11	14.07
19	2.64	45.74	7.59	10.43	1.20	80912.73	20.04	8.61	0.92	188.86	14.34
20	2.64	40.01	7.73	10.45	1.22	80230.02	19.77	8.42	0.94	188.26	14.18
21	2.69	40.93	8.02	10.49	1.22	79798.76	19.52	8.56	0.94	186.00	14.04
22	2.61	40.36	9.37	10.47	1.22	80129.44	19.34	8.84	0.94	187.98	14.11
23	2.93	44.60	7.31	10.49	1.21	80361.28	19.06	8.83	0.94	186.26	14.06
24	2.90	41.91	6.37	10.38	1.23	79519.19	19.83	8.83	0.96	185.56	13.88
25	2.84	44.24	7.03	10.31	1.28	78796.33	19.85	8.66	0.99	185.38	13.67
26	3.01	41.03	8.43	10.50	1.24	78891.45	19.14	9.21	0.96	184.23	13.77
27	3.50	36.69	11.47	10.57	1.27	79742.75	18.12	8.82	0.98	183.59	13.82
28	3.41	38.83	9.38	10.54	1.30	80156.01	18.17	9.29	1.00	184.17	13.88
29	3.82	39.64	9.08	10.73	1.31	79894.57	17.55	9.23	1.01	184.49	13.99
30	3.90	40.09	9.91	10.74	1.30	79034.11	17.34	9.04	1.00	183.49	13.80
監測日數	30	30	30	30	29	30	30	30	30	30	30
平均值	2.87	44.94	8.28	10.40	1.22	79240.47	19.64	9.02	0.94	186.34	13.86
最大值	4.36	51.65	11.47	10.74	1.31	81370.57	21.10	10.17	1.01	188.86	14.34
發生日期											
最小值	1.40	36.69	6.37	10.01	1.15	74007.38	17.34	8.42	0.88	183.49	12.62
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國113年11月30日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	2.00	33.47	11.57	10.59	1.13	78402.33	20.61	9.56	0.87	192.73	14.32
02	1.52	31.14	12.33	10.42	1.04	80185.92	21.19	10.08	0.80	195.57	14.61
03	1.17	30.79	11.38	10.21	1.03	81491.18	22.13	9.10	0.79	196.94	14.78
04	1.29	34.38	14.24	10.51	1.03	80480.36	20.35	8.80	0.79	194.85	14.61
05	1.33	35.13	15.09	10.55	1.01	81609.26	20.46	9.37	0.77	196.35	14.95
06	1.66	35.43	14.21	10.69	0.99	83161.78	20.17	8.88	0.76	191.75	15.24
07	1.83	35.09	15.43	10.61	0.98	83037.10	20.02	9.22	0.75	191.86	15.06
08	1.95	37.96	14.23	10.54	1.01	82099.99	20.07	9.35	0.78	196.47	14.94
09	2.60	38.32	13.17	10.41	0.99	82139.08	20.58	8.82	0.76	196.99	14.89
10	1.81	37.54	14.25	10.12	1.00	84040.97	21.26	8.84	0.77	197.94	14.99
11	2.07	43.39	15.25	10.33	1.07	83148.65	20.34	8.96	0.82	196.44	14.90
12	1.73	43.04	13.24	10.34	1.06	83194.61	20.92	8.88	0.81	197.80	15.08
13	1.27	46.23	11.80	10.33	1.07	83193.84	20.92	8.51	0.82	198.30	15.08
14	1.39	38.96	13.13	10.34	1.10	81764.84	20.74	8.78	0.85	196.14	14.72
15	1.79	30.68	13.39	10.57	1.11	82122.41	20.35	8.69	0.86	190.94	14.87
16	1.79	35.28	14.84	10.77	1.11	80705.94	20.04	7.92	0.86	189.78	14.81
17	1.66	35.65	12.91	10.59	1.06	82145.79	20.39	8.43	0.81	192.15	14.95
18	1.60	34.60	13.07	10.62	1.06	80979.57	20.01	8.21	0.81	196.90	14.87
19	1.59	34.69	13.72	10.68	1.04	81287.10	20.04	8.25	0.80	197.25	15.03
20	1.77	34.31	12.99	10.49	1.02	81906.97	20.00	8.16	0.79	196.02	14.82
21	1.42	33.44	13.08	10.46	1.03	82318.30	20.13	8.47	0.79	196.16	14.87
22	1.72	30.92	13.23	10.61	1.03	81913.08	19.73	8.55	0.79	196.60	14.95
23	1.83	33.50	13.28	10.63	1.05	82323.59	19.46	8.05	0.81	196.96	15.02
24	1.56	33.96	14.05	10.47	1.06	82198.80	20.19	8.59	0.81	196.68	14.89
25	1.55	35.48	14.48	10.39	1.02	81541.31	20.21	7.83	0.79	196.10	14.65
26	2.03	36.44	14.09	10.57	0.95	82548.32	19.30	8.47	0.73	196.21	14.92
27	2.53	36.22	14.73	10.55	0.91	83592.18	18.52	8.83	0.70	196.94	14.96
28	2.83	36.59	14.34	10.77	0.95	81978.26	18.33	8.45	0.73	195.09	14.89
29	2.98	34.88	14.84	10.79	0.93	81331.17	18.09	8.88	0.72	193.09	14.70
30	3.65	31.52	13.04	10.86	0.93	79762.07	17.63	8.28	0.72	190.85	14.36
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	1.86	35.63	13.65	10.53	1.03	81886.83	20.07	8.71	0.79	195.26	14.86
最大值	3.65	46.23	15.43	10.86	1.13	84040.97	22.13	10.08	0.87	198.30	15.24
發生日期											
最小值	1.17	30.68	11.38	10.12	0.91	78402.33	17.63	7.83	0.70	189.78	14.32
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管