

連續自動監測紀錄月報表

中華民國109年9月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	3.40	69.40	8.46	9.90	1.63	79320.22	18.03	9.14	0.68	177.00	12.73
02	3.65	68.45	8.51	9.62	1.74	81904.36	18.30	15.00	0.72	178.41	12.89
03	3.19	68.60	6.41	9.61	2.00	82947.21	18.39	15.04	0.83	180.07	13.15
04	3.82	68.87	8.40	9.61	2.25	82661.81	18.27	14.70	0.94	179.51	13.03
05	3.76	69.29	6.58	9.67	2.29	81753.40	17.88	12.93	0.95	178.25	12.86
06	4.01	69.70	5.02	9.73	2.32	82078.70	17.72	13.89	0.97	178.32	12.95
07	3.48	68.83	6.68	9.50	2.32	83779.47	17.89	15.22	0.97	179.18	13.00
08	3.74	68.59	5.46	9.73	2.34	81729.41	17.78	14.15	0.97	179.34	12.93
09	3.83	69.36	6.37	9.62	2.29	81950.50	18.00	14.54	0.95	178.09	12.84
10	4.06	65.83	8.00	9.38	2.25	82895.82	18.81	16.37	0.94	177.79	12.83
11	3.97	66.95	7.82	9.51	2.23	82111.63	18.65	13.13	0.93	178.72	12.87
12	3.38	68.16	9.39	9.51	2.22	82324.42	18.55	14.01	0.93	177.25	12.83
13	3.57	67.56	6.22	9.49	2.20	82697.95	18.92	13.45	0.92	178.48	12.97
14	3.13	66.63	8.18	9.58	2.20	81794.84	18.37	12.01	0.91	176.92	12.79
15	3.62	67.74	7.47	9.63	2.19	81735.08	18.46	8.25	0.91	178.17	12.89
16	3.69	66.94	8.06	9.51	2.18	81393.64	18.46	6.82	0.91	176.39	12.66
17	3.49	66.39	7.43	9.50	2.20	80835.57	18.77	12.30	0.92	176.85	12.62
18	3.74	66.73	8.84	9.59	2.19	81998.40	18.76	12.21	0.91	178.84	12.96
19	3.72	68.09	8.14	9.54	2.17	81791.77	18.52	13.65	0.90	177.71	12.80
20	3.85	67.93	6.48	9.67	2.10	81699.62	18.18	12.31	0.88	178.01	12.89
21	3.83	66.84	6.75	9.73	2.12	81973.60	18.10	12.36	0.88	178.14	12.98
22	4.04	65.14	5.75	9.81	2.18	82798.31	17.97	14.16	0.91	179.55	13.23
23	4.45	61.46	7.36	9.84	2.21	81850.07	17.55	15.37	0.92	177.33	12.98
24	4.01	59.52	6.71	9.75	2.23	81599.98	18.14	13.96	0.93	177.26	12.93
25	4.16	65.74	6.50	9.76	2.21	81223.15	18.21	14.93	0.92	176.70	12.89
26	3.82	69.83	7.35	9.68	2.24	81413.50	18.04	16.15	0.93	175.46	12.75
27	4.00	69.24	6.13	9.72	2.21	82188.48	18.22	15.86	0.92	176.52	12.99
28	3.80	68.96	7.75	9.65	2.22	82508.06	18.28	13.75	0.92	176.50	12.96
29	3.96	68.28	5.43	9.73	2.20	81934.87	18.20	13.72	0.92	177.38	12.98
30	4.73	69.56	5.60	9.88	2.13	81649.39	17.50	15.19	0.89	176.03	12.96
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.80	67.49	7.11	9.65	2.18	81951.44	18.23	13.49	0.91	177.81	12.90
最大值	4.73	69.83	9.39	9.90	2.34	83779.47	18.92	16.37	0.97	180.07	13.23
發生日期											
最小值	3.13	59.52	5.02	9.38	1.63	79320.22	17.50	6.82	0.68	175.46	12.62
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國109年9月30日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	4.20	67.77	10.99	10.14	2.40	74446.85	18.52	14.14	1.00	175.63	12.24
02	3.79	69.18	10.91	10.19	2.40	76577.79	18.22	16.04	1.00	183.16	12.81
03	3.45	69.31	9.89	9.99	2.38	78041.60	18.52	15.72	0.99	182.15	12.85
04	3.59	68.63	10.76	10.01	2.35	78335.74	18.27	15.77	0.98	182.49	12.88
05	3.49	66.86	9.40	10.03	2.31	78979.76	18.04	15.02	0.96	189.24	13.17
06	3.38	69.02	11.16	9.90	2.31	78847.16	18.41	15.69	0.96	186.23	12.96
07	3.27	68.51	10.77	9.66	2.32	79345.92	18.38	16.26	0.97	180.25	12.59
08	3.58	69.44	9.55	9.89	2.33	76815.00	18.60	15.09	0.97	179.66	12.47
09	3.77	68.79	10.50	9.91	2.43	77037.52	18.20	16.30	1.01	179.18	12.45
10	3.76	67.56	10.01	9.74	2.45	77776.30	18.65	16.22	1.02	178.83	12.45
11	4.64	66.94	9.74	9.73	2.33	77968.27	18.63	16.40	0.97	178.46	12.41
12	4.57	68.56	9.98	9.72	2.32	77665.88	18.67	12.87	0.97	178.45	12.39
13	3.16	66.43	10.48	9.65	2.35	78655.85	19.21	7.15	0.98	183.03	12.69
14	2.78	67.84	10.20	9.84	2.37	77637.18	19.02	7.44	0.99	180.88	12.64
15	3.33	69.53	9.92	9.93	2.26	77473.63	18.87	11.33	0.94	181.04	12.70
16	3.92	69.29	10.02	9.97	2.18	76662.23	18.46	12.94	0.91	179.29	12.50
17	3.74	68.82	9.65	9.80	2.31	77835.18	18.90	14.43	0.96	179.60	12.58
18	3.93	69.73	10.92	10.35	2.39	77158.24	17.72	14.34	1.00	183.22	13.03
19	3.66	70.43	9.75	10.48	2.36	76681.37	17.43	13.51	0.98	183.04	13.06
20	3.67	69.87	8.96	10.22	2.34	79077.00	18.09	14.19	0.98	184.47	13.28
21	3.81	69.85	9.74	10.20	2.33	78992.47	17.79	14.03	0.97	184.43	13.19
22	3.75	69.45	10.40	10.16	2.30	78431.48	18.11	15.29	0.96	183.38	13.07
23	3.97	67.18	10.51	10.18	2.30	77730.59	17.80	15.76	0.96	181.73	12.88
24	3.74	68.19	12.06	10.32	2.31	77296.55	17.78	15.25	0.96	181.72	12.98
25	3.90	69.95	8.49	10.48	2.37	77768.91	17.96	15.70	0.99	183.77	13.34
26	3.84	69.09	9.07	10.42	2.38	77761.28	17.66	16.33	0.99	182.83	13.19
27	3.99	69.47	7.93	10.49	2.35	78004.82	17.77	16.53	0.98	183.48	13.36
28	3.84	69.38	10.03	10.23	2.42	79220.16	18.00	15.48	1.01	183.53	13.27
29	4.13	69.45	9.25	10.60	2.54	79234.75	17.68	15.94	1.06	186.31	13.78
30	4.69	70.50	10.73	10.62	2.49	79355.61	17.27	17.28	1.04	185.23	13.73
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.78	68.83	10.06	10.10	2.36	77893.84	18.22	14.61	0.98	182.16	12.90
最大值	4.69	70.50	12.06	10.62	2.54	79355.61	19.21	17.28	1.06	189.24	13.78
發生日期											
最小值	2.78	66.43	7.93	9.65	2.18	74446.85	17.27	7.15	0.91	175.63	12.24
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管