

連續自動監測紀錄月報表

中華民國106年05月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	5.52	88.08	15.22	15.84	2.59	46099.78	22.09	6.13	1.30	119.71	10.1
02	5.78	86.17	14.41	15.85	2.90	46737.91	22.72	5.36	1.45	121.04	10.29
03	5.60	77.55	15.50	15.95	2.97	45564.00	22.42	5.30	1.49	121.24	10.25
04	5.65	77.66	13.91	16.04	2.94	44604.12	22.17	5.36	1.47	121.61	10.21
05	5.98	85.57	14.14	15.90	3.28	45359.68	22.80	5.33	1.64	121.65	10.1
06	6.41	90.75	15.45	15.43	3.35	49902.61	23.47	4.98	1.68	120.54	10.14
07	6.99	96.41	16.77	15.09	3.15	54172.55	24.20	5.60	1.57	120.99	10.38
08	7.44	93.75	17.80	15.25	3.36	53539.32	23.96	6.80	1.68	122.44	10.61
09	6.75	83.30	20.23	14.59	3.78	60160.09	25.47	6.61	1.89	122.76	10.69
10	8.05	82.94	24.99	14.77	3.44	58147.95	24.69	7.44	1.72	123.73	10.67
11	8.08	87.59	27.29	14.73	3.48	58358.99	24.48	8.16	1.74	123.60	10.62
12	7.48	78.68	28.32	14.43	3.77	61604.81	25.30	7.50	1.89	123.17	10.7
13	6.78	80.40	25.36	14.64	4.32	59999.66	25.31	7.49	2.16	122.60	10.75
14	7.40	78.82	22.16	14.52	4.17	60775.44	25.37	7.38	2.08	122.88	10.7
15	7.09	80.51	24.58	14.58	4.22	60108.61	25.11	7.12	2.11	122.40	10.68
16	6.81	84.09	21.45	14.68	4.21	59428.08	25.09	7.04	2.10	120.59	10.67
17	6.94	83.58	22.99	14.92	3.58	56701.49	25.19	6.24	1.79	120.89	10.58
18	7.89	88.23	26.09	14.77	3.20	58921.85	24.42	8.81	1.60	122.22	10.76
19	7.86	94.62	19.51	14.89	3.38	57437.41	24.81	12.24	1.69	122.50	10.71
20	7.50	90.58	18.48	15.20	3.54	54773.56	24.33	12.30	1.77	121.71	10.73
21	7.35	83.27	20.50	14.88	3.72	57724.22	25.03	11.69	1.86	121.96	10.72
22	8.03	90.58	19.49	15.02	3.69	56238.09	24.82	11.98	1.84	122.77	10.73
23	8.65	91.09	21.60	14.99	3.95	56600.14	25.23	12.67	1.98	123.31	10.74
24	8.19	85.50	22.20	14.80	4.09	58503.28	25.56	12.61	2.04	123.25	10.78
25	7.52	85.83	22.07	14.67	3.78	59733.62	25.17	12.52	1.89	121.21	10.71
26	7.56	81.60	23.89	14.74	4.22	59388.20	25.38	12.30	2.11	120.61	10.76
27	7.84	87.24	20.35	14.87	4.29	58507.68	24.83	12.03	2.14	121.01	10.83
28	7.50	81.20	23.66	14.65	4.36	60352.94	25.42	11.29	2.18	121.74	10.8
29	7.80	80.67	22.27	14.71	4.49	59597.71	25.27	11.38	2.24	122.15	10.79
30	7.55	78.47	21.73	14.68	4.74	59325.90	26.07	11.58	2.37	122.54	10.7
31	7.71	77.08	24.11	14.75	5.91	59401.06	26.09	11.89	2.95	122.11	10.8
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	7.22	84.90	20.86	14.99	3.77	56057.12	24.59	8.88	1.88	121.97	10.60
最大值	8.65	96.41	28.32	16.04	5.91	61604.81	26.09	12.67	2.95	123.73	10.83
發生日期	23	7	12	4	31	12	31	23	31	10	27
最小值	5.52	77.08	13.91	14.43	2.59	44604.12	22.09	4.98	1.30	119.71	10.10
發生日期	1	31	4	12	1	4	1	6	1	1	1
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國106年05月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	7.91	86.22	10.72	15.51	2.77	53269.40	24.26	4.34	1.39	127.91	10.95
02	7.74	86.08	10.82	15.50	2.77	54210.15	23.35	4.10	1.39	128.52	11.16
03	7.08	77.78	15.61	15.67	2.78	55083.22	23.43	4.54	1.39	129.08	11.71
04	7.31	75.08	15.56	15.67	2.76	53180.12	24.20	4.88	1.38	129.01	11.31
05	7.36	87.30	9.87	15.50	2.76	53532.02	22.88	4.80	1.38	129.08	11.02
06	7.80	88.45	8.90	14.90	2.77	57959.39	21.64	5.66	1.38	128.53	10.78
07	8.32	90.46	8.73	14.70	2.76	62756.57	21.14	6.24	1.38	128.56	11.27
08	8.29	84.34	9.10	14.56	2.75	64400.69	21.01	4.39	1.37	129.24	11.33
09	7.85	78.30	13.47	14.14	2.74	71217.93	18.96	4.18	1.37	129.58	11.78
10	8.23	70.31	16.20	14.15	2.74	68589.13	20.60	6.06	1.37	130.26	11.39
11	8.15	80.67	13.04	14.25	2.74	69321.14	20.55	5.68	1.37	130.30	11.67
12	7.75	73.82	20.99	14.17	2.73	69715.04	19.62	4.44	1.37	129.82	11.59
13	7.73	74.84	15.19	14.08	2.74	70823.95	18.64	3.76	1.37	129.42	11.62
14	7.87	68.13	13.30	13.98	2.76	71982.12	19.08	4.17	1.38	129.65	11.64
15	7.75	76.23	10.46	14.19	2.73	68694.41	19.66	4.02	1.36	129.44	11.46
16	8.37	79.35	11.11	14.14	2.74	71283.93	19.30	3.15	1.37	128.18	11.76
17	8.38	75.70	12.42	14.28	2.78	70481.00	20.03	13.79	1.39	128.38	11.87
18	8.15	74.23	11.14	14.28	2.76	68916.68	20.82	13.70	1.38	129.15	11.62
19	8.74	76.01	16.44	14.58	2.75	69447.73	21.00	9.17	1.38	129.62	12.28
20	8.50	83.15	14.06	14.75	2.75	66792.20	20.99	7.95	1.38	129.10	12.13
21	7.84	74.45	12.77	14.36	2.73	68581.24	19.88	7.88	1.37	129.07	11.71
22	8.07	78.87	11.87	14.48	2.71	67232.76	20.35	7.77	1.36	129.48	11.7
23	8.20	80.46	11.89	14.40	2.73	67660.64	19.76	7.37	1.37	129.73	11.63
24	8.34	78.64	13.51	14.41	2.75	68504.68	19.50	7.93	1.37	129.88	11.82
25	8.23	74.61	13.15	14.20	2.77	71851.94	19.68	5.17	1.38	128.48	11.97
26	8.45	73.57	14.10	14.21	2.79	72095.17	19.51	6.68	1.40	128.43	12.02
27	8.43	76.51	12.07	14.29	2.78	70572.84	20.10	9.89	1.39	128.56	11.91
28	7.81	75.89	11.51	14.19	2.79	72242.13	19.42	9.67	1.39	128.88	12.02
29	7.64	77.81	10.11	14.21	2.78	71903.78	19.28	9.26	1.39	129.39	12.02
30	7.54	73.96	14.17	14.08	2.78	72022.55	18.11	6.12	1.39	129.34	11.8
31	7.98	71.10	16.25	14.06	2.78	73070.61	17.75	7.03	1.39	129.57	11.95
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	7.99	78.14	12.86	14.51	2.76	66690.17	20.47	6.57	1.38	129.15	11.64
最大值	8.74	90.46	20.99	15.67	2.79	73070.61	24.26	13.79	1.40	130.30	12.28
發生日期	19	7	12	3	26	31	1	17	26	11	19
最小值	7.08	68.13	8.73	13.98	2.71	53180.12	17.75	3.15	1.36	127.91	10.78
發生日期	3	14	7	14	22	4	31	16	15	1	6
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管