

連續自動監測紀錄月報表

中華民國114年02月28日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.74	50.20	5.82	11.61	1.25	73854.33	17.97	9.55	0.96	188.02	14.33
02	3.61	45.80	6.68	11.76	1.26	73998.17	18.36	8.72	0.97	189.52	14.70
03	4.16	47.58	6.50	11.68	1.26	75043.39	17.87	8.89	0.98	188.48	14.69
04	3.53	44.03	5.95	11.61	1.26	77090.77	17.98	8.66	0.98	190.49	15.03
05	3.57	45.11	5.14	11.61	1.26	76212.59	17.90	9.23	0.97	190.57	14.86
06	3.58	50.44	5.01	11.59	1.28	75836.94	18.18	8.75	0.99	189.58	14.76
07	3.86	54.27	5.51	11.54	1.31	77463.85	17.80	8.70	1.01	189.82	14.95
08	3.71	48.23	5.13	11.48	1.31	77306.18	18.12	8.86	1.00	187.36	14.80
09	3.51	44.15	6.03	11.38	1.32	75721.23	18.91	8.75	1.01	186.00	14.43
10	2.53	43.59	5.84	11.38	1.31	74775.34	18.24	8.50	1.01	185.65	14.14
11	1.18	47.24	6.00	11.40	1.31	74953.38	18.31	7.92	1.01	187.68	14.28
12	1.46	46.09	8.05	11.37	1.33	75529.13	18.19	8.68	1.03	187.40	14.31
13	1.88	47.31	5.53	11.66	1.33	73339.08	17.30	9.12	1.02	184.18	14.08
14	1.64	45.05	5.96	12.06	1.37	71612.77	17.28	8.39	1.06	187.63	14.46
15	1.91	41.59	6.25	12.46	1.37	68607.26	16.68	8.39	1.06	187.39	14.39
16	1.90	39.60	5.55	11.94	1.35	72259.07	17.46	8.80	1.04	186.46	14.39
17	1.65	37.12	8.35	11.51	1.34	75586.73	17.41	8.56	1.03	185.07	14.32
18	1.38	42.87	7.10	11.79	1.34	74976.59	17.21	9.04	1.03	186.18	14.64
19	1.25	43.63	7.83	11.79	1.32	75192.19	17.00	8.85	1.01	185.97	14.63
20	0.59	40.16	7.21	11.54	1.33	75505.25	17.88	8.51	1.02	186.62	14.49
21	0.68	44.36	6.19	11.66	1.32	75663.14	17.90	9.15	1.02	186.64	14.70
22	0.32	40.70	8.23	11.63	1.32	75238.96	18.06	9.21	1.01	184.81	14.54
23	0.30	39.65	6.63	11.60	1.31	75446.59	18.45	8.96	1.01	185.93	14.63
24	0.55	43.57	6.34	11.56	1.30	76275.01	18.36	8.85	1.00	185.26	14.71
25	0.43	53.97	6.97	11.59	1.30	74836.16	19.36	8.29	1.00	185.94	14.67
26	0.61	53.53	7.05	11.53	1.32	74950.36	19.19	8.86	1.01	185.62	14.55
27	1.01	54.36	7.26	11.66	1.28	73907.58	18.65	8.84	0.98	184.21	14.41
28	1.05	53.07	10.77	11.78	1.27	74781.87	18.56	8.99	0.98	186.34	14.83
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	1.99	45.97	6.60	11.65	1.31	74855.85	18.02	8.79	1.01	186.96	14.56
最大值	4.16	54.36	10.77	12.46	1.37	77463.85	19.36	9.55	1.06	190.57	15.03
發生日期											
最小值	0.30	37.12	5.01	11.37	1.25	68607.26	16.68	7.92	0.96	184.18	14.08
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國114年02月28日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	1.78	42.40	14.02	10.92	0.96	79950.12	18.60	9.40	0.74	195.76	14.82
02	1.65	36.44	12.49	10.90	0.97	81089.75	19.19	7.99	0.75	197.96	15.18
03	2.13	44.28	11.15	11.00	1.00	81340.34	18.41	8.14	0.77	196.94	15.20
04	1.75	45.20	11.18	10.98	0.96	82442.52	18.65	7.46	0.74	199.18	15.49
05	1.96	46.17	11.73	10.99	0.89	82006.96	18.36	8.04	0.68	197.67	15.31
06	2.06	43.31	12.15	10.91	0.87	81138.75	18.58	8.17	0.66	195.64	15.00
07	2.19	42.12	12.92	10.92	0.90	81652.89	18.39	8.19	0.69	196.29	15.10
08	1.67	42.01	11.43	10.82	0.96	83376.56	18.62	8.30	0.74	196.50	15.32
09	1.77	36.58	11.32	10.90	1.02	83191.20	19.00	8.17	0.78	198.85	15.56
10	2.29	38.81	12.72	10.94	1.04	80052.03	18.53	7.96	0.80	194.58	14.80
11	2.71	42.12	11.44	11.10	1.07	78604.39	18.37	7.87	0.82	195.07	14.76
12	3.22	45.96	12.97	11.09	1.09	78199.83	18.25	8.42	0.84	193.61	14.61
13	2.68	42.24	12.65	11.02	1.12	79183.69	18.15	8.63	0.86	192.78	14.63
14	2.71	35.41	13.00	11.13	1.11	78626.69	18.75	8.35	0.85	193.50	14.83
15	2.51	35.76	11.68	11.11	1.07	78351.47	18.68	7.98	0.82	193.29	14.73
16	2.63	37.26	13.76	11.10	1.07	79000.72	18.77	8.21	0.82	193.73	14.86
17	2.87	37.79	14.80	11.10	1.05	79522.53	17.70	8.15	0.81	193.66	14.77
18	2.69	36.28	13.42	11.18	1.05	79527.24	18.00	8.28	0.80	193.73	14.95
19	2.81	34.23	13.17	11.33	1.06	78058.26	17.35	8.05	0.82	192.11	14.73
20	2.53	36.65	12.70	11.27	1.08	78382.67	17.92	7.85	0.83	193.32	14.85
21	3.19	35.90	11.66	11.48	0.99	78342.51	17.44	8.08	0.77	194.51	15.11
22	3.00	39.81	11.70	11.38	0.93	78965.22	17.46	8.61	0.72	192.68	15.04
23	2.82	41.07	12.52	11.20	0.97	80673.55	18.18	8.39	0.75	194.72	15.25
24	2.77	37.84	13.74	11.33	0.99	80221.12	17.76	8.62	0.76	193.87	15.27
25	2.35	34.69	13.37	11.49	1.01	78374.98	17.98	8.22	0.77	195.10	15.25
26	2.66	33.25	13.18	11.58	1.01	77786.60	17.59	8.09	0.78	194.99	15.21
27	3.00	33.72	12.70	11.61	1.03	77456.84	17.31	8.04	0.79	193.83	15.10
28	3.38	33.35	11.84	11.74	1.04	76852.00	17.24	8.41	0.80	195.15	15.22
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	2.49	38.95	12.55	11.16	1.01	79727.55	18.19	8.22	0.78	194.97	15.03
最大值	3.38	46.17	14.80	11.74	1.12	83376.56	19.19	9.40	0.86	199.18	15.56
發生日期											
最小值	1.65	33.25	11.15	10.82	0.87	76852.00	17.24	7.46	0.66	192.11	14.61
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管