

連續自動監測紀錄月報表

中華民國111年12月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	2.45	42.51	7.19	10.19	1.42	80148.26	17.51	11.71	0.95	183.21	13.30
02	2.41	41.72	7.26	10.08	1.36	79558.44	17.97	12.01	0.91	182.06	13.10
03	2.61	41.90	7.55	10.05	1.43	79063.44	17.84	11.79	0.96	182.08	12.98
04	2.85	40.61	6.67	9.91	1.44	79882.66	18.50	14.02	0.96	183.14	13.07
05	2.72	41.03	5.92	10.04	1.44	79367.06	17.87	11.67	0.96	182.29	13.02
06	2.77	41.89	8.35	10.19	1.55	80326.53	18.07	10.71	1.04	183.82	13.43
07	2.85	40.25	8.15	10.12	1.74	79861.67	18.13	11.59	1.16	183.65	13.27
08	2.49	39.15	6.02	9.93	1.70	79986.49	18.43	11.95	1.13	182.90	13.09
09	2.40	37.43	7.33	10.04	1.66	80274.11	18.46	11.69	1.10	183.79	13.30
10	2.61	37.00	6.80	10.07	1.65	79823.66	18.16	11.52	1.10	183.13	13.20
11	2.76	39.61	7.19	9.96	1.66	80051.32	18.17	12.03	1.10	181.33	13.05
12	2.44	40.27	7.65	10.05	1.70	79625.77	18.14	11.68	1.13	182.17	13.11
13	2.69	41.41	7.22	10.13	1.78	80592.10	17.79	11.53	1.18	183.01	13.34
14	2.91	43.74	7.27	10.11	1.79	80964.38	17.87	12.26	1.19	182.93	13.39
15	2.60	44.22	6.44	10.05	1.86	80290.44	17.89	12.11	1.24	182.34	13.20
16	2.48	46.10	5.28	10.08	1.83	79401.19	18.45	12.12	1.22	183.75	13.20
17	2.63	47.35	6.42	10.11	1.75	81216.33	17.73	11.94	1.17	182.52	13.39
18	2.68	48.04	7.03	10.40	1.86	80700.97	17.25	11.75	1.24	183.01	13.56
19	2.45	48.76	7.11	10.41	1.95	78967.31	17.53	11.90	1.30	183.49	13.38
20	2.28	48.46	7.90	10.43	1.97	78479.27	17.48	10.90	1.31	183.99	13.34
21	2.79	44.99	8.84	10.39	1.89	78888.38	17.36	11.32	1.26	182.76	13.33
22	3.11	48.72	7.04	10.63	1.93	78986.48	16.39	11.91	1.29	183.15	13.48
23	3.12	49.33	7.54	10.84	1.97	78181.65	16.18	11.57	1.32	182.85	13.57
24	2.78	47.15	6.74	10.70	1.98	79275.43	17.30	11.79	1.33	183.06	13.78
25	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐
26	4.52	50.29	7.93	10.87	2.13	74861.08	15.23	11.41	1.42	181.72	12.86
27	4.07	52.50	7.34	10.67	2.05	77175.79	16.02	11.57	1.37	177.47	12.99
28	3.82	53.01	8.41	10.73	2.06	76546.94	16.15	12.23	1.38	178.27	13.01
29	3.45	52.55	5.32	10.49	2.03	77427.60	16.62	12.12	1.36	178.28	12.93
30	3.73	52.47	7.82	10.53	2.01	77240.42	16.45	13.10	1.34	178.49	12.94
31	3.38	54.79	7.25	10.80	1.93	76038.48	15.91	11.98	1.29	178.31	12.99
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	2.90	45.24	7.17	10.30	1.78	79106.79	17.43	11.86	1.19	182.10	13.22
最大值	4.52	54.79	8.84	10.87	2.13	81216.33	18.50	14.02	1.42	183.99	13.78
發生日期											
最小值	2.28	37.00	5.28	9.91	1.36	74861.08	15.23	10.71	0.91	177.47	12.86
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國111年12月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.37	52.28	8.41	10.79	1.82	80740.26	17.08	11.92	1.21	192.50	14.39
02	3.01	53.73	6.74	10.88	1.82	79325.32	17.56	11.90	1.21	192.45	14.35
03	3.08	52.02	5.66	10.87	1.83	79117.95	17.61	11.50	1.22	193.43	14.35
04	3.74	52.75	5.89	10.55	1.83	80023.77	18.31	11.90	1.22	192.84	14.18
05	3.22	52.68	5.12	10.78	1.83	79521.21	17.58	11.40	1.22	192.32	14.24
06	3.07	55.59	8.66	11.13	1.75	79269.71	17.39	11.36	1.16	194.66	14.76
07	3.43	51.61	5.87	10.97	1.64	79105.41	17.50	11.78	1.09	193.59	14.46
08	3.05	55.59	7.61	10.80	1.66	79738.30	18.18	11.40	1.11	193.59	14.45
09	2.84	53.77	6.86	10.94	1.63	79266.56	18.08	11.63	1.09	194.50	14.59
10	3.17	51.14	6.57	10.86	1.61	79105.45	18.01	11.65	1.07	193.36	14.39
11	3.25	53.00	6.70	10.90	1.67	79480.71	17.70	11.64	1.11	192.48	14.43
12	2.98	55.55	8.06	10.83	1.72	79806.45	17.94	11.43	1.15	193.33	14.46
13	3.30	55.19	6.47	11.00	1.72	79793.67	17.56	11.26	1.15	194.18	14.67
14	3.56	53.61	6.20	10.91	1.69	79938.95	17.62	11.67	1.13	193.07	14.53
15	3.26	52.75	7.93	10.82	1.71	8452.79	17.81	12.29	1.14	193.25	14.54
16	3.03	52.58	5.90	10.88	1.70	79250.86	18.17	11.69	1.14	193.88	14.49
17	2.79	55.21	6.93	10.95	1.64	80805.96	17.46	11.20	1.10	195.71	14.82
18	2.88	56.59	5.40	10.95	1.65	81562.41	17.23	11.89	1.10	194.02	14.84
19	2.79	52.94	6.77	11.01	1.70	80435.90	17.30	11.56	1.13	195.02	14.78
20	2.85	55.78	6.48	11.22	1.69	78061.13	17.08	11.34	1.13	194.95	14.62
21	3.26	55.44	8.24	11.17	1.65	79185.87	17.04	11.45	1.10	194.84	14.75
22	3.59	56.65	7.80	11.25	1.67	79909.53	16.19	12.06	1.12	194.52	14.82
23	3.47	56.09	8.40	11.43	1.66	78537.46	15.98	11.31	1.11	193.62	14.77
24	3.43	55.29	9.19	11.40	1.70	79293.58	15.69	11.54	1.13	191.39	14.76
25	3.44	51.26	6.06	11.17	1.71	79254.58	15.38	11.54	1.15	189.15	14.29
26	2.86	50.71	7.20	11.09	1.69	79360.33	16.19	11.38	1.13	197.50	14.59
27	3.80	57.71	5.80	11.47	1.68	78501.24	15.95	11.45	1.12	196.86	14.94
28	3.69	54.86	7.13	11.41	1.72	78202.50	16.26	12.39	1.15	195.13	14.78
29	3.40	53.69	6.20	11.23	1.75	78276.48	16.88	11.62	1.17	194.34	14.60
30	3.42	55.58	7.00	11.34	1.75	78686.11	16.84	12.27	1.17	196.17	14.91
31	3.48	54.90	8.41	11.43	1.71	78182.99	16.35	11.80	1.14	195.01	14.82
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.24	54.08	6.96	11.05	1.71	77103.01	17.16	11.65	1.14	193.92	14.59
最大值	3.80	57.71	9.19	11.47	1.83	81562.41	18.31	12.39	1.22	197.50	14.94
發生日期											
最小值	2.79	50.71	5.12	10.55	1.61	8452.79	15.38	11.20	1.07	189.15	14.18
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管