

連續自動監測紀錄月報表

中華民國108年3月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	9.01	84.68	6.64	10.47	1.72	79482.07	18.44	9.91	0.72	149.37	12.67
02	9.29	81.43	7.51	10.33	1.75	79658.99	18.72	9.39	0.73	149.46	12.58
03	9.63	79.60	6.26	10.33	1.70	79575.98	18.48	10.58	0.71	148.84	12.52
04	8.45	76.99	7.64	10.16	1.75	80392.43	18.57	7.65	0.73	148.43	12.44
05	8.82	77.95	4.96	10.20	1.80	80432.63	19.01	9.37	0.75	149.09	12.58
06	9.48	81.18	5.36	10.27	1.80	80388.59	18.95	9.24	0.75	148.91	12.64
07	8.47	84.65	4.72	10.19	1.76	81526.18	18.79	7.69	0.74	148.11	12.68
08	8.20	90.04	3.98	10.35	1.83	81276.29	19.05	8.02	0.76	148.70	12.89
09	7.71	90.68	4.36	10.40	1.89	79892.96	19.18	7.54	0.78	149.34	12.76
10	7.95	86.72	5.38	10.22	1.80	80898.86	19.36	7.06	0.75	149.08	12.73
11	8.05	83.10	7.86	10.25	1.77	79958.82	18.96	7.24	0.74	148.54	12.55
12	8.59	86.89	3.01	10.28	1.78	81139.53	18.79	9.96	0.74	149.60	12.77
13	8.60	81.54	3.94	9.95	1.77	81789.99	19.75	10.08	0.74	149.67	12.63
14	9.68	83.31	10.60	10.20	1.75	80048.71	18.92	10.77	0.73	148.83	12.50
15	8.96	84.10	8.89	10.13	1.65	82004.16	18.78	11.68	0.69	151.22	12.77
16	9.39	80.04	11.57	10.03	1.59	83539.38	18.16	11.02	0.66	151.56	12.79
17	8.61	74.05	11.56	9.85	1.60	81883.84	19.39	10.34	0.67	151.32	12.54
18	8.38	64.62	13.36	9.66	1.60	77816.88	19.90	7.23	0.67	148.12	11.69
19	7.97	64.76	7.21	9.68	1.65	77796.14	19.81	7.27	0.69	147.99	11.69
20	9.48	67.57	16.00	9.62	1.74	79158.27	20.06	9.31	0.72	148.78	11.89
21	8.93	65.22	11.01	9.52	1.75	79221.34	20.53	8.11	0.73	149.37	11.89
22	9.47	69.81	8.63	9.77	1.75	79145.19	19.84	8.90	0.73	148.48	12.01
23	9.51	74.04	13.60	9.86	1.75	79044.47	19.00	10.56	0.73	147.28	11.94
24	9.27	74.67	7.42	9.92	1.77	80792.19	19.04	8.60	0.74	147.87	12.28
25	8.35	75.41	7.97	9.90	1.82	79912.38	19.47	7.37	0.76	147.87	12.19
26	8.23	79.73	5.32	10.16	1.76	80720.06	19.33	6.66	0.73	149.10	12.63
27	9.31	83.21	3.98	10.01	1.77	80008.94	19.04	9.89	0.74	149.14	12.31
28	9.48	76.02	8.11	9.84	1.76	80181.00	19.67	9.52	0.73	149.46	12.25
29	9.14	76.09	8.57	9.92	1.67	80615.51	19.31	10.55	0.70	149.81	12.36
30	9.19	78.78	6.45	9.79	1.65	80392.95	19.12	11.11	0.69	149.33	12.14
31	8.61	73.51	5.22	9.65	1.56	82354.51	19.36	9.54	0.65	149.29	12.31
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	8.85	78.40	7.65	10.03	1.73	80356.43	19.19	9.10	0.72	149.10	12.41
最大值	9.68	90.68	16.00	10.47	1.89	83539.38	20.53	11.68	0.78	151.56	12.89
發生日期											
最小值	7.71	64.62	3.01	9.52	1.56	77796.14	18.16	6.66	0.65	147.28	11.69
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國108年3月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	17.22	67.92	17.19	15.14	3.41	63512.25	11.41	1.54	1.42	107.99	15.10
02	17.26	70.37	17.38	15.32	3.58	60964.60	11.43	1.26	1.49	108.55	14.99
03	17.29	69.95	22.65	15.26	3.51	61942.12	11.32	1.29	1.46	107.26	15.02
04	17.14	66.38	28.30	15.21	3.32	63141.49	10.83	1.43	1.38	106.30	15.04
05	16.79	69.29	22.82	15.24	3.38	62385.85	11.39	1.09	1.41	107.31	15.08
06	17.84	67.14	23.09	15.22	3.36	62681.92	11.44	1.02	1.40	106.41	15.05
07	16.23	64.73	25.41	15.07	3.40	64949.02	11.13	1.11	1.42	105.28	15.11
08	16.70	68.36	16.50	15.14	3.49	63958.34	11.49	0.82	1.45	106.31	15.15
09	17.43	69.12	26.22	15.28	3.46	61355.00	11.65	0.92	1.44	107.37	14.96
10	18.76	63.50	21.85	15.09	3.59	63320.48	11.82	0.67	1.50	106.15	14.93
11	18.59	72.08	14.93	15.19	3.41	62904.23	11.19	0.78	1.42	104.86	14.93
12	20.86	63.68	20.58	15.21	3.24	62789.07	11.23	0.71	1.35	104.47	14.96
13	23.12	61.83	25.83	15.11	3.22	64389.34	12.27	0.59	1.34	100.99	15.11
14	28.34	60.61	27.24	14.97	3.30	64760.95	13.44	0.64	1.37	98.53	14.95
15	18.97	76.46	12.04	15.47	3.28	61367.10	13.53	0.19	1.36	95.03	15.31
16	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機
17	19.56	60.98	17.68	15.43	2.99	63376.45	11.18	1.66	1.25	107.22	15.81
18	21.05	70.49	18.91	15.38	3.03	63857.92	11.21	1.23	1.26	106.64	15.75
19	20.47	75.51	16.97	15.43	3.05	62887.86	11.41	1.27	1.27	107.25	15.72
20	23.00	68.08	21.28	15.30	3.05	63208.35	11.93	1.69	1.27	108.32	15.57
21	22.75	67.38	22.07	15.16	3.09	64004.19	12.09	1.67	1.29	108.88	15.43
22	25.16	64.57	25.51	15.12	3.11	65396.18	12.02	0.94	1.30	107.10	15.57
23	20.81	65.01	24.82	15.15	3.04	66667.58	11.17	0.87	1.26	104.42	15.68
24	21.33	62.78	22.14	15.14	3.00	66808.82	11.20	0.84	1.25	104.58	15.72
25	21.59	63.09	19.98	15.13	3.11	66230.36	11.43	0.94	1.29	105.14	15.62
26	18.24	63.55	13.40	15.00	3.12	67722.81	11.56	0.86	1.30	107.19	15.73
27	19.03	67.43	16.89	15.00	3.14	66828.25	11.56	1.25	1.31	108.47	15.58
28	19.90	63.35	22.17	15.19	3.15	64225.04	11.54	1.89	1.31	109.31	15.49
29	21.34	62.08	21.08	15.08	3.21	65371.39	11.67	1.94	1.34	109.24	15.48
30	20.98	59.63	24.51	15.04	3.23	64031.27	11.38	2.13	1.34	108.06	14.98
31	17.40	57.52	19.97	14.90	3.24	65196.17	11.35	2.01	1.35	107.76	14.88
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	19.84	66.10	20.98	15.18	3.25	64007.81	11.61	1.18	1.35	106.08	15.29
最大值	28.34	76.46	28.30	15.47	3.59	67722.81	13.53	2.13	1.50	109.31	15.81
發生日期											
最小值	16.23	57.52	12.04	14.90	2.99	60964.60	10.83	0.19	1.25	95.03	14.88
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管