

連續自動監測紀錄月報表

中華民國110年11月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.04	60.97	7.27	9.31	1.65	83024.19	18.28	12.25	1.10	177.53	12.70
02	2.66	63.99	6.89	9.46	1.70	82539.43	18.39	11.90	1.13	178.93	12.84
03	4.82	62.01	7.40	9.62	1.73	82577.79	17.53	13.25	1.15	176.03	12.81
04	3.00	61.09	7.68	9.35	1.72	83475.30	18.20	11.94	1.15	178.84	12.84
05	3.16	66.32	8.08	9.43	1.73	82898.41	18.15	12.01	1.15	178.82	12.83
06	3.12	66.25	10.91	9.39	1.68	83788.79	17.96	12.24	1.12	178.82	12.89
07	3.40	63.74	9.67	9.36	1.64	83146.13	18.32	11.74	1.09	178.16	12.80
08	3.54	64.31	7.40	9.36	1.53	84426.08	18.03	11.90	1.02	178.16	12.94
09	3.25	66.52	6.74	9.48	1.56	83154.16	17.50	12.09	1.04	177.67	12.78
10	3.72	66.89	8.78	9.61	1.61	84348.85	16.97	12.38	1.07	178.13	13.03
11	3.64	66.62	7.15	9.61	1.65	84017.72	16.69	12.01	1.10	178.20	12.96
12	3.40	65.17	7.57	9.62	1.68	85575.20	17.32	11.69	1.12	179.39	13.34
13	3.30	65.34	8.39	9.77	1.69	83771.81	17.63	11.83	1.13	179.39	13.28
14	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐
15	4.41	60.02	11.23	9.78	1.64	84380.57	16.32	12.13	1.10	176.70	13.14
16	4.27	60.62	11.50	9.35	1.65	83271.26	17.52	11.89	1.10	173.25	12.55
17	4.30	64.11	10.94	9.45	1.65	82819.75	17.17	11.97	1.10	173.52	12.53
18	3.46	62.45	6.87	9.61	1.58	83311.72	16.96	11.60	1.05	175.39	12.80
19	3.19	62.40	7.59	9.82	1.57	83087.68	16.85	11.70	1.05	176.78	13.04
20	3.56	62.61	6.72	9.84	1.59	81313.05	16.43	11.92	1.06	174.34	12.65
21	3.32	61.91	6.45	9.77	1.62	81748.77	16.79	11.74	1.08	175.79	12.74
22	3.47	62.49	7.77	9.74	1.58	83286.29	16.50	11.65	1.05	175.55	12.89
23	3.23	65.54	7.78	10.04	1.56	84655.05	16.57	12.17	1.04	179.26	13.58
24	3.43	65.33	8.33	10.04	1.61	83515.34	16.14	11.47	1.07	178.41	13.30
25	3.01	64.47	8.54	9.94	1.67	82333.12	16.68	12.07	1.11	176.31	13.02
26	3.11	67.67	7.83	10.02	1.65	82691.77	16.93	12.33	1.10	178.93	13.29
27	2.92	66.62	8.09	10.00	1.63	82802.33	16.89	12.15	1.08	178.56	13.26
28	3.15	63.79	8.32	9.98	1.65	82603.62	16.81	11.72	1.10	178.36	13.19
29	2.92	66.81	8.37	9.92	1.65	82337.69	16.96	12.05	1.10	178.54	13.11
30	2.84	64.36	7.74	10.02	1.62	82748.72	16.94	11.97	1.08	179.41	13.31
監測日數	29	29	29	29	29	29	29	29	29	29	29
平均值	3.40	64.15	8.21	9.68	1.64	83229.33	17.22	11.99	1.09	177.49	12.98
最大值	4.82	67.67	11.50	10.04	1.73	85575.20	18.39	13.25	1.15	179.41	13.58
發生日期											
最小值	2.66	60.02	6.45	9.31	1.53	81313.05	16.14	11.47	1.02	173.25	12.53
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國110年11月30日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	5.25	63.39	9.89	10.29	1.69	81356.28	17.60	12.63	1.13	189.39	13.83
02	4.70	62.95	9.49	10.30	1.71	82810.87	17.81	12.17	1.14	192.24	14.22
03	5.20	60.25	10.62	10.42	1.68	82337.36	17.35	12.03	1.12	190.86	14.17
04	5.08	59.23	10.32	10.18	1.69	83235.20	17.77	12.41	1.12	191.98	14.11
05	4.70	62.60	10.97	10.39	1.70	82206.36	17.97	11.99	1.14	193.47	14.30
06	5.16	64.72	10.53	10.51	1.68	81922.36	17.59	12.32	1.12	193.18	14.33
07	5.67	63.15	10.84	10.38	1.65	80897.60	17.68	12.13	1.10	190.78	13.92
08	5.29	63.17	11.05	10.27	1.64	82931.12	17.48	12.28	1.09	190.11	14.07
09	4.99	64.78	10.10	10.30	1.61	83600.96	17.46	12.08	1.07	191.56	14.27
10	5.56	65.72	10.98	10.47	1.60	83463.26	16.55	12.13	1.07	191.78	14.32
11	5.83	64.40	10.90	10.39	1.56	83750.62	16.38	12.34	1.04	191.24	14.21
12	5.30	65.87	10.70	10.48	1.55	83101.31	16.70	11.63	1.03	191.69	14.31
13	5.21	65.58	10.18	10.43	1.58	83402.19	16.58	12.27	1.05	189.12	14.19
14	5.64	64.41	11.49	10.41	1.58	84092.41	16.44	11.70	1.05	189.06	14.24
15	4.74	64.29	10.54	10.31	1.55	83979.82	16.53	11.89	1.03	195.80	14.32
16	5.06	63.97	11.01	10.21	1.58	81616.12	17.59	11.53	1.05	191.01	13.81
17	5.49	63.28	10.88	10.40	1.62	80522.26	17.46	11.49	1.08	190.12	13.83
18	4.88	64.26	8.20	10.41	1.67	81763.01	17.25	12.03	1.12	190.65	14.03
19	5.29	65.93	9.70	10.56	1.78	81728.74	17.13	12.05	1.19	191.47	14.24
20	5.83	65.37	6.63	10.67	1.78	79938.87	16.66	12.17	1.18	189.52	13.94
21	5.44	64.84	7.94	10.57	1.71	80396.19	16.93	11.63	1.14	190.26	13.95
22	5.82	65.16	9.44	10.48	1.67	81426.59	16.65	12.03	1.11	188.99	13.92
23	5.39	67.82	10.75	10.64	1.67	82454.65	16.66	11.67	1.11	191.79	14.39
24	5.60	67.61	8.92	10.70	1.62	82354.50	16.24	11.65	1.08	192.28	14.41
25	4.78	67.44	10.01	10.55	1.64	81111.56	16.73	11.93	1.10	190.35	14.00
26	4.61	66.68	10.01	10.48	1.65	82659.64	17.46	12.07	1.10	192.96	14.39
27	5.01	67.25	10.42	10.54	1.61	82465.59	17.12	12.19	1.07	191.91	14.34
28	4.58	67.88	8.93	10.47	1.62	83189.47	17.46	11.92	1.08	193.61	14.48
29	4.63	67.19	10.16	10.37	1.63	83058.35	17.79	12.27	1.09	192.96	14.35
30	4.26	67.04	10.95	10.51	1.63	83112.22	17.81	11.73	1.09	194.59	14.61
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	5.17	64.87	10.09	10.44	1.65	82362.85	17.16	12.01	1.10	191.49	14.18
最大值	5.83	67.88	11.49	10.70	1.78	84092.41	17.97	12.63	1.19	195.80	14.61
發生日期											
最小值	4.26	59.23	6.63	10.18	1.55	79938.87	16.24	11.49	1.03	188.99	13.81
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管