

# 連續自動監測紀錄月報表

中華民國113年1月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	2.70	52.79	9.46	12.48	1.23	66024.88	18.16	8.97	0.95	181.50	13.95
02	2.35	52.76	10.45	12.46	1.24	67010.77	18.40	7.92	0.96	180.87	14.15
03	3.04	46.90	9.92	12.37	1.23	67572.40	17.78	9.11	0.95	181.24	14.04
04	2.15	45.55	10.97	11.50	1.24	74006.60	18.49	8.78	0.96	185.40	14.21
05	2.47	40.97	10.82	11.33	1.24	75171.22	18.10	9.24	0.96	184.89	14.09
06	2.46	40.82	10.27	11.02	1.25	76594.26	18.19	9.68	0.97	183.35	13.88
07	2.40	38.44	8.73	10.91	1.25	76846.20	18.32	9.39	0.97	183.51	13.80
08	1.93	38.31	9.15	10.63	1.22	77855.08	19.39	8.85	0.94	184.28	13.81
09	2.05	43.43	10.83	11.08	1.23	78168.17	19.01	9.37	0.95	181.98	14.38
10	2.41	46.46	9.86	11.14	1.19	78351.39	18.71	8.96	0.92	180.51	14.38
11	2.48	42.01	10.91	11.07	1.16	79236.94	18.21	9.07	0.89	178.60	14.30
12	2.53	43.90	10.72	10.85	1.21	77242.46	18.35	9.92	0.93	183.11	13.79
13	2.21	51.04	9.91	10.82	1.22	77191.64	18.52	9.47	0.94	183.10	13.76
14	1.78	48.77	9.72	10.67	1.25	77791.24	19.09	9.03	0.96	185.02	13.82
15	2.32	45.28	9.14	11.02	1.26	76104.74	18.08	9.45	0.97	183.94	13.80
16	2.01	44.61	9.57	11.19	1.24	75076.78	18.36	9.26	0.96	184.20	13.93
17	2.15	45.89	9.33	11.03	1.24	74956.44	18.47	9.54	0.96	183.63	13.65
18	2.07	46.53	9.05	11.04	1.25	74863.37	18.34	9.71	0.97	183.35	13.62
19	1.96	45.12	9.44	11.18	1.26	73323.98	18.36	9.05	0.98	182.09	13.51
20	1.96	42.88	9.13	10.65	1.26	79603.13	18.48	9.86	0.97	184.38	14.00
21	1.83	42.04	10.12	10.69	1.25	79233.35	18.27	9.23	0.97	186.80	14.02
22	2.32	43.26	8.38	10.82	1.24	77908.81	18.30	9.38	0.96	182.52	13.86
23	1.88	41.11	9.50	10.60	1.23	80657.37	18.75	9.19	0.95	183.10	14.12
24	2.06	40.05	8.70	10.78	1.24	79412.33	18.43	9.14	0.96	182.55	14.08
25	2.17	39.87	9.07	10.70	1.25	78842.24	18.76	9.46	0.97	181.85	13.91
26	2.18	41.27	10.10	10.91	1.24	77547.16	18.41	9.39	0.96	182.12	13.91
27	2.04	38.32	8.69	10.81	1.22	76783.69	18.65	9.57	0.94	181.23	13.64
28	2.21	36.89	8.07	10.64	1.20	77284.65	18.63	9.46	0.93	179.62	13.46
29	2.15	39.54	8.96	10.57	1.26	78140.52	19.04	9.55	0.97	182.67	13.67
30	2.10	43.67	8.00	10.65	1.27	76839.50	19.05	10.31	0.98	181.59	13.51
31	2.43	47.29	8.90	10.62	1.32	76169.97	19.23	10.65	1.02	181.61	13.40
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.22	43.73	9.54	11.04	1.24	76187.46	18.53	9.35	0.96	182.73	13.89
最大值	3.04	52.79	10.97	12.48	1.32	80657.37	19.39	10.65	1.02	186.80	14.38
發生日期											
最小值	1.78	36.89	8.00	10.57	1.16	66024.88	17.78	7.92	0.89	178.60	13.40
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國113年1月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	4.12	45.26	9.58	12.93	1.19	66207.16	18.63	8.99	0.92	191.66	15.19
02	4.29	46.01	9.96	13.09	1.23	64965.43	18.49	8.56	0.95	192.05	15.20
03	4.51	44.00	10.84	13.04	1.24	65745.05	18.01	8.29	0.95	192.61	15.21
04	4.70	38.18	9.50	12.38	1.22	71431.48	18.42	9.76	0.94	191.45	15.30
05	3.59	34.64	12.87	11.91	1.26	74495.71	18.57	9.87	0.98	194.42	15.27
06	4.71	31.47	10.13	11.93	1.27	75034.93	17.98	11.18	0.98	191.70	15.21
07	4.61	30.73	9.59	11.80	1.21	76107.79	18.16	10.98	0.93	191.16	15.22
08	3.96	29.74	9.89	11.69	1.15	76548.17	18.97	9.50	0.88	192.52	15.32
09	3.39	35.44	9.72	11.82	1.16	75538.48	18.80	11.01	0.89	192.39	15.31
10	3.05	39.52	12.02	11.73	1.17	76835.47	18.36	10.33	0.90	191.43	15.30
11	3.07	37.30	9.64	11.65	1.19	77983.84	18.17	10.19	0.91	190.88	15.33
12	2.97	38.53	9.77	11.86	1.22	77043.04	18.26	10.97	0.94	187.51	15.42
13	3.07	41.46	9.99	11.89	1.18	76107.14	18.02	10.71	0.91	191.09	15.34
14	2.76	39.44	10.55	11.80	1.17	75682.82	18.63	10.11	0.90	191.95	15.25
15	2.22	43.59	9.91	11.00	1.15	78944.41	19.24	10.44	0.88	188.67	14.63
16	1.65	39.40	8.90	11.08	1.11	77738.91	19.61	9.84	0.86	189.28	14.63
17	2.57	38.62	9.38	11.58	1.14	73551.76	18.67	10.76	0.88	187.60	14.34
18	2.44	39.35	9.49	11.44	1.13	74601.53	18.71	10.53	0.87	187.60	14.33
19	2.62	40.63	8.47	11.52	1.13	73947.13	18.55	10.52	0.87	188.28	14.33
20	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐
21	4.55	31.89	19.61	14.16	1.01	86518.06	13.82	7.23	0.78	186.80	14.02
22	2.98	42.24	10.28	11.77	0.99	75782.72	17.75	10.59	0.77	186.69	14.90
23	2.30	44.19	9.48	11.18	1.03	80701.67	18.67	10.87	0.79	187.83	15.11
24	2.65	43.10	10.03	11.01	1.08	81559.88	18.40	10.74	0.83	188.43	14.98
25	1.93	44.38	9.22	11.12	1.21	80105.04	18.63	9.79	0.94	188.97	14.94
26	2.20	44.05	9.35	11.12	1.20	79974.29	18.77	10.26	0.92	189.96	14.96
27	2.16	40.38	8.44	10.97	1.16	79586.28	19.07	10.92	0.89	189.01	14.70
28	2.03	38.89	7.99	10.93	1.17	79946.72	19.14	10.20	0.90	189.28	13.46
29	1.93	41.26	8.94	10.97	1.16	79508.80	19.29	10.61	0.89	191.29	14.79
30	2.13	42.24	9.67	11.01	1.10	78159.61	19.59	11.71	0.85	190.42	14.62
31	3.04	41.14	9.00	10.98	1.07	77066.23	19.72	11.93	0.82	189.93	14.39
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.07	39.57	10.07	11.71	1.16	76247.32	18.50	10.25	0.89	190.10	14.90
最大值	4.71	46.01	19.61	14.16	1.27	86518.06	19.72	11.93	0.98	194.42	15.42
發生日期											
最小值	1.65	29.74	7.99	10.93	0.99	64965.43	13.82	7.23	0.77	186.69	13.46
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管