

連續自動監測紀錄月報表

中華民國115年7月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	0.90	57.38	12.37	10.25	1.09	78206.92	21.68	9.18	0.83	191.03	13.98
02	0.90	56.61	11.50	10.25	1.09	77666.40	21.29	9.09	0.84	189.17	13.76
03	1.11	56.21	13.39	10.92	1.10	77358.87	20.44	11.04	0.85	188.72	14.48
04	1.79	55.10	13.39	10.50	1.15	76783.98	20.77	10.62	0.88	193.44	13.97
05	0.98	56.54	12.10	10.40	1.12	76222.33	21.20	9.55	0.86	187.97	13.64
06	0.98	56.90	12.50	10.43	1.13	76698.02	20.77	10.06	0.87	193.70	13.85
07	0.52	56.05	12.37	10.55	1.12	75954.30	21.19	9.97	0.86	197.75	14.08
08	1.69	54.86	13.42	10.45	1.14	76876.12	20.52	11.98	0.87	200.62	14.09
09	1.73	58.42	10.78	10.41	1.09	76798.10	20.62	10.94	0.84	190.21	13.73
10	1.58	58.96	11.35	10.42	1.08	77088.18	21.14	11.05	0.83	195.07	14.02
11	2.08	56.99	12.68	11.04	1.08	73279.15	19.56	10.27	0.83	189.08	13.70
12	1.35	58.00	12.02	10.51	1.10	76739.63	20.34	10.05	0.85	188.47	13.75
13	0.96	55.55	10.90	9.92	1.10	81880.66	21.63	8.79	0.84	196.33	14.12
14	1.61	53.08	12.20	10.01	1.10	80515.82	21.47	12.11	0.84	201.91	14.37
15	1.74	54.15	11.52	9.90	1.09	80858.40	21.42	11.47	0.84	198.54	14.18
16	1.71	55.40	11.72	10.00	1.13	80382.39	21.12	11.66	0.87	190.51	13.92
17	1.70	57.95	11.58	10.19	1.12	79594.68	21.02	10.58	0.86	196.31	14.19
18	2.28	57.06	11.94	10.38	1.09	80099.80	20.41	9.81	0.84	195.65	14.41
19	2.53	56.31	11.53	10.32	1.09	79836.81	20.30	10.52	0.84	190.07	14.09
20	2.08	56.99	11.26	10.13	1.08	80846.26	20.76	10.14	0.83	195.96	14.27
21	1.72	58.17	12.54	10.75	1.05	73795.13	20.38	8.77	0.80	197.26	13.59
22	2.14	59.98	11.33	11.59	1.06	67025.70	19.25	8.14	0.81	192.54	13.32
23	2.23	60.45	12.09	11.45	1.09	69404.83	19.58	7.24	0.83	186.87	13.49
24	3.90	59.48	11.78	11.62	1.12	68508.82	18.93	3.48	0.86	193.13	13.63
25	2.48	57.87	12.60	11.70	1.15	66564.09	18.96	6.11	0.89	189.32	13.24
26	2.69	58.37	12.85	11.77	1.14	66405.45	18.92	5.51	0.87	185.37	13.20
27	2.12	63.50	11.76	11.62	1.13	67782.69	19.13	6.06	0.87	191.31	13.45
28	1.72	58.77	12.49	11.51	1.11	68393.74	19.54	6.10	0.86	196.27	13.63
29	3.45	52.70	13.38	11.59	1.11	66986.16	19.02	6.80	0.85	191.06	13.24
30	3.87	49.55	11.64	11.50	1.05	67714.16	19.51	6.98	0.80	184.51	13.14
31	2.82	54.08	12.47	11.58	1.06	67799.05	19.37	7.46	0.82	190.68	13.42
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	1.91	56.82	12.11	10.76	1.10	74647.31	20.33	9.08	0.85	192.54	13.80
最大值	3.90	63.50	13.42	11.77	1.15	81880.66	21.68	12.11	0.89	201.91	14.48
發生日期											
最小值	0.52	49.55	10.78	9.90	1.05	66405.45	18.92	3.48	0.80	184.51	13.14
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國115年7月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	1.45	57.88	12.30	9.81	0.75	78159.26	23.04	9.09	0.58	205.82	13.57
02	1.51	56.48	12.31	10.09	0.73	77533.67	22.53	7.04	0.56	196.59	13.44
03	2.48	57.14	13.28	9.94	0.98	77074.94	22.69	7.64	0.76	196.65	13.22
04	2.53	57.97	12.55	10.11	1.22	76347.19	21.97	8.93	0.94	193.37	13.07
05	1.86	58.72	11.15	10.11	1.22	76107.06	22.42	8.92	0.95	192.75	13.09
06	1.75	60.41	13.29	10.69	1.24	77820.63	21.41	8.98	0.96	198.12	14.14
07	0.75	58.81	12.93	10.23	1.24	76748.30	22.47	8.92	0.96	205.35	13.72
08	1.65	56.88	13.95	10.22	1.24	76453.10	22.40	8.88	0.96	207.64	13.70
09	1.53	57.06	12.64	10.36	1.23	76265.28	21.76	8.65	0.95	197.57	13.45
10	1.53	54.19	11.94	10.08	1.22	76309.45	22.76	9.11	0.94	199.81	13.34
11	2.31	53.62	12.52	10.14	1.20	75953.41	21.92	9.33	0.93	195.58	13.09
12	1.50	55.76	12.25	9.62	1.25	78365.14	23.30	8.79	0.96	192.33	13.02
13	1.06	57.88	12.26	9.72	1.27	78253.57	23.56	8.78	0.98	200.75	13.40
14	0.82	55.07	11.67	9.80	1.25	77385.24	23.38	8.77	0.97	205.49	13.46
15	1.61	57.75	12.11	9.89	1.22	77245.72	22.71	8.84	0.94	194.48	13.12
16	1.46	60.13	11.30	9.75	1.20	77727.75	23.07	9.09	0.92	192.35	13.03
17	1.25	59.05	11.82	9.89	1.16	77593.33	22.95	8.93	0.89	199.51	13.36
18	1.82	58.92	12.86	10.22	1.16	77499.94	22.22	8.68	0.89	194.68	13.48
19	2.04	59.93	12.43	10.28	1.16	77779.53	21.76	9.08	0.89	194.26	13.52
20	1.78	60.36	11.73	10.02	1.15	78738.55	22.31	8.72	0.88	200.72	13.65
21	1.25	57.35	13.81	10.57	1.17	71913.95	21.87	9.76	0.90	200.36	12.84
22	1.15	61.69	11.74	11.22	1.23	64399.02	21.04	6.84	0.95	194.30	12.17
23	1.92	59.30	12.38	11.00	1.22	64762.24	21.27	7.57	0.94	185.57	11.77
24	3.79	59.65	10.93	11.16	1.20	64341.77	20.70	8.78	0.93	192.33	11.99
25	2.26	60.03	12.65	10.95	1.19	63408.05	21.14	6.44	0.91	194.01	11.66
26	1.85	57.79	12.28	11.09	1.18	64578.36	21.21	5.35	0.91	197.47	12.15
27	2.45	59.69	11.74	11.02	1.12	65787.62	20.85	6.18	0.86	186.68	11.94
28	1.52	61.94	10.64	10.99	1.13	67747.36	21.38	4.37	0.87	194.95	12.57
29	4.14	59.34	12.26	11.04	1.14	67044.56	20.53	7.21	0.88	190.78	12.27
30	3.91	58.42	12.10	10.79	1.15	67853.58	21.19	6.10	0.89	184.27	12.04
31	2.51	59.40	12.50	11.09	1.17	68484.55	20.93	6.93	0.90	193.88	12.74
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	1.92	58.34	12.27	10.38	1.16	73409.10	22.02	8.09	0.90	196.08	12.97
最大值	4.14	61.94	13.95	11.22	1.27	78738.55	23.56	9.76	0.98	207.64	14.14
發生日期											
最小值	0.75	53.62	10.64	9.62	0.73	63408.05	20.53	4.37	0.56	184.27	11.66
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管