

# 連續自動監測紀錄月報表

中華民國109年8月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	℃	m/s
01	4.06	66.87	6.22	9.92	1.94	81393.71	17.79	17.68	0.81	177.49	13.05
02	3.85	66.12	4.02	9.86	1.87	81798.14	18.33	17.55	0.78	177.25	13.12
03	4.18	67.06	6.10	9.78	1.73	82611.23	18.15	17.45	0.72	176.09	13.09
04	4.21	68.38	3.72	9.88	1.69	82143.73	18.55	17.19	0.70	172.81	13.23
05	4.26	69.33	4.64	9.83	1.80	82748.31	17.93	16.56	0.75	182.19	13.32
06	3.97	68.05	6.41	9.69	1.83	83731.41	18.69	15.83	0.76	180.76	13.39
07	4.05	67.86	6.23	9.76	1.85	82966.44	18.89	16.66	0.77	180.45	13.37
08	4.29	67.77	7.73	9.87	1.85	81909.15	18.48	16.68	0.77	179.10	13.24
09	4.27	67.22	7.97	9.65	1.78	83210.16	18.77	16.51	0.74	178.78	13.21
10	4.14	64.05	8.06	9.51	1.80	83437.89	18.77	16.85	0.75	178.17	13.07
11	3.89	64.29	7.27	10.16	1.75	79237.83	18.38	16.45	0.73	179.99	13.15
12	4.22	66.60	5.01	9.65	1.74	81997.52	18.83	16.62	0.73	178.95	13.04
13	4.47	69.25	6.63	9.69	1.78	82160.34	18.28	16.79	0.74	179.67	13.04
14	4.27	68.88	6.11	9.70	1.80	81929.05	18.65	17.19	0.75	179.55	13.07
15	4.39	67.98	7.28	9.80	1.82	79452.02	18.32	17.43	0.76	176.45	12.66
16	4.37	66.43	7.60	9.51	1.83	82526.10	18.98	17.64	0.76	178.96	12.99
17	4.20	66.21	8.58	9.52	1.72	82008.61	18.52	16.85	0.72	179.65	12.86
18	4.42	67.71	8.67	9.61	1.71	80732.97	18.24	17.47	0.71	176.87	12.66
19	4.32	67.79	10.58	9.61	1.72	81436.90	18.27	17.53	0.71	177.95	12.79
20	4.02	66.54	7.84	9.54	1.71	80811.03	18.24	17.57	0.71	176.68	12.57
21	4.21	68.33	5.71	9.79	1.74	81277.87	18.40	16.87	0.73	178.48	13.01
22	4.47	68.13	8.61	9.71	1.72	81242.20	18.16	17.62	0.72	177.74	12.85
23	4.25	67.78	6.74	9.64	1.75	81060.42	18.45	17.40	0.73	176.25	12.74
24	4.16	68.48	5.93	9.82	1.72	79826.56	17.88	16.54	0.72	176.96	12.69
25	4.17	68.73	8.39	9.79	1.76	80838.11	17.85	15.76	0.73	177.73	12.83
26	3.97	68.90	9.61	9.86	1.81	80659.31	17.80	16.95	0.75	177.48	12.86
27	3.36	66.60	7.41	9.74	1.82	80711.62	18.44	17.26	0.76	176.91	12.82
28	3.26	66.29	7.97	9.89	1.77	79615.49	19.00	17.66	0.74	178.39	12.95
29	3.36	67.01	6.73	9.66	1.66	81485.81	19.03	17.59	0.69	178.37	12.99
30	4.05	68.80	7.52	9.77	1.65	81034.52	18.38	17.54	0.69	179.07	12.95
31	4.03	67.80	7.71	9.66	1.58	81064.97	18.18	13.61	0.66	177.28	12.76
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.10	67.46	7.06	9.74	1.76	81518.05	18.41	16.95	0.74	178.14	12.98
最大值	4.47	69.33	10.58	10.16	1.94	83731.41	19.03	17.68	0.81	182.19	13.39
發生日期											
最小值	3.26	64.05	3.72	9.51	1.58	79237.83	17.79	13.61	0.66	172.81	12.57
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國109年8月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	2.86	65.30	10.77	10.18	2.39	76849.90	19.45	16.85	0.99	184.32	13.08
02	2.72	61.71	11.27	9.91	2.29	77361.17	20.28	16.99	0.95	182.50	12.92
03	3.49	64.42	12.04	9.93	2.24	78083.88	19.83	16.59	0.94	182.23	12.99
04	2.88	67.05	11.83	9.77	2.31	78677.22	20.74	16.62	0.96	176.71	13.02
05	3.80	68.24	9.47	9.78	2.31	78333.72	19.66	16.27	0.96	181.28	12.80
06	3.42	68.11	10.91	9.86	2.24	78099.01	18.68	15.05	0.93	180.99	12.68
07	3.73	68.58	7.90	10.13	2.23	76345.49	18.99	15.10	0.93	180.80	12.76
08	3.78	68.02	9.17	10.17	2.28	77239.70	18.38	16.81	0.95	181.29	12.87
09	3.70	67.31	10.17	10.06	2.35	78197.55	18.76	16.62	0.98	182.26	12.99
10	4.09	68.02	11.85	10.12	2.36	77423.76	18.29	16.51	0.98	181.69	12.83
11	3.95	66.69	11.70	10.01	2.33	77735.95	18.60	15.99	0.97	180.95	12.79
12	3.37	62.05	10.42	10.13	2.35	76555.82	19.24	16.14	0.98	181.98	12.86
13	3.65	67.47	10.62	10.05	2.34	77616.17	18.29	16.29	0.98	182.20	12.80
14	3.94	68.75	11.02	10.10	2.36	77501.15	18.30	17.25	0.98	181.55	12.83
15	4.05	66.88	10.84	10.16	2.35	75983.13	17.82	17.16	0.98	178.10	12.49
16	3.88	68.70	10.62	10.05	2.33	76561.92	18.52	17.23	0.97	180.59	12.62
17	3.95	68.08	10.78	9.86	2.32	76670.88	18.41	16.66	0.96	178.91	12.37
18	4.35	68.16	11.89	10.01	2.24	75882.40	17.89	16.14	0.93	178.42	12.32
19	4.24	68.59	10.18	10.13	2.24	76789.84	17.75	16.69	0.93	180.44	12.62
20	3.90	68.75	9.92	10.01	2.29	76377.23	18.07	15.88	0.95	178.87	12.42
21	4.07	69.96	10.55	10.40	2.30	77196.75	17.45	16.03	0.96	184.14	13.08
22	3.98	70.04	10.64	10.43	2.31	77004.80	17.38	16.59	0.96	182.31	13.02
23	3.89	69.07	9.50	10.43	2.29	77407.97	17.82	15.55	0.95	183.72	13.20
24	3.84	69.48	10.01	10.40	2.21	76956.49	17.54	14.80	0.92	183.64	13.05
25	3.69	69.69	9.79	10.39	2.18	77237.66	17.93	14.55	0.91	184.54	13.16
26	3.92	69.49	11.23	10.38	2.24	75863.66	17.33	15.54	0.93	181.71	12.75
27	3.32	67.88	10.57	10.21	2.30	76182.75	18.41	15.98	0.96	180.71	12.73
28	3.48	67.68	9.50	10.32	2.34	75429.89	18.80	15.77	0.97	181.35	12.82
29	3.36	68.14	11.74	10.26	2.33	76692.79	18.79	16.08	0.97	182.74	13.00
30	3.83	69.58	12.66	10.19	2.41	77723.14	18.46	15.07	1.00	184.28	13.07
31	4.21	69.00	10.44	10.40	2.41	75450.39	17.80	13.60	1.00	181.75	12.76
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.72	67.77	10.65	10.14	2.31	77013.94	18.51	16.08	0.96	181.52	12.83
最大值	4.35	70.04	12.66	10.43	2.41	78677.22	20.74	17.25	1.00	184.54	13.20
發生日期											
最小值	2.72	61.71	7.90	9.77	2.18	75429.89	17.33	13.60	0.91	176.71	12.32
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

