

連續自動監測紀錄月報表

中華民國110年7月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	2.86	63.56	7.32	9.47	1.36	82642.70	18.87	11.98	0.91	182.72	13.06
02	2.48	65.67	6.74	9.60	1.35	82419.39	18.97	11.50	0.90	183.14	13.20
03	3.34	62.51	8.06	9.42	1.33	82678.49	18.84	11.85	0.89	180.43	12.94
04	2.93	57.94	7.67	9.40	1.32	83277.17	19.70	11.62	0.88	182.43	13.21
05	2.42	60.73	6.38	9.79	1.28	84723.46	18.86	12.22	0.85	180.02	13.68
06	2.37	59.17	7.68	10.16	1.30	84676.27	18.25	11.79	0.87	175.83	13.90
07	2.39	62.06	7.80	10.14	1.23	84908.20	18.27	12.72	0.82	175.94	13.93
08	2.46	60.74	7.30	10.07	1.21	84489.71	18.24	12.54	0.80	173.92	13.69
09	2.61	60.81	6.31	10.10	1.23	83490.97	18.09	11.30	0.82	175.63	13.63
10	3.06	56.99	8.57	9.48	1.20	82723.93	19.06	12.18	0.80	181.83	13.10
11	3.34	53.34	6.85	9.29	1.19	83790.16	19.28	11.64	0.79	181.73	13.07
12	3.63	54.07	6.91	9.14	1.17	84129.82	19.77	12.29	0.78	181.36	13.02
13	3.36	58.03	6.66	9.52	1.18	83776.46	19.08	11.96	0.79	182.93	13.34
14	3.04	60.70	7.21	9.43	1.19	84565.79	19.15	12.15	0.79	183.66	13.38
15	2.97	62.79	6.73	9.42	1.22	83769.41	18.70	12.26	0.82	182.23	13.13
16	2.84	61.37	8.11	9.60	1.23	82662.65	18.56	12.12	0.82	182.28	13.14
17	2.94	58.88	9.60	9.49	1.22	83414.30	18.39	12.67	0.81	181.07	13.08
18	3.13	58.48	8.28	9.42	1.21	83860.32	18.96	12.06	0.81	182.06	13.19
19	3.50	53.28	6.41	9.20	1.22	83394.72	19.09	11.80	0.81	180.11	12.83
20	3.26	52.66	10.07	9.38	1.23	83233.67	18.82	11.74	0.82	180.34	12.97
21	3.08	57.23	9.37	9.54	1.20	83206.32	18.44	12.22	0.80	179.83	13.08
22	2.66	61.37	8.08	9.37	1.19	83747.63	19.17	12.20	0.79	180.16	13.09
23	2.77	63.21	7.10	9.52	1.18	83756.35	19.65	12.18	0.78	181.74	13.39
24	2.94	67.74	7.49	10.33	1.11	76718.37	18.35	11.70	0.74	178.03	12.86
25	2.79	62.84	7.48	9.41	1.18	84296.17	19.81	11.71	0.79	182.48	13.39
26	2.77	59.62	8.17	9.33	1.15	84665.96	19.93	11.96	0.77	183.24	13.41
27	2.90	62.56	7.39	9.34	1.16	83893.47	19.46	11.82	0.77	181.84	13.17
28	3.00	59.51	6.85	9.42	1.13	83389.86	19.08	11.81	0.75	181.06	13.11
29	2.90	58.82	9.18	9.32	1.05	84516.02	19.22	12.19	0.70	181.40	13.20
30	2.67	57.89	7.32	9.40	0.99	84004.61	19.24	12.31	0.66	181.90	13.22
31	2.92	58.41	8.76	9.55	1.00	83095.27	18.59	12.08	0.67	180.78	13.12
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.91	59.77	7.67	9.55	1.20	83481.21	18.96	12.02	0.80	180.71	13.24
最大值	3.63	67.74	10.07	10.33	1.36	84908.20	19.93	12.72	0.91	183.66	13.93
發生日期											
最小值	2.37	52.66	6.31	9.14	0.99	76718.37	18.09	11.30	0.66	173.92	12.83
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國110年7月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	4.06	61.27	10.81	9.99	1.70	84012.96	19.24	12.27	1.13	195.32	14.36
02	2.71	64.39	10.52	10.14	1.69	83564.40	19.37	12.05	1.13	197.18	14.55
03	2.97	61.21	9.40	10.01	1.67	82933.43	18.98	11.86	1.11	195.02	14.14
04	3.47	61.68	10.11	9.88	1.64	83046.18	19.30	11.97	1.09	194.77	14.18
05	3.49	63.25	9.94	10.54	1.58	84094.30	18.36	11.57	1.05	191.37	14.83
06	3.98	60.23	9.13	10.77	1.53	83446.27	17.94	13.29	1.02	184.90	14.77
07	3.98	62.79	10.23	10.74	1.56	84245.12	17.75	13.92	1.04	187.34	14.91
08	3.69	61.02	9.38	10.64	1.54	84621.08	17.91	13.30	1.03	186.07	14.82
09	3.97	60.04	10.97	10.51	1.51	84151.01	17.98	12.29	1.01	187.91	14.64
10	4.24	58.62	10.95	9.93	1.50	83725.93	18.96	12.17	1.00	194.65	14.16
11	4.43	57.29	9.37	9.84	1.56	83704.17	18.98	11.29	1.04	194.11	14.02
12	4.48	55.86	9.67	9.72	1.60	84451.31	19.25	11.49	1.07	194.24	14.05
13	4.45	60.97	10.38	10.03	1.61	83365.95	18.79	11.87	1.07	194.93	14.22
14	4.30	60.86	10.62	9.95	1.57	83691.55	18.63	12.37	1.05	194.70	14.12
15	4.43	58.99	9.59	9.96	1.58	83488.89	18.26	12.25	1.05	194.48	14.02
16	4.16	59.17	11.07	10.16	1.61	82653.35	18.16	12.21	1.07	194.99	14.15
17	4.73	56.30	11.36	10.06	1.64	83533.17	18.02	12.61	1.09	193.46	14.10
18	4.15	56.60	11.24	9.98	1.65	83350.05	18.61	11.83	1.10	193.69	14.07
19	4.98	55.25	9.31	9.65	1.62	83819.66	19.13	11.99	1.08	192.13	13.77
20	4.61	59.68	10.04	9.92	1.59	82850.77	18.96	12.18	1.06	192.44	13.93
21	4.35	60.84	10.32	10.07	1.61	83984.24	18.45	12.46	1.07	195.14	14.32
22	4.23	59.66	9.74	9.92	1.63	83129.55	19.00	12.31	1.09	191.50	13.96
23	4.12	63.16	10.31	10.03	1.61	83224.18	19.44	12.25	1.07	193.30	14.25
24	4.35	64.52	10.33	10.20	1.60	83794.23	18.90	12.19	1.07	192.97	14.47
25	3.63	64.15	10.01	10.04	1.60	83815.57	19.53	11.60	1.07	195.71	14.45
26	3.87	61.36	10.35	9.95	1.62	83865.81	19.44	12.06	1.08	195.48	14.32
27	3.60	62.15	9.35	9.96	1.65	83751.64	19.23	11.55	1.10	194.20	14.24
28	4.93	58.57	9.67	9.84	1.66	83665.02	19.16	12.38	1.10	193.26	14.03
29	3.90	59.90	9.76	10.05	1.64	82920.95	18.72	11.74	1.09	193.40	14.10
30	3.94	62.87	9.74	9.99	1.53	83846.56	19.08	12.11	1.02	194.36	14.27
31	4.08	58.84	10.55	10.19	1.45	83690.38	18.42	12.19	0.97	195.13	14.42
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.07	60.37	10.14	10.09	1.60	83627.02	18.77	12.18	1.07	193.17	14.28
最大值	4.98	64.52	11.36	10.77	1.70	84621.08	19.53	13.92	1.13	197.18	14.91
發生日期											
最小值	2.71	55.25	9.13	9.65	1.45	82653.35	17.75	11.29	0.97	184.90	13.77
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管