

連續自動監測紀錄月報表

中華民國114年11月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂ 二氧化 硫	NO _x 氮氧化 物	CO 一氧化 碳	O ₂ 氧氣	DUST 粉塵濃 度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光 率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	1.79	47.48	10.89	10.03	1.11	80806.08	20.17	8.32	0.85	186.76	13.75
02	1.49	45.71	10.07	10.06	1.13	80627.86	20.39	7.03	0.87	186.42	13.79
03	1.30	46.99	8.34	9.95	1.11	80807.61	20.51	5.96	0.85	185.93	13.68
04	1.33	49.27	9.79	10.11	1.13	81125.16	20.51	7.05	0.87	187.71	14.00
05	1.11	48.02	9.75	9.98	1.15	81000.96	20.98	7.10	0.88	187.84	13.90
06	1.56	51.28	9.29	9.95	1.15	80477.39	20.52	8.02	0.89	186.86	13.66
07	1.27	51.32	9.00	9.98	1.16	80681.60	20.59	8.90	0.90	188.08	13.78
08	1.50	50.75	10.12	9.88	1.19	81095.91	20.52	8.52	0.92	187.37	13.71
09	1.61	51.10	9.90	9.97	1.19	80218.24	19.94	8.19	0.92	186.07	13.53
10	1.22	51.11	8.71	9.80	1.20	80809.85	20.58	7.06	0.93	185.18	13.51
11	0.56	55.16	9.33	9.84	1.21	81734.83	21.50	6.03	0.93	188.20	13.95
12	1.00	55.03	8.84	9.86	1.17	81504.28	21.33	7.73	0.90	189.45	13.94
13	1.35	55.49	10.32	9.65	1.11	82289.12	21.38	7.84	0.86	188.23	13.80
14	1.10	50.15	8.86	9.75	1.13	83363.11	21.25	6.86	0.87	190.28	14.13
15	0.73	46.82	8.73	9.81	1.15	83749.31	21.22	6.32	0.88	189.83	14.06
16	0.33	46.96	9.56	9.71	1.14	82946.21	22.01	5.98	0.88	191.89	14.19
17	0.32	42.61	10.28	9.86	1.17	81022.34	21.38	6.96	0.90	189.37	13.86
18	0.72	42.56	10.26	9.88	1.17	81713.95	21.45	7.16	0.90	189.12	14.02
19	1.58	43.52	9.68	10.26	1.18	83503.18	20.39	6.53	0.91	182.72	14.45
20	1.05	46.62	9.49	9.89	1.18	81672.49	20.20	6.91	0.91	187.57	13.76
21	0.88	47.23	9.03	10.05	1.17	81407.40	20.21	6.82	0.90	189.40	13.97
22	1.30	45.75	9.57	9.93	1.16	81204.51	20.26	7.00	0.89	187.88	13.76
23	1.14	47.57	9.06	9.76	1.18	82182.35	21.20	6.94	0.91	190.12	13.94
24	1.17	48.41	9.87	9.73	1.12	81861.04	20.89	6.98	0.86	188.98	13.76
25	1.44	47.54	8.64	10.00	1.12	81801.44	19.90	6.85	0.87	188.74	13.89
26	1.24	46.49	9.53	10.06	1.10	82562.26	19.90	6.16	0.85	189.00	14.11
27	1.04	46.45	9.33	10.05	1.12	81419.04	19.80	5.00	0.86	188.51	13.88
28	1.00	46.29	9.82	10.12	1.12	81326.26	19.72	5.00	0.86	188.04	13.91
29	0.76	46.00	9.75	10.03	1.12	81687.22	20.27	4.69	0.86	189.69	14.00
30	0.91	46.75	9.52	9.95	1.12	82024.04	20.62	7.28	0.86	189.81	14.03
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	1.13	48.21	9.51	9.93	1.15	81620.83	20.65	6.91	0.88	188.17	13.89
最大值	1.79	55.49	10.89	10.26	1.21	83749.31	22.01	8.90	0.93	191.89	14.45
發生日期											
最小值	0.32	42.56	8.34	9.65	1.10	80218.24	19.72	4.69	0.85	182.72	13.51
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國114年11月30日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂ 二氧化 硫	NO _x 氮氧化 物	CO 一氧化 碳	O ₂ 氧氣	DUST 粉塵濃 度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光 率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	1.24	50.48	12.75	10.35	1.12	84014.09	20.28	7.08	0.86	196.72	14.49
02	1.38	51.43	13.21	10.37	1.13	83586.82	20.47	7.68	0.87	195.56	14.44
03	1.42	50.05	12.27	10.21	1.11	83298.69	20.59	5.84	0.85	193.78	14.16
04	1.48	54.58	13.24	10.42	1.05	83347.97	20.49	6.65	0.81	195.68	14.48
05	1.61	51.98	14.08	10.25	1.03	83287.85	20.81	8.70	0.79	194.49	14.26
06	1.72	50.01	12.42	10.14	1.01	81775.18	20.60	7.73	0.77	192.47	13.77
07	1.47	53.91	12.94	10.20	1.07	82750.94	20.64	8.49	0.82	194.75	14.09
08	1.27	57.57	10.88	10.42	1.11	83586.67	20.94	7.70	0.85	197.40	14.66
09	1.73	52.35	13.07	10.21	1.09	82653.39	20.14	8.08	0.84	193.92	13.98
10	1.59	51.14	12.01	10.27	1.09	83109.47	20.23	7.06	0.84	193.42	14.12
11	1.26	54.13	11.33	10.20	1.04	84883.93	21.51	6.63	0.80	196.88	14.67
12	1.41	53.62	11.90	10.11	1.01	82851.86	21.57	7.37	0.77	196.59	14.18
13	1.31	54.63	11.65	10.04	0.97	82518.50	21.57	7.70	0.75	193.99	13.98
14	0.98	51.49	12.01	10.23	0.78	84797.69	21.12	7.05	0.78	197.78	14.66
15	1.15	55.76	11.31	10.19	1.08	85286.79	20.99	7.46	0.83	197.21	14.64
16	0.95	52.90	12.36	10.00	1.11	85385.23	21.92	6.58	0.85	198.53	14.63
17	0.92	48.17	11.67	10.22	1.09	83085.68	21.15	6.85	0.84	195.80	14.29
18	0.72	48.56	12.32	10.39	1.06	83799.48	21.10	6.45	0.81	196.82	14.66
19	0.79	47.47	12.02	10.36	1.06	84621.73	20.91	7.33	0.82	196.53	14.73
20	1.42	47.81	12.22	10.70	1.11	85219.44	19.38	7.42	0.86	189.64	14.82
21	1.38	50.16	13.17	10.41	1.13	83797.84	20.03	6.85	0.87	196.57	14.50
22	1.35	49.97	11.62	10.39	1.08	83364.41	19.97	7.21	0.83	195.05	14.34
23	1.06	53.75	11.29	10.33	1.09	84033.78	21.05	6.50	0.83	198.04	14.64
24	1.15	52.92	12.12	10.28	1.07	84092.41	20.69	6.38	0.82	196.96	14.49
25	1.30	52.52	13.35	10.47	1.05	84113.32	19.64	5.99	0.80	195.71	14.49
26	1.03	52.71	12.56	10.43	1.07	84433.52	19.82	4.06	0.82	195.77	14.56
27	1.05	53.14	12.49	10.37	1.09	83251.10	19.85	4.27	0.84	195.11	14.25
28	1.13	52.89	14.50	10.46	1.12	83681.91	19.86	4.72	0.86	195.29	14.48
29	1.15	47.79	12.80	10.25	1.15	83851.62	21.16	5.87	0.89	196.11	14.47
30	1.04	47.00	12.52	10.25	1.16	84342.02	21.53	7.84	0.89	196.81	14.65
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	1.25	51.70	12.40	10.30	1.07	83760.78	20.67	6.85	0.83	195.65	14.42
最大值	1.73	57.57	14.50	10.70	1.16	85385.23	21.92	8.70	0.89	198.53	14.82
發生日期											
最小值	0.72	47.00	10.88	10.00	0.78	81775.18	19.38	4.06	0.75	189.64	13.77
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管