

# 連續自動監測紀錄月報表

中華民國106年12月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO <sub>2</sub> 二氧化硫	NO <sub>x</sub> 氮氧化物	CO 一氧化碳	O <sub>2</sub> 氧氣	DUST 粉塵濃度	MASS 排放流率	H <sub>2</sub> O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	6.81	95.17	20.60	14.81	1.66	66620.19	23.22	11.82	0.83	116.50	11.91
02	7.86	90.92	20.53	14.73	1.67	67411.33	23.74	14.74	0.84	116.66	11.90
03	6.37	87.66	21.33	14.66	1.80	68496.36	24.16	11.85	0.90	116.88	11.97
04	5.92	89.18	21.66	14.79	1.79	66889.59	23.87	10.46	0.90	116.45	11.88
05	2.83	82.69	21.12	14.74	1.53	65169.74	23.41	10.16	0.76	114.46	11.61
06	2.33	79.03	23.80	14.62	1.47	67277.55	23.18	11.80	0.74	114.93	11.63
07	1.98	81.66	22.33	14.68	1.77	66942.26	23.97	11.64	0.88	115.57	11.69
08	1.73	86.80	22.14	14.77	1.42	65935.03	23.11	12.88	0.71	114.30	11.64
09	2.28	87.58	24.50	14.77	1.24	65800.76	23.01	18.21	0.62	114.18	11.62
10	2.58	78.99	23.66	14.69	1.21	67039.23	23.23	15.17	0.60	113.88	11.68
11	2.46	83.50	21.96	14.79	1.19	66337.69	23.10	11.58	0.59	114.69	11.77
12	2.40	85.94	20.08	14.79	1.31	66478.17	23.40	10.36	0.66	114.62	11.78
13	5.40	86.01	24.39	14.74	1.42	66629.86	23.47	13.78	0.71	115.41	11.74
14	5.25	82.32	21.91	14.69	1.32	67121.13	23.98	12.00	0.66	116.40	11.78
15	7.93	81.41	26.08	14.69	1.49	66780.72	24.13	11.59	0.74	117.17	11.73
16	6.67	86.99	21.30	14.74	1.45	66455.30	23.39	15.87	0.73	115.14	11.72
17	2.85	78.59	24.31	14.75	1.13	66485.53	23.03	14.11	0.56	112.98	11.67
18	1.94	75.22	14.88	14.71	1.25	65207.20	23.42	11.71	0.63	113.10	11.38
19	1.99	79.69	20.64	14.75	1.19	65973.26	23.46	10.15	0.59	114.32	11.63
20	4.24	79.75	24.12	14.74	1.11	65787.14	23.01	13.44	0.56	114.80	11.57
21	2.80	79.13	22.62	14.71	1.00	66177.91	23.16	14.69	0.50	114.95	11.60
22	6.18	74.29	25.71	14.51	1.06	67928.48	23.76	12.34	0.53	116.75	11.60
23	7.45	77.85	21.14	14.65	1.16	65953.88	23.90	15.00	0.58	117.22	11.51
24	5.97	78.29	22.93	14.64	1.06	66635.03	23.81	15.39	0.53	115.81	11.58
25	3.13	74.44	22.19	14.67	0.92	66502.57	23.16	11.55	0.46	114.71	11.57
26	4.13	79.58	17.53	14.60	1.13	66938.32	23.50	13.55	0.56	115.69	11.55
27	6.33	79.80	14.86	14.67	1.28	66243.58	23.59	15.90	0.64	115.79	11.56
28	7.51	81.03	22.18	14.63	1.38	66838.22	23.97	12.55	0.69	117.28	11.64
29	6.88	76.51	26.93	14.64	1.37	66889.97	24.19	13.54	0.68	116.64	11.63
30	5.36	73.66	28.81	14.59	1.15	66945.00	24.35	14.94	0.57	115.92	11.55
31	2.20	73.76	17.44	14.63	0.94	66697.65	24.04	13.58	0.47	114.65	11.54
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.51	81.53	22.05	14.70	1.32	66599.63	23.57	13.11	0.66	115.41	11.67
最大值	7.93	95.17	28.81	14.81	1.80	68496.36	24.35	18.21	0.90	117.28	11.97
發生日期											
最小值	1.73	73.66	14.86	14.51	0.92	65169.74	23.01	10.15	0.46	112.98	11.38
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國106年12月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	8.93	73.40	28.05	14.33	2.34	69149.04	21.82	5.27	1.17	121.30	11.70
02	8.30	67.94	20.78	14.20	2.35	69693.29	21.26	4.23	1.17	121.43	11.58
03	8.71	67.16	26.19	14.23	2.38	70512.95	20.91	5.13	1.19	121.82	11.76
04	8.30	65.57	18.19	14.15	2.34	70442.11	21.24	4.33	1.17	121.26	11.61
05	7.47	69.19	24.84	14.27	2.39	69647.44	21.91	4.73	1.18	119.98	11.66
06	8.03	67.57	28.42	14.25	2.47	69571.82	22.38	4.92	1.23	119.90	11.58
07	7.50	70.78	23.13	14.19	2.62	70488.50	21.20	7.97	1.30	120.66	11.67
08	7.53	71.38	25.34	14.30	2.54	69289.16	22.00	9.77	1.27	119.44	11.62
09	7.96	77.18	30.14	14.51	2.47	67923.28	22.54	10.64	1.24	119.23	11.75
10	7.50	74.74	18.54	14.33	2.43	69996.51	21.34	9.62	1.21	119.63	11.78
11	7.98	70.19	16.17	14.22	2.39	70621.56	21.62	7.56	1.20	120.79	11.74
12	7.74	71.55	21.17	14.33	2.44	69718.85	21.51	7.51	1.22	121.15	11.78
13	7.98	68.39	28.29	14.31	2.43	70409.85	21.76	9.54	1.21	121.33	11.87
14	8.58	63.91	29.81	14.20	2.40	70373.85	21.84	10.24	1.20	121.62	11.71
15	8.79	67.12	23.49	14.37	2.39	69428.89	21.61	8.34	1.19	122.33	11.84
16	7.84	71.26	18.55	14.35	2.38	70112.11	22.21	8.77	1.19	120.76	11.90
17	6.38	77.40	27.91	14.37	2.41	70411.59	22.45	9.08	1.21	118.82	11.90
18	6.34	72.32	19.53	14.22	2.42	70662.47	21.95	8.14	1.21	119.05	11.69
19	6.85	73.13	17.84	14.32	2.44	70996.30	21.37	8.01	1.22	119.42	11.94
20	7.44	72.64	21.36	14.35	2.47	70185.10	22.15	8.63	1.23	119.76	11.85
21	8.12	72.97	23.59	14.22	2.48	71507.90	22.20	9.87	1.24	119.89	11.87
22	9.01	70.33	27.02	14.26	2.47	71637.07	22.21	11.04	1.24	121.54	12.00
23	9.09	69.89	26.21	14.30	2.41	70582.41	21.95	10.51	1.21	121.84	11.88
24	8.35	66.16	25.26	14.24	2.41	71290.53	21.68	10.55	1.21	120.99	11.89
25	7.53	72.59	19.61	14.23	2.44	70661.47	22.52	7.91	1.22	120.12	11.74
26	8.44	74.63	17.30	14.38	2.45	70758.05	22.06	10.47	1.22	121.03	12.05
27	9.36	69.41	14.52	14.23	2.42	71619.96	21.35	11.84	1.21	121.27	11.93
28	9.12	67.36	17.46	14.21	2.38	71941.46	21.46	10.77	1.19	122.37	11.98
29	8.47	73.54	27.02	14.26	2.42	72429.50	21.33	10.82	1.21	121.55	12.15
30	8.28	70.19	22.21	14.11	2.40	72488.28	21.32	11.50	1.20	120.69	11.85
31	7.56	67.65	21.04	14.19	2.44	71221.12	21.27	10.01	1.22	119.60	11.75
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	8.05	70.57	22.87	14.27	2.43	70508.79	21.76	8.64	1.21	120.66	11.81
最大值	9.36	77.40	30.14	14.51	2.62	72488.28	22.54	11.84	1.30	122.37	12.15
發生日期											
最小值	6.34	63.91	14.52	14.11	2.34	67923.28	20.91	4.23	1.17	118.82	11.58
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管