

連續自動監測紀錄月報表

中華民國109年5月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	4.95	66.94	9.21	10.29	2.64	81691.12	17.79	14.56	1.10	175.07	13.48
02	4.71	65.73	9.03	10.22	2.62	81501.78	17.89	14.47	1.09	174.21	13.35
03	4.85	67.31	7.74	10.16	2.64	81579.60	17.93	14.48	1.10	174.31	13.30
04	4.57	66.40	6.53	10.10	2.62	81754.11	18.36	14.55	1.09	176.54	13.39
05	4.62	67.12	10.11	10.26	2.49	80529.38	17.94	14.55	1.04	174.89	13.27
06	4.26	64.23	8.91	10.08	2.41	82433.04	18.05	14.59	1.01	173.92	13.36
07	3.80	60.71	7.35	9.94	2.35	83498.33	18.74	14.65	0.98	175.42	13.50
08	3.55	61.68	8.68	10.15	2.36	82340.54	18.67	14.30	0.98	176.42	13.59
09	3.26	62.83	7.28	10.36	2.35	80685.14	18.06	14.84	0.98	174.63	13.44
10	3.19	62.61	5.84	9.94	2.36	82928.49	18.82	14.19	0.99	176.08	13.44
11	3.04	60.38	7.60	10.36	2.34	80039.50	18.87	14.15	0.97	176.63	13.56
12	3.91	65.68	6.61	10.18	2.29	82700.05	18.06	14.24	0.96	174.90	13.55
13	3.66	68.16	7.38	10.00	2.30	82880.89	18.36	14.43	0.96	175.70	13.43
14	3.74	67.12	8.33	9.85	2.43	83387.26	18.63	14.50	1.01	176.28	13.39
15	3.59	66.96	6.28	10.05	2.42	82377.39	19.09	14.56	1.01	176.17	13.55
16	3.97	65.79	7.30	10.03	2.36	82995.46	18.51	14.69	0.98	176.18	13.52
17	4.07	67.54	5.86	10.11	2.36	83447.67	18.16	13.49	0.98	177.58	13.68
18	3.80	68.16	5.91	10.05	2.28	82889.01	18.66	13.96	0.95	176.65	13.57
19	3.69	66.61	6.33	9.95	2.31	84182.23	19.10	14.46	0.96	177.82	13.77
20	3.73	66.48	4.29	9.90	2.31	84056.32	18.63	14.08	0.96	177.61	13.60
21	3.90	68.51	8.59	9.82	2.34	84457.67	18.93	14.62	0.97	176.50	13.57
22	3.55	67.91	7.39	9.85	2.31	84646.80	19.57	14.29	0.96	177.40	13.79
23	3.47	67.29	7.35	9.98	2.32	83585.65	19.07	14.45	0.97	176.09	13.65
24	3.57	67.67	5.80	9.93	2.33	84240.75	19.01	13.97	0.97	177.54	13.73
25	3.50	65.80	5.15	9.85	2.34	85261.50	18.91	13.57	0.97	178.35	13.80
26	3.51	66.12	6.78	9.91	2.38	83936.33	19.04	13.89	0.99	178.19	13.69
27	3.52	64.64	5.25	10.02	2.28	82883.71	18.65	12.99	0.95	178.03	13.57
28	3.78	66.74	4.36	9.98	2.16	83570.86	18.62	14.05	1.23	175.48	13.54
29	3.54	67.03	5.83	10.08	2.32	82955.39	18.76	14.28	0.97	176.58	13.63
30	3.46	64.71	6.17	9.89	2.36	83454.23	19.25	13.57	0.98	176.85	13.57
31	3.48	65.42	5.90	9.89	2.36	83185.58	19.25	13.80	0.98	177.55	13.55
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.81	65.82	6.94	10.04	2.38	82905.67	18.63	14.23	1.00	176.31	13.54
最大值	4.95	68.51	10.11	10.36	2.64	85261.50	19.57	14.84	1.23	178.35	13.80
發生日期											
最小值	3.04	60.38	4.29	9.82	2.16	80039.50	17.79	12.99	0.95	173.92	13.27
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國109年5月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	4.62	68.46	10.59	10.43	2.43	79873.35	18.19	14.53	1.01	180.55	13.59
02	4.43	68.07	10.62	10.59	2.38	79106.71	18.17	14.64	0.99	181.17	13.68
03	4.42	68.03	10.43	10.53	2.35	78637.14	18.17	14.67	0.98	180.60	13.50
04	3.85	66.97	12.74	10.31	2.34	79494.32	19.17	14.60	0.98	182.43	13.58
05	4.35	64.10	9.60	10.43	2.37	78749.29	19.24	14.50	0.99	183.02	13.65
06	4.32	64.27	10.60	10.37	2.41	79656.76	18.81	14.77	1.00	180.51	13.60
07	3.94	62.41	9.78	10.18	2.45	80821.40	19.05	14.78	1.02	179.92	13.55
08	3.67	61.96	9.18	10.16	2.44	81233.78	19.24	14.73	1.01	182.04	13.69
09	2.23	63.90	10.55	10.56	2.39	78717.58	18.28	14.78	1.00	179.26	13.54
10	2.66	62.85	10.42	10.27	2.48	80351.28	19.01	14.64	1.03	180.97	13.61
11	3.47	64.03	10.62	10.31	2.46	80370.46	18.56	14.54	1.03	179.56	13.55
12	2.79	62.75	10.56	10.81	2.46	76478.24	19.18	14.32	1.02	182.14	13.75
13	3.88	65.33	9.93	10.05	2.46	80605.14	19.00	14.53	1.02	178.55	13.30
14	3.73	64.74	11.70	10.09	2.48	79902.39	18.81	14.41	1.03	178.75	13.22
15	4.04	62.52	9.76	9.98	2.48	78619.03	19.78	14.51	1.03	176.54	12.99
16	3.72	62.36	9.58	9.95	2.49	79090.30	19.71	14.61	1.04	176.18	12.99
17	3.70	64.89	11.29	10.12	2.48	80794.06	19.21	13.19	1.03	180.27	13.51
18	3.41	66.47	11.22	10.03	2.43	80217.88	19.19	13.47	1.01	177.70	13.22
19	3.39	65.72	10.29	10.11	2.51	79554.03	19.25	13.05	1.05	178.14	13.24
20	3.46	66.94	9.74	10.10	2.56	80030.86	19.09	13.55	1.07	179.36	13.31
21	3.46	66.15	10.02	10.03	2.56	79968.30	19.45	13.78	1.07	178.94	13.26
22	3.59	64.13	9.27	9.88	2.64	79226.02	20.17	13.94	1.10	178.50	13.05
23	3.42	63.65	10.45	9.90	2.91	77300.41	19.97	14.36	1.21	178.28	12.73
24	4.09	62.30	9.92	9.73	2.86	78272.83	20.59	13.73	1.19	180.54	12.87
25	3.04	63.37	10.19	9.87	2.76	77974.43	19.87	12.95	1.15	180.57	12.85
26	3.39	65.98	10.75	9.97	2.77	77579.24	19.81	13.12	1.15	179.89	12.88
27	3.26	64.40	9.97	10.13	2.72	75350.12	19.65	11.86	1.13	178.59	12.62
28	3.69	64.62	11.14	10.08	2.61	76076.65	19.62	13.94	1.16	178.26	12.74
29	3.36	66.80	10.01	10.13	2.66	76477.23	19.82	14.00	1.11	178.86	12.85
30	3.50	65.42	10.96	10.11	2.67	76064.84	19.83	13.21	1.11	179.69	12.79
31	3.72	64.46	9.40	9.97	2.60	77075.17	20.00	13.86	1.08	179.73	12.82
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.63	64.78	10.36	10.17	2.54	78828.04	19.29	14.05	1.06	179.66	13.24
最大值	4.62	68.46	12.74	10.81	2.91	81233.78	20.59	14.78	1.21	183.02	13.75
發生日期											
最小值	2.23	61.96	9.18	9.73	2.34	75350.12	18.17	11.86	0.98	176.18	12.62
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管