

連續自動監測紀錄月報表

中華民國106年08月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	10.04	79.74	22.45	15.04	1.53	62621.09	23.92	9.08	0.77	118.81	11.6
02	9.83	63.59	25.35	14.48	1.35	68079.56	24.88	10.38	0.67	118.89	11.53
03	10.28	71.92	27.79	14.63	1.33	66479.53	24.41	10.41	0.67	118.48	11.5
04	10.12	65.37	31.99	14.45	1.56	67909.30	25.06	9.22	0.78	119.11	11.46
05	11.95	59.06	35.56	14.24	0.59	70175.57	24.50	10.90	0.35	119.40	11.47
06	12.07	62.73	28.48	14.27	2.57	69449.99	24.65	11.01	1.17	119.42	11.42
07	13.41	65.38	28.49	14.33	2.25	68206.30	24.92	11.08	1.12	120.70	11.35
08	13.08	61.02	31.03	14.25	2.28	64986.38	25.39	8.55	1.14	121.10	10.68
09	12.59	64.46	27.27	14.30	2.17	68816.52	24.83	10.31	1.08	121.01	11.4
10	11.96	70.83	30.69	14.38	2.12	67873.72	24.98	9.56	1.06	120.69	11.38
11	12.58	68.52	36.80	14.49	2.15	60432.38	24.64	11.38	1.08	120.62	10.3
12	12.62	68.01	30.72	14.44	2.23	68153.40	24.42	11.90	1.11	120.29	11.52
13	12.03	67.93	32.16	14.40	2.28	67897.35	24.90	9.95	1.14	120.55	11.4
14	11.37	60.98	30.06	14.30	2.32	68785.38	25.21	8.01	1.16	120.55	11.38
15	11.62	60.79	33.13	14.36	2.25	68282.74	25.07	8.70	1.12	120.34	11.39
16	11.99	65.89	42.06	14.41	2.22	67796.43	24.79	10.54	1.11	120.13	11.39
17	11.48	67.05	40.25	14.50	2.23	67618.75	24.07	11.09	1.11	119.56	11.5
18	12.67	69.64	32.13	14.51	2.19	67010.54	24.27	14.56	1.10	119.84	11.44
19	11.43	70.33	27.50	14.58	2.17	66302.08	24.30	7.86	1.08	119.37	11.42
20	13.08	71.53	33.05	14.55	2.20	66894.12	24.09	10.56	1.10	119.92	11.48
21	10.60	70.02	28.39	14.47	2.20	67229.76	25.35	5.31	1.10	119.93	11.4
22	11.12	66.41	33.75	14.45	2.20	67107.57	25.23	4.13	1.10	120.59	11.36
23	14.78	63.90	32.68	14.36	2.21	68738.57	24.39	9.97	1.10	120.11	11.46
24	11.87	55.72	40.58	14.04	2.21	72234.78	24.53	8.97	1.11	119.40	11.48
25	12.44	53.26	38.47	14.01	2.18	71746.93	24.96	9.10	1.09	119.99	11.36
26	11.07	67.27	27.07	14.56	2.20	66360.96	24.37	5.23	1.10	119.64	11.4
27	11.00	64.74	30.09	14.42	2.23	67815.15	24.94	3.75	1.12	119.68	11.41
28	10.08	66.58	31.10	14.49	2.22	66374.78	24.61	3.95	1.11	119.62	11.3
29	11.67	61.58	32.83	14.36	2.25	66231.20	24.87	5.78	1.12	120.54	11.17
30	12.04	55.90	46.27	14.17	2.19	68941.12	25.43	7.77	1.10	120.52	11.31
31	11.07	60.04	37.98	14.09	2.14	67960.00	25.49	6.90	1.07	120.52	11.34
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	11.74	65.17	32.46	14.40	2.07	67564.90	24.76	8.90	1.03	119.98	11.35
最大值	14.78	79.74	46.27	15.04	2.57	72234.78	25.49	14.56	1.17	121.10	11.60
發生日期	23	1	30	1	6	24	31	18	6	8	1
最小值	9.83	53.26	22.45	14.01	0.59	60432.38	23.92	3.75	0.35	118.48	10.30
發生日期	2	25	1	25	5	11	1	27	5	3	11
超標準時數	0	0	1	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國106年08月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	8.26	87.13	18.75	14.67	2.07	63266.28	20.95	3.50	1.04	128.84	11.61
02	8.53	69.00	22.87	14.02	2.03	71238.00	19.78	3.28	1.02	128.63	11.86
03	8.86	71.83	18.62	14.01	2.03	71921.41	19.43	4.55	1.02	128.86	11.96
04	8.66	75.56	24.53	14.07	2.04	73500.44	19.33	4.18	1.02	129.40	12.35
05	9.27	69.06	28.06	13.96	2.05	72959.96	19.66	5.69	1.02	129.77	12.09
06	9.76	66.88	20.46	13.99	2.05	72936.88	19.42	5.30	1.02	129.98	12.15
07	9.48	63.76	19.72	13.78	2.05	73807.59	19.08	4.24	1.02	130.25	11.92
08	9.38	61.78	24.98	13.70	2.03	75074.91	18.82	3.46	1.01	130.17	12
09	10.26	62.68	24.43	13.74	2.05	74607.62	19.07	4.86	1.03	130.19	12
10	9.87	64.58	22.11	13.76	2.05	74941.37	18.74	4.25	1.03	129.72	12.08
11	9.94	68.65	26.02	13.97	2.03	73301.44	19.61	4.08	1.02	129.75	12.16
12	9.79	69.36	22.46	14.02	2.06	72287.08	19.60	4.43	1.03	129.68	12.07
13	9.29	68.55	21.18	13.91	2.08	75168.80	19.06	4.45	1.04	129.34	12.33
14	8.92	63.71	18.91	13.75	2.07	75682.38	18.54	3.30	1.04	129.10	12.16
15	8.97	61.15	26.32	13.76	2.05	75025.98	18.72	3.58	1.02	128.60	12.04
16	9.50	60.78	32.61	13.83	2.09	74508.13	19.56	4.39	1.05	128.63	12.08
17	8.62	66.31	27.80	13.93	2.10	73140.71	20.00	4.31	1.05	128.11	12.02
18	9.14	66.26	25.17	14.02	2.07	72785.91	20.11	5.27	1.04	128.29	12.12
19	8.46	68.08	18.98	14.03	2.08	72772.86	19.70	12.33	1.04	128.18	12.16
20	9.45	62.04	19.94	13.92	2.10	72428.33	19.84	12.47	1.05	128.32	11.89
21	8.34	62.75	18.91	13.72	2.08	75214.72	18.10	4.80	1.04	128.54	12.02
22	8.78	61.89	26.38	13.81	2.08	75259.26	18.13	9.33	1.04	129.53	12.21
23	8.59	63.93	22.87	13.95	2.08	74553.68	18.42	7.31	1.04	129.52	12.32
24	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
25	9.22	58.96	35.71	14.23	2.17	70470.82	19.64	9.93	1.09	129.66	11.57
26	8.23	63.66	18.11	13.88	2.13	67812.95	20.37	7.85	1.07	129.23	11.09
27	7.93	61.86	13.65	13.82	2.13	70265.85	19.59	5.33	1.07	128.70	11.39
28	7.75	60.96	17.99	13.72	2.12	72311.46	19.27	5.61	1.06	128.49	11.55
29	8.56	60.48	21.84	13.96	2.11	70255.62	19.96	6.88	1.05	129.24	11.61
30	9.49	59.60	30.37	13.80	2.10	71469.95	19.29	8.63	1.05	129.31	11.56
31	8.42	57.31	23.78	13.62	2.08	72566.66	19.06	8.64	1.04	129.23	11.45
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	8.70	63.18	22.37	13.46	2.01	70372.16	18.74	5.68	1.01	125.01	11.54
最大值	10.26	87.13	35.71	14.67	2.17	75682.38	20.95	12.47	1.09	130.25	12.35
發生日期	9	1	25	1	25	14	1	20	25	7	4
最小值	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
發生日期	24	24	24	24	24	24	24	24	24	24	24
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管