

連續自動監測紀錄月報表

中華民國110年12月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	2.96	67.00	7.96	10.17	1.66	83109.11	15.58	12.31	1.10	178.27	13.30
02	2.63	66.94	8.99	9.86	1.69	84322.65	16.48	12.27	1.13	178.28	13.26
03	3.15	66.92	8.66	10.14	1.73	83832.84	16.14	12.34	1.15	179.22	13.49
04	3.07	64.75	8.11	10.10	1.74	83593.74	16.03	11.82	1.16	179.26	13.40
05	2.71	63.97	7.84	9.89	1.76	83586.18	16.92	11.84	1.17	179.37	13.29
06	2.75	64.53	6.04	9.89	1.72	83504.81	16.73	12.18	1.15	179.20	13.23
07	2.51	66.22	6.47	9.91	1.72	83466.69	17.17	11.28	1.15	179.46	13.32
08	2.86	65.90	8.43	9.87	1.77	83684.19	16.33	11.71	1.18	178.53	13.16
09	2.32	64.33	7.79	9.82	1.81	83587.86	17.40	11.82	1.21	180.07	13.29
10	2.60	65.87	8.42	9.85	1.84	83397.09	17.50	12.81	1.22	180.18	13.31
11	2.25	63.82	9.15	9.72	1.83	83130.68	17.73	12.26	1.22	179.31	13.14
12	2.06	66.19	9.43	10.17	1.80	78972.22	17.00	10.93	1.20	177.20	12.82
13	3.06	67.22	67.78	10.30	1.72	76772.52	16.10	12.12	1.15	177.40	12.48
14	2.81	64.96	5.25	10.51	1.70	78127.85	17.12	11.13	1.13	179.18	13.17
15	2.97	61.13	6.11	10.58	1.70	75425.44	16.66	11.10	1.13	176.65	12.67
16	2.43	68.19	8.06	10.64	1.68	75413.91	16.43	11.26	1.12	176.74	12.72
17	2.54	67.67	8.55	10.64	1.62	76091.27	16.20	12.23	1.08	176.77	12.79
18	4.26	63.67	6.36	10.47	1.73	79617.01	11.93	15.32	1.15	177.22	12.92
19	2.96	66.20	7.87	9.97	1.76	83440.56	16.72	12.00	1.17	178.96	13.31
20	2.46	65.95	7.74	10.10	1.80	83178.30	16.88	11.93	1.20	181.83	13.54
21	2.00	65.88	7.88	10.15	1.77	81915.73	17.22	11.13	1.18	179.69	13.38
22	2.24	66.45	8.27	10.08	1.68	80797.33	17.09	11.58	1.12	179.37	13.07
23	2.54	64.95	8.34	9.97	1.75	81643.59	17.30	11.34	1.16	178.84	13.09
24	2.64	65.02	10.09	10.11	1.70	81941.90	17.39	11.80	1.14	179.74	13.37
25	2.10	64.10	9.06	10.14	1.64	82140.40	16.72	11.74	1.09	179.09	13.32
26	2.18	64.92	7.32	10.08	1.60	83696.33	17.08	11.66	1.07	179.92	13.58
27	2.35	65.16	6.68	10.03	1.67	83749.57	16.66	11.62	1.11	179.28	13.43
28	2.54	67.24	8.60	10.30	1.68	82455.42	16.44	11.48	1.12	180.63	13.56
29	2.68	66.72	6.14	10.17	1.69	82749.43	16.50	11.73	1.13	180.09	13.44
30	2.82	67.01	8.21	10.15	1.68	82840.28	15.65	11.92	1.12	179.05	13.27
31	2.49	65.64	8.22	10.20	1.69	83265.81	16.11	11.74	1.13	179.77	13.49
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.64	65.63	9.80	10.13	1.72	81724.22	16.56	11.88	1.15	178.99	13.21
最大值	4.26	68.19	67.78	10.64	1.84	84322.65	17.73	15.32	1.22	181.83	13.58
發生日期											
最小值	2.00	61.13	5.25	9.72	1.60	75413.91	11.93	10.93	1.07	176.65	12.48
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國110年12月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	4.45	67.51	11.20	10.64	1.57	83793.06	16.18	12.32	1.04	193.29	14.60
02	4.07	68.24	10.43	10.41	1.57	83604.26	17.16	12.16	1.05	192.12	14.38
03	5.23	66.59	10.42	10.61	1.60	83482.25	16.71	12.26	1.06	192.55	14.57
04	5.23	67.16	10.81	10.55	1.62	83689.39	16.61	12.33	1.08	192.43	14.50
05	4.59	66.57	9.99	10.38	1.66	83787.68	17.52	11.92	1.11	193.08	14.46
06	4.74	67.48	10.58	10.35	1.61	83402.66	17.31	12.18	1.08	192.13	14.28
07	4.18	68.60	9.59	10.45	1.55	83172.11	17.89	11.74	1.03	193.12	14.52
08	4.87	67.16	10.77	10.54	1.56	83036.90	16.87	11.37	1.04	192.89	14.44
09	4.19	67.93	9.84	10.52	1.53	82588.04	17.12	11.50	1.02	192.93	14.37
10	4.59	67.60	9.29	10.64	1.52	81572.79	17.29	12.02	1.01	192.91	14.39
11	4.31	68.30	9.80	10.54	1.60	81899.35	17.68	11.83	1.07	193.42	14.40
12	4.50	67.52	9.22	10.74	1.61	78643.03	17.17	10.96	1.07	186.05	13.77
13	5.01	66.93	7.99	10.95	1.64	76097.46	15.95	11.69	1.10	190.00	13.53
14	4.17	67.92	9.65	11.19	1.74	74884.92	17.21	10.61	1.16	191.80	13.90
15	5.10	66.07	10.04	11.12	1.76	72956.38	16.92	11.86	1.18	188.63	13.31
16	4.67	68.04	10.15	11.32	1.74	72080.26	16.14	11.38	1.16	188.00	13.30
17	4.37	66.73	8.97	11.23	1.71	73503.07	16.07	11.26	1.14	188.31	13.42
18	5.79	65.74	9.00	11.06	1.59	77140.91	15.87	11.28	1.06	184.64	13.72
19	5.23	67.79	9.25	10.90	1.60	79224.75	16.02	12.04	1.07	190.82	14.06
20	4.71	67.10	8.47	10.68	1.63	79766.37	16.89	11.97	1.09	192.23	14.03
21	3.76	66.81	10.03	10.82	1.68	78325.20	17.17	11.64	1.12	192.97	14.04
22	4.47	68.24	11.35	10.62	1.65	79786.87	17.08	11.58	1.10	192.02	13.99
23	4.48	66.59	10.88	10.53	1.79	79271.32	17.27	12.15	1.19	191.75	13.80
24	4.76	64.73	11.79	10.92	1.85	77780.92	16.99	12.17	1.23	193.00	14.05
25	4.60	62.88	10.55	10.94	1.79	78632.37	16.16	11.85	1.19	192.44	14.08
26	4.37	64.59	9.35	10.80	1.72	79650.24	16.81	11.24	1.15	192.93	14.19
27	4.67	64.97	7.47	10.81	1.77	78995.15	16.59	11.66	1.18	192.15	14.02
28	4.72	66.25	8.16	11.08	1.76	77756.38	16.49	11.70	1.17	194.04	14.22
29	4.82	66.21	8.29	11.01	1.70	78264.58	16.13	12.17	1.13	193.36	14.14
30	4.96	66.51	8.79	11.04	1.71	78372.08	15.58	12.24	1.14	193.04	14.09
31	4.37	65.86	11.30	11.02	1.76	78659.81	16.03	11.69	1.17	194.32	14.23
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.64	66.79	9.79	10.79	1.66	79478.08	16.74	11.77	1.11	191.72	14.09
最大值	5.79	68.60	11.79	11.32	1.85	83793.06	17.89	12.33	1.23	194.32	14.60
發生日期											
最小值	3.76	62.88	7.47	10.35	1.52	72080.26	15.58	10.61	1.01	184.64	13.30
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管