

連續自動監測紀錄月報表

中華民國115年5月31日

| | | | | 管制編號 | | F0501686 | | 煙道排放口編 | | P001 | |
|----------|-----------------|-----------------|-------|----------------|-------------------|---------------------|------------------|--------|------|--------|-------|
| 項目 日期 | SO ₂ | NO _x | CO | O ₂ | DUST | MASS | H ₂ O | HCL | OPAC | TEMP | VEL |
| | 二氧化硫 | 氮氧化物 | 一氧化碳 | 氧氣 | 粉塵濃度 | 排放流率 | 水份 | 鹽酸 | 不透光率 | 溫度 | 流速 |
| | ppm | ppm | ppm | % | mg/m ³ | Nm ³ /hr | % | ppm | % | °C | m/s |
| 01 | 2.71 | 55.91 | 11.31 | 10.47 | 1.10 | 79894.59 | 20.25 | 9.39 | 0.85 | 186.33 | 14.17 |
| 02 | 2.66 | 55.89 | 11.55 | 10.35 | 1.10 | 79210.98 | 20.69 | 9.62 | 0.85 | 186.24 | 13.97 |
| 03 | 2.57 | 56.34 | 11.68 | 10.13 | 1.11 | 80268.96 | 21.54 | 9.83 | 0.86 | 187.70 | 14.06 |
| 04 | 2.82 | 59.74 | 10.74 | 10.28 | 1.10 | 80227.50 | 20.22 | 8.87 | 0.85 | 185.07 | 13.94 |
| 05 | 2.56 | 59.02 | 11.68 | 10.28 | 1.13 | 80344.53 | 21.08 | 9.65 | 0.87 | 186.31 | 14.15 |
| 06 | 2.94 | 60.83 | 12.30 | 10.27 | 1.15 | 80367.50 | 21.03 | 9.94 | 0.89 | 190.19 | 14.28 |
| 07 | 3.95 | 60.43 | 11.90 | 10.28 | 1.12 | 79941.97 | 20.65 | 10.47 | 0.86 | 187.14 | 14.02 |
| 08 | 2.69 | 55.03 | 12.79 | 10.50 | 1.15 | 79539.32 | 20.52 | 10.31 | 0.88 | 187.55 | 14.24 |
| 09 | 3.05 | 55.51 | 11.75 | 10.46 | 1.17 | 79762.27 | 20.02 | 10.66 | 0.90 | 185.55 | 14.08 |
| 10 | 2.74 | 58.59 | 11.56 | 10.05 | 1.19 | 80460.75 | 21.62 | 10.29 | 0.92 | 187.14 | 14.00 |
| 11 | 2.52 | 58.70 | 11.16 | 10.07 | 1.20 | 80154.24 | 21.73 | 8.64 | 0.93 | 187.03 | 13.97 |
| 12 | 2.24 | 55.88 | 12.25 | 10.29 | 1.18 | 79752.36 | 21.09 | 9.16 | 0.91 | 187.75 | 14.11 |
| 13 | 2.82 | 56.01 | 12.60 | 10.24 | 1.15 | 79182.96 | 20.64 | 9.60 | 0.89 | 185.43 | 13.79 |
| 14 | 2.48 | 57.58 | 11.71 | 10.09 | 1.14 | 79915.02 | 21.56 | 10.81 | 0.88 | 185.54 | 13.89 |
| 15 | 2.75 | 60.93 | 11.47 | 10.30 | 1.16 | 79680.02 | 20.94 | 10.31 | 0.90 | 186.21 | 14.04 |
| 16 | 2.77 | 61.63 | 11.53 | 10.59 | 1.14 | 78314.16 | 20.23 | 8.61 | 0.88 | 186.47 | 14.05 |
| 17 | 3.05 | 59.69 | 11.85 | 10.45 | 1.12 | 78629.16 | 20.37 | 8.91 | 0.86 | 186.32 | 13.95 |
| 18 | 2.77 | 61.46 | 12.98 | 10.72 | 1.13 | 76584.86 | 20.32 | 8.79 | 0.87 | 187.21 | 13.95 |
| 19 | 2.55 | 57.95 | 13.95 | 10.83 | 1.12 | 74833.24 | 20.81 | 8.89 | 0.86 | 186.35 | 13.84 |
| 20 | 2.82 | 58.14 | 13.32 | 11.02 | 1.12 | 74180.82 | 20.13 | 9.10 | 0.86 | 186.29 | 13.87 |
| 21 | 3.97 | 57.30 | 12.57 | 10.92 | 1.10 | 74566.78 | 20.06 | 9.19 | 0.84 | 185.04 | 13.75 |
| 22 | 2.96 | 51.33 | 11.95 | 10.77 | 1.08 | 74596.27 | 20.56 | 8.93 | 0.83 | 187.75 | 13.73 |
| 23 | 3.11 | 54.51 | 12.63 | 10.79 | 1.09 | 74995.34 | 20.56 | 9.15 | 0.84 | 186.32 | 13.78 |
| 24 | 3.27 | 55.67 | 11.38 | 10.73 | 1.07 | 74909.98 | 20.53 | 9.20 | 0.82 | 185.25 | 13.64 |
| 25 | 2.84 | 59.73 | 12.98 | 10.63 | 1.07 | 75378.06 | 20.73 | 9.02 | 0.82 | 185.22 | 13.63 |
| 26 | 2.62 | 59.25 | 12.66 | 10.73 | 1.06 | 75290.29 | 20.95 | 8.80 | 0.81 | 186.97 | 13.84 |
| 27 | 3.24 | 55.79 | 13.21 | 10.78 | 1.03 | 75124.33 | 20.54 | 9.15 | 0.79 | 186.87 | 13.79 |
| 28 | 2.65 | 59.08 | 11.95 | 10.85 | 1.02 | 74445.36 | 20.05 | 9.10 | 0.78 | 185.68 | 13.64 |
| 29 | 2.48 | 57.92 | 12.91 | 10.93 | 1.04 | 75361.91 | 20.22 | 9.22 | 0.80 | 186.25 | 13.96 |
| 30 | 2.54 | 59.44 | 11.93 | 11.06 | 1.09 | 75376.66 | 19.79 | 8.92 | 0.84 | 186.73 | 14.08 |
| 31 | 3.11 | 57.92 | 11.20 | 11.05 | 1.11 | 75037.10 | 19.55 | 8.99 | 0.85 | 186.07 | 13.94 |
| 監測日數 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 |
| 平均值 | 2.85 | 57.85 | 12.11 | 10.55 | 1.11 | 77623.46 | 20.61 | 9.40 | 0.86 | 186.52 | 13.94 |
| 最大值 | 3.97 | 61.63 | 13.95 | 11.06 | 1.20 | 80460.75 | 21.73 | 10.81 | 0.93 | 190.19 | 14.28 |
| 發生日期 | | | | | | | | | | | |
| 最小值 | 2.24 | 51.33 | 10.74 | 10.05 | 1.02 | 74180.82 | 19.55 | 8.61 | 0.78 | 185.04 | 13.63 |
| 發生日期 | | | | | | | | | | | |
| 超標準時數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 標準值 | 150 | 220 | 150 | ----- | ----- | ----- | ----- | 60 | 20 | ----- | ----- |
| 備註 | | | | | | | | | | | |

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國115年5月31日

| | | | | 管制編號 | | F0501686 | | 煙道排放口編 | | P002 | |
|----------|-----------------|-----------------|----------|----------------|-------------------|---------------------|------------------|--------|----------|--------|-------|
| 項目 日期 | SO ₂ | NO _x | CO | O ₂ | DUST | MASS | H ₂ O | HCL | OPAC | TEMP | VEL |
| | 二氧化 硫 | 氮氧化 物 | 一氧化 碳 | 氧氣 | 粉塵濃 度 | 排放流率 | 水份 | 鹽酸 | 不透光 率 | 溫度 | 流速 |
| | ppm | ppm | ppm | % | mg/m ³ | Nm ³ /hr | % | ppm | % | ℃ | m/s |
| 01 | 1.67 | 51.16 | 12.34 | 9.79 | 0.99 | 78898.78 | 22.35 | 6.99 | 0.76 | 188.91 | 13.07 |
| 02 | 1.65 | 54.86 | 11.94 | 9.80 | 1.01 | 78903.45 | 22.45 | 6.25 | 0.77 | 190.21 | 13.14 |
| 03 | 2.00 | 54.05 | 12.03 | 9.68 | 1.03 | 79285.34 | 22.81 | 6.54 | 0.79 | 191.07 | 13.15 |
| 04 | 1.93 | 51.76 | 12.03 | 9.74 | 1.03 | 79131.60 | 21.86 | 5.62 | 0.79 | 188.36 | 12.96 |
| 05 | 1.89 | 51.48 | 12.83 | 9.84 | 1.05 | 79165.51 | 22.59 | 7.67 | 0.80 | 189.88 | 13.24 |
| 06 | 1.60 | 49.78 | 13.36 | 9.89 | 1.03 | 79338.65 | 22.48 | 8.33 | 0.79 | 194.18 | 13.44 |
| 07 | 4.73 | 51.82 | 12.25 | 9.78 | 1.01 | 79786.31 | 22.37 | 7.71 | 0.78 | 191.56 | 13.30 |
| 08 | 2.33 | 52.77 | 13.50 | 9.95 | 1.02 | 79778.16 | 22.15 | 10.10 | 0.78 | 191.68 | 13.46 |
| 09 | 2.46 | 51.61 | 12.75 | 9.90 | 1.02 | 78805.21 | 21.68 | 8.73 | 0.78 | 186.96 | 13.02 |
| 10 | 1.86 | 53.61 | 13.01 | 9.75 | 1.01 | 79530.54 | 22.85 | 5.93 | 0.78 | 189.85 | 13.24 |
| 11 | 1.76 | 50.36 | 13.28 | 9.68 | 1.01 | 79062.39 | 22.94 | 5.20 | 0.77 | 188.53 | 13.06 |
| 12 | 1.42 | 51.49 | 13.96 | 9.88 | 1.03 | 79108.07 | 22.51 | 6.03 | 0.79 | 189.84 | 13.27 |
| 13 | 1.90 | 49.23 | 13.06 | 10.25 | 1.00 | 76718.94 | 21.56 | 5.26 | 0.77 | 188.37 | 13.08 |
| 14 | 1.63 | 51.25 | 12.45 | 9.91 | 0.93 | 78483.60 | 22.65 | 6.60 | 0.71 | 188.91 | 13.18 |
| 15 | 1.73 | 51.84 | 12.83 | 10.13 | 0.88 | 77725.08 | 22.15 | 6.08 | 0.67 | 189.21 | 13.24 |
| 16 | 2.27 | 52.88 | 11.90 | 9.82 | 0.88 | 78714.27 | 22.09 | 8.46 | 0.67 | 187.81 | 12.99 |
| 17 | 2.94 | 48.93 | 12.98 | 9.66 | 0.87 | 79240.96 | 22.22 | 8.95 | 0.67 | 187.75 | 12.92 |
| 18 | 2.74 | 51.57 | 13.97 | 9.76 | 0.93 | 79005.56 | 22.10 | 8.70 | 0.71 | 189.16 | 13.01 |
| 19 | 2.25 | 52.89 | 14.07 | 10.24 | 0.98 | 76831.08 | 22.04 | 9.13 | 0.76 | 190.15 | 13.25 |
| 20 | 2.77 | 52.68 | 13.47 | 10.54 | 0.96 | 75093.84 | 21.64 | 8.96 | 0.74 | 190.93 | 13.27 |
| 21 | 3.81 | 51.82 | 12.84 | 10.35 | 0.95 | 75144.00 | 21.74 | 8.23 | 0.73 | 188.42 | 13.01 |
| 22 | 3.64 | 45.83 | 11.93 | 10.28 | 0.97 | 74979.32 | 21.98 | 8.88 | 0.75 | 188.39 | 12.97 |
| 23 | 3.28 | 48.50 | 12.82 | 10.31 | 0.98 | 75182.23 | 21.85 | 9.33 | 0.75 | 188.65 | 12.98 |
| 24 | 3.70 | 48.42 | 13.30 | 9.96 | 0.95 | 75706.52 | 22.39 | 8.99 | 0.74 | 187.70 | 12.71 |
| 25 | 3.45 | 52.19 | 12.03 | 9.91 | 0.97 | 75758.75 | 22.40 | 9.08 | 0.75 | 186.32 | 12.62 |
| 26 | 2.67 | 53.90 | 12.08 | 10.10 | 1.01 | 75825.50 | 22.53 | 8.58 | 0.77 | 189.42 | 12.97 |
| 27 | 4.10 | 52.70 | 13.04 | 10.32 | 0.99 | 75565.68 | 21.88 | 9.66 | 0.76 | 191.17 | 13.15 |
| 28 | 2.44 | 54.47 | 13.56 | 10.33 | 0.95 | 76313.96 | 21.69 | 9.03 | 0.74 | 191.94 | 13.28 |
| 29 | 2.34 | 55.13 | 12.57 | 10.24 | 0.91 | 75604.31 | 21.96 | 9.18 | 0.70 | 188.96 | 12.98 |
| 30 | 2.75 | 51.61 | 12.15 | 10.19 | 0.86 | 75000.12 | 21.64 | 8.70 | 0.66 | 186.39 | 12.69 |
| 31 | 3.23 | 53.84 | 12.29 | 10.18 | 0.86 | 75048.53 | 21.55 | 9.12 | 0.66 | 186.63 | 12.68 |
| 監測日數 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 | 31 |
| 平均值 | 2.55 | 51.76 | 12.79 | 10.01 | 0.97 | 77507.62 | 22.16 | 7.94 | 0.74 | 189.27 | 13.08 |
| 最大值 | 4.73 | 55.13 | 14.07 | 10.54 | 1.05 | 79786.31 | 22.94 | 10.10 | 0.80 | 194.18 | 13.46 |
| 發生日期 | | | | | | | | | | | |
| 最小值 | 1.42 | 45.83 | 11.90 | 9.66 | 0.86 | 74979.32 | 21.55 | 5.20 | 0.66 | 186.32 | 12.62 |
| 發生日期 | | | | | | | | | | | |
| 超標準時數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 標準值 | 150 | 220 | 150 | ----- | ----- | ----- | ----- | 60 | 20 | ----- | ----- |
| 備註 | | | | | | | | | | | |

廠長

維修組長

操作組長

值班主管