

# 連續自動監測紀錄月報表

中華民國106年04月30日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO <sub>2</sub> 二氧化硫	NO <sub>x</sub> 氮氧化物	CO 一氧化碳	O <sub>2</sub> 氧氣	DUST 粉塵濃度	MASS 排放流率	H <sub>2</sub> O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	1.93	81.44	22.60	14.59	2.12	60336.93	24.03	6.79	1.06	118.97	10.64
02	3.41	81.53	23.67	14.51	2.31	60809.66	24.16	6.40	1.16	119.48	10.59
03	4.53	84.39	21.68	14.51	2.28	60816.16	24.03	4.37	1.14	121.12	10.64
04	4.99	80.20	23.71	14.45	2.35	49935.23	24.71	3.67	1.18	122.18	8.66
05	4.17	76.44	27.74	14.35	2.52	61600.93	24.92	4.59	1.26	122.50	10.54
06	5.39	81.22	26.48	14.44	2.95	61321.17	24.74	5.63	1.47	122.67	10.65
07	6.25	79.41	36.06	14.38	3.58	61286.51	24.91	6.39	1.79	123.22	10.57
08	6.02	79.15	27.02	14.34	3.55	59955.14	25.02	6.77	1.77	123.99	10.29
09	5.44	74.25	25.75	14.22	3.07	63157.93	25.63	5.76	1.53	124.59	10.67
10	6.28	76.84	23.03	14.27	4.02	62839.79	25.54	6.39	2.01	125.35	10.71
11	5.36	76.01	24.03	14.34	3.99	62334.95	25.24	4.91	2.00	122.12	10.65
12	5.46	80.05	26.28	14.42	3.70	61447.21	24.57	5.35	1.85	120.52	10.59
13	4.60	75.90	31.33	14.35	3.30	62623.67	24.29	5.25	1.65	120.50	10.67
14	5.27	76.77	31.40	14.29	6.13	62950.98	25.24	6.16	2.90	121.84	10.66
15	5.83	74.40	33.35	14.24	3.50	63591.81	25.34	6.56	1.76	122.88	10.73
16	5.85	72.58	33.19	14.25	4.05	63374.58	25.19	6.62	2.02	123.26	10.71
17	5.97	73.73	38.79	14.21	4.62	63655.46	25.57	6.63	2.31	124.04	10.72
18	6.41	67.08	25.42	14.00	5.32	65691.96	25.68	7.74	2.66	123.74	10.73
19	5.74	64.75	17.99	14.12	5.92	57273.94	25.83	7.08	2.96	123.32	9.47
20	5.85	79.07	22.93	14.89	5.36	56648.81	24.70	7.15	2.68	122.62	10.57
21	6.33	73.21	29.94	14.41	3.89	61886.46	25.90	6.40	1.95	123.12	10.73
22	6.23	75.86	40.79	14.52	3.29	61244.78	24.70	8.75	1.65	119.41	10.69
23	7.38	76.40	29.36	14.42	2.16	62269.39	24.41	10.26	1.08	119.55	10.69
24	7.13	88.34	24.48	14.65	3.39	59812.49	23.72	8.80	1.69	119.43	10.65
25	6.06	84.21	19.90	15.21	4.71	53668.91	23.59	6.34	2.36	121.05	10.51
26	6.31	90.38	18.29	15.55	5.49	49657.67	22.90	7.27	2.75	120.69	10.32
27	5.43	91.58	15.74	15.72	4.30	49467.52	22.32	7.40	2.15	117.95	10.55
28	5.10	95.52	16.31	15.56	2.83	50674.86	22.53	7.39	1.42	118.59	10.52
29	4.81	86.06	18.97	15.73	2.67	48206.24	21.72	7.61	1.34	118.85	10.3
30	5.75	102.30	15.68	15.55	3.16	49282.64	22.91	7.00	1.58	119.50	10.23
31											
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	5.51	79.97	25.73	14.62	3.68	58927.46	24.47	6.58	1.84	121.57	10.49
最大值	7.38	102.30	40.79	15.73	6.13	65691.96	25.90	10.26	2.96	125.35	10.73
發生日期	23	30	22	29	14	18	21	23	19	10	15
最小值	1.93	64.75	15.68	14.00	2.12	48206.24	21.72	3.67	1.06	117.95	8.66
發生日期	1	19	30	18	1	29	29	4	1	27	4
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國106年04月30日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	7.34	83.16	14.28	14.08	3.47	72903.48	19.67	7.79	1.73	127.11	11.88
02	8.09	81.80	12.05	14.17	3.36	73661.62	20.13	9.68	1.68	126.98	12.16
03	8.56	80.09	10.97	14.05	3.64	74019.11	20.32	8.74	1.82	128.15	12.05
04	8.50	79.28	13.41	14.17	3.86	73063.00	19.74	6.59	1.93	129.06	12.12
05	8.04	75.12	14.09	14.07	3.63	74685.65	19.22	6.59	1.81	129.27	12.23
06	8.10	71.27	13.75	13.98	3.52	74924.90	19.25	5.71	1.76	129.15	12.11
07	8.79	73.16	18.37	14.10	3.62	73821.46	19.35	7.32	1.81	129.97	12.16
08	8.76	69.50	19.69	13.99	3.55	75825.00	18.92	9.35	1.78	130.53	12.3
09	8.03	69.01	14.31	13.93	3.56	75444.73	17.92	8.53	1.78	131.18	12.15
10	8.57	65.97	16.51	13.84	3.49	77303.17	17.94	8.84	1.74	131.92	12.33
11	8.56	74.18	15.51	13.93	3.46	75257.99	17.88	8.59	1.73	130.34	12.09
12	8.67	79.06	17.77	14.04	3.30	73244.00	19.80	11.49	1.65	128.81	11.93
13	8.19	75.53	14.49	14.04	3.37	74710.02	20.02	12.52	1.69	128.34	12.14
14	8.23	75.21	18.94	14.02	3.76	73443.41	18.56	9.30	1.88	128.97	11.92
15	7.73	70.80	18.14	13.88	3.76	74739.65	18.11	11.48	1.88	129.96	11.92
16	7.84	68.46	18.77	13.87	3.83	74740.77	17.86	6.81	1.91	130.31	11.92
17	7.58	70.33	24.54	13.98	2.88	73676.25	15.29	2.28	1.43	131.01	11.96
18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.40	0.00	0
19	7.59	54.11	22.64	14.03	3.95	74169.48	20.19	17.06	1.98	128.94	12.05
20	7.83	75.74	14.74	14.60	3.91	66916.74	20.34	12.43	1.96	129.32	11.82
21	8.32	73.07	14.79	14.14	3.78	71867.26	18.39	5.90	1.89	130.13	11.92
22	8.04	75.74	21.64	14.09	3.51	73820.30	20.04	2.28	1.76	127.30	12.06
23	8.96	70.71	16.31	14.08	3.53	73558.28	20.33	7.60	1.76	127.53	12
24	9.42	81.65	12.06	14.43	3.82	71133.12	21.69	4.22	1.91	128.27	12.25
25	7.79	85.81	14.82	15.00	3.70	64070.29	21.88	4.76	1.85	128.96	12.1
26	8.17	85.28	10.94	15.21	3.55	60100.51	22.64	5.96	1.78	128.72	11.77
27	8.60	90.91	10.56	15.28	3.65	59375.07	23.95	4.03	1.83	126.50	11.69
28	9.00	94.06	10.85	15.33	3.63	58337.16	23.94	5.75	1.81	126.56	11.59
29	8.19	83.31	17.75	15.69	2.02	54414.44	25.28	7.43	1.02	126.91	11.55
30	8.56	91.34	9.36	15.20	0.00	56976.55	23.00	4.88	----	127.49	11.1
31											
監測日數	30	30	30	30	30	30	30	30	29	30	30
平均值	8.00	74.12	15.07	13.84	3.30	68340.11	19.39	7.46	1.76	124.59	11.58
最大值	9.42	94.06	24.54	15.69	3.95	77303.17	25.28	17.06	1.98	131.92	12.33
發生日期	24	28	17	29	19	10	29	19	19	10	10
最小值	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.02	0.00	0.00
發生日期	18	18	18	18	18	18	18	18	29	18	18
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管