

連續自動監測紀錄月報表

中華民國112年10月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	6.28	53.79	8.88	12.17	1.19	69312.08	14.37	8.55	0.92	178.94	13.43
02	5.47	50.41	9.65	11.80	1.15	71878.96	14.59	8.71	0.89	179.75	13.43
03	6.16	47.93	10.27	12.61	1.16	69180.97	14.46	8.30	0.89	178.70	14.13
04	5.91	45.72	9.34	12.55	1.13	68644.60	14.66	7.81	0.87	180.86	14.03
05	6.02	50.86	8.54	12.23	1.11	69286.14	14.62	8.62	0.85	182.25	13.66
06	5.50	52.95	8.66	12.14	1.14	69969.48	14.48	8.61	0.88	184.13	13.67
07	5.40	50.41	7.97	11.93	1.14	70847.05	14.90	8.23	0.87	180.89	13.55
08	5.42	50.35	8.71	12.05	1.11	70943.20	14.78	8.58	0.85	181.56	13.71
09	5.62	48.90	7.84	12.06	1.09	70650.02	14.68	8.43	0.84	181.28	13.64
10	5.67	47.89	10.28	12.19	1.07	70159.43	14.92	8.53	0.82	182.38	13.82
11	5.98	47.20	10.63	12.17	1.05	70471.49	14.44	8.68	0.81	181.73	13.75
12	4.25	46.91	9.03	12.07	1.11	70892.71	14.03	8.42	0.85	183.29	13.66
13	2.68	45.12	7.48	12.10	1.11	71010.07	14.34	8.75	0.86	182.35	13.74
14	2.83	41.33	8.16	12.19	1.12	70059.57	14.07	8.46	0.86	180.80	13.61
15	2.80	41.28	8.25	12.18	1.13	70776.64	14.23	8.55	0.87	182.17	13.82
16	3.14	45.87	9.22	12.15	1.16	70045.96	13.49	8.47	0.89	180.01	13.43
17	2.96	48.50	9.45	12.14	1.09	71109.44	13.70	8.47	0.84	181.42	13.70
18	3.33	51.99	7.74	11.41	1.14	75499.91	14.34	8.70	0.88	180.99	13.53
19	2.78	50.67	9.26	10.74	1.19	78727.26	15.34	8.51	0.92	179.55	13.30
20	2.61	49.09	10.01	10.85	1.18	79062.69	15.32	8.72	0.91	179.89	13.50
21	2.64	46.62	9.38	10.97	1.14	79059.20	14.94	8.54	0.88	179.72	13.60
22	2.43	47.07	8.23	10.91	1.14	78856.32	15.44	8.29	0.88	179.91	13.57
23	2.20	39.60	7.07	10.93	1.16	77226.22	15.55	8.00	0.89	179.64	13.34
24	2.05	39.10	8.61	11.10	1.17	75963.97	15.76	8.33	0.90	180.13	13.40
25	2.15	39.21	8.65	11.05	1.19	77165.08	15.99	8.19	0.92	181.81	13.62
26	2.05	38.89	8.85	11.05	1.19	77196.11	15.59	8.17	0.92	181.21	13.54
27	2.52	36.79	9.95	11.58	1.19	74165.15	15.01	8.83	0.92	181.29	13.65
28	2.37	40.21	10.27	11.57	1.16	74778.89	14.94	8.52	0.90	180.03	13.70
29	2.66	37.48	7.99	11.59	1.14	74306.89	14.75	9.21	0.88	180.52	13.63
30	2.95	41.48	9.64	11.56	1.15	73589.00	15.02	8.66	0.89	180.13	13.48
31	2.70	43.00	8.33	11.69	1.15	73472.09	14.78	9.25	0.88	180.94	13.63
監測日數	31	31	31	31	31	30	31	31	31	31	31
平均值	3.79	45.70	8.91	11.73	1.14	73167.35	14.76	8.52	0.88	180.91	13.62
最大值	6.28	53.79	10.63	12.61	1.19	79062.69	15.99	9.25	0.92	184.13	14.13
發生日期											
最小值	2.05	36.79	7.07	10.74	1.05	68644.60	13.49	7.81	0.81	178.70	13.30
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國112年10月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.49	47.64	9.43	10.77	1.16	80532.92	17.37	6.78	0.89	192.98	14.40
02	3.22	46.17	9.28	10.53	1.09	82711.97	17.33	5.51	0.84	195.89	14.54
03	3.01	48.88	10.15	11.05	1.08	79550.62	17.29	4.96	0.83	195.64	14.71
04	3.81	47.66	8.07	10.94	1.20	80025.80	17.62	7.47	0.93	193.59	14.63
05	3.05	45.96	9.74	11.02	1.23	79551.54	17.84	8.06	0.95	193.61	14.70
06	3.52	45.56	9.78	11.35	1.18	77370.30	18.04	8.32	0.91	193.09	14.82
07	3.66	50.90	7.77	11.56	1.19	75210.62	17.56	9.23	0.92	194.67	14.69
08	3.40	48.01	8.84	11.46	1.21	75873.41	17.68	8.21	0.93	193.89	14.64
09	3.52	48.10	8.50	11.39	1.16	76239.86	17.79	8.28	0.89	193.72	14.60
10	3.23	47.34	10.19	11.48	1.17	76429.57	18.07	7.70	0.90	193.87	14.84
11	3.98	43.74	9.23	11.79	1.18	76346.06	17.10	7.77	0.91	190.35	15.03
12	3.21	44.89	9.76	11.31	1.19	77879.91	16.46	9.18	0.92	194.35	14.58
13	2.54	42.69	9.00	11.08	1.22	79846.87	16.83	9.82	0.95	194.21	14.66
14	2.74	39.84	8.13	11.11	1.23	79607.71	16.52	9.18	0.95	192.62	14.57
15	2.60	40.61	9.21	10.97	1.19	80930.61	16.98	8.93	0.92	193.63	14.71
16	2.82	42.84	8.19	11.06	1.21	79705.77	15.98	8.22	0.93	192.39	14.41
17	2.92	44.97	9.16	11.15	1.12	80296.22	16.05	8.68	0.86	193.62	14.70
18	3.75	47.84	9.21	11.09	1.12	80525.59	15.73	8.67	0.86	193.43	14.60
19	3.21	46.59	9.16	11.03	1.11	79550.13	15.87	9.08	0.86	191.45	14.29
20	3.88	44.40	10.46	11.29	1.07	78232.32	15.63	10.53	0.82	191.32	14.39
21	3.73	44.70	8.34	11.28	1.04	79871.07	15.62	10.32	0.80	192.25	14.70
22	3.17	43.21	8.62	11.19	1.01	80419.10	16.22	9.19	0.78	192.77	14.78
23	2.91	38.94	8.97	11.02	1.03	80748.46	16.58	8.99	0.79	193.14	14.67
24	2.76	38.89	8.56	11.21	1.05	79793.45	16.60	9.04	0.80	194.26	14.82
25	2.76	37.41	9.16	11.02	1.03	80982.33	16.98	9.20	0.79	194.33	14.82
26	2.53	37.53	9.07	11.03	1.03	81182.05	16.59	9.35	0.79	193.90	14.79
27	2.89	38.82	9.75	11.10	1.02	82607.03	16.68	9.06	0.79	194.94	15.20
28	2.60	43.29	9.76	11.51	1.04	79866.88	15.73	6.63	0.79	194.03	15.14
29	3.52	42.96	7.76	11.42	1.04	80355.77	15.74	10.01	0.80	194.31	15.10
30	2.88	43.01	8.88	11.41	1.07	79992.91	16.06	8.88	0.82	194.78	15.08
31	2.98	43.00	8.53	11.41	1.04	79949.64	16.10	9.24	0.80	194.63	15.08
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.17	44.08	9.05	11.19	1.12	79425.37	16.73	8.53	0.86	193.60	14.73
最大值	3.98	50.90	10.46	11.79	1.23	82711.97	18.07	10.53	0.95	195.89	15.20
發生日期											
最小值	2.53	37.41	7.76	10.53	1.01	75210.62	15.62	4.96	0.78	190.35	14.29
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管