

# 連續自動監測紀錄月報表

中華民國107年2月28日

			管制編號		F0501686		煙道排放口編		P001		
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	2.93	66.31	20.17	14.78	1.45	65698.72	23.50	10.40	0.73	109.21	11.46
02	1.97	69.97	16.33	14.78	1.59	66400.16	23.71	10.19	0.79	110.55	11.65
03	1.43	70.19	18.36	14.75	1.48	66818.53	23.29	12.99	0.74	109.15	11.60
04	0.65	67.31	17.16	14.81	1.30	65447.73	23.36	10.15	0.65	108.49	11.46
05	1.13	62.50	22.33	14.74	1.34	65147.62	23.68	9.12	0.67	108.34	11.26
06	1.78	66.90	20.75	14.82	1.38	63517.49	23.69	11.32	0.69	108.32	11.13
07	3.85	66.68	19.73	14.74	1.60	65275.23	24.05	17.86	0.80	110.49	11.37
08	3.12	64.66	25.91	14.75	1.68	64110.58	24.21	16.69	0.84	109.47	11.14
09	4.15	68.17	26.34	14.70	2.07	65567.90	24.57	15.19	1.04	112.51	11.40
10	4.14	64.80	19.34	14.90	2.33	63989.03	24.53	14.94	1.17	109.07	11.40
11	3.40	64.80	15.13	15.10	1.84	63431.76	23.07	15.79	0.92	106.92	11.60
12	2.30	61.73	23.45	15.05	1.67	64236.44	22.84	14.16	0.84	106.13	11.62
13	2.50	73.22	19.00	15.29	1.73	62014.75	22.26	17.19	0.86	107.45	11.75
14	5.48	63.17	20.04	15.01	1.71	64643.19	23.00	18.17	0.86	108.57	11.71
15	6.01	62.84	24.10	14.99	1.78	64730.24	21.68	18.67	0.89	109.78	11.72
16	6.62	58.53	27.58	14.92	2.18	65259.39	22.61	17.88	1.09	109.44	11.66
17	4.90	62.75	19.63	14.72	2.20	66498.84	21.83	19.41	1.10	111.89	11.58
18	6.98	58.16	25.78	14.62	2.33	66424.69	22.50	16.87	1.16	113.57	11.44
19	5.84	60.01	25.27	14.70	2.22	64953.36	22.79	14.47	1.11	112.95	11.30
20	7.14	51.37	25.23	14.63	2.22	65347.30	23.62	11.05	1.11	112.56	11.22
21	3.51	56.20	16.24	14.89	2.19	63222.67	22.45	11.22	1.10	111.03	11.28
22	3.31	57.72	19.00	14.88	1.88	63225.10	22.52	10.27	0.94	110.93	11.27
23	3.24	58.07	16.88	14.80	1.84	63722.56	23.04	10.21	0.92	111.48	11.23
24	7.27	63.53	23.30	14.81	1.92	61276.01	23.80	12.37	0.96	113.21	10.87
25	3.06	55.62	10.59	14.89	1.67	62171.55	23.24	11.90	0.84	110.92	11.10
26	3.04	50.25	13.91	14.69	1.78	64255.40	23.42	9.72	0.89	111.36	11.12
27	6.19	52.83	17.48	14.74	1.97	63360.22	23.76	9.53	0.99	112.96	11.09
28	5.13	51.18	14.12	14.73	2.22	63609.03	23.74	9.44	1.11	111.97	11.09
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	3.97	61.77	20.11	14.83	1.84	64441.27	23.24	13.47	0.92	110.31	11.38
最大值	7.27	73.22	27.58	15.29	2.33	66818.53	24.57	19.41	1.17	113.57	11.75
發生日期											
最小值	0.65	50.25	10.59	14.62	1.30	61276.01	21.68	9.12	0.65	106.13	10.87
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國107年2月28日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	7.52	65.23	15.06	14.48	2.72	71700.83	20.87	4.24	1.36	117.32	12.29
02	7.41	68.79	18.07	14.45	2.75	71985.70	21.19	2.89	1.37	117.45	12.30
03	6.98	79.75	11.92	14.38	2.73	70436.99	21.15	5.67	1.36	116.17	12.04
04	5.86	76.65	12.75	14.54	2.76	70815.47	21.50	4.81	1.38	115.88	12.21
05	5.53	73.78	15.64	14.47	2.74	71800.47	21.88	6.79	1.37	115.89	12.23
06	6.13	73.98	16.28	14.41	2.76	72383.11	21.26	7.86	1.38	117.13	12.26
07	7.21	73.66	19.04	14.43	2.75	71362.74	21.53	7.44	1.38	117.89	12.16
08	6.84	69.27	15.66	14.35	2.74	71489.15	21.51	13.54	1.37	117.94	12.02
09	7.07	68.36	18.40	14.30	2.75	71785.64	20.72	10.09	1.38	119.85	12.05
10	7.31	66.04	21.27	14.22	2.73	72232.57	20.78	8.03	1.37	120.17	12.00
11	6.70	68.70	11.09	14.34	2.70	70231.67	22.43	8.63	1.35	118.06	11.80
12	6.82	70.54	14.10	14.42	2.75	69960.11	21.76	8.61	1.38	118.57	11.91
13	7.97	67.95	17.02	14.30	2.72	70549.58	22.99	18.46	1.36	119.36	11.82
14	8.17	68.15	16.86	14.33	2.74	70988.00	21.87	14.23	1.37	119.90	11.96
15	8.60	65.40	20.32	14.33	2.75	71426.56	21.53	11.72	1.38	120.88	12.07
16	7.36	67.50	21.05	14.23	2.76	72637.14	20.10	6.70	1.38	120.78	12.09
17	7.65	70.69	17.88	14.24	2.73	71583.75	21.80	11.49	1.36	119.99	11.90
18	7.74	66.90	15.65	14.14	2.73	72735.77	20.90	7.93	1.36	120.78	11.95
19	7.31	74.65	10.08	14.41	2.75	70179.09	20.70	6.01	1.38	120.29	11.99
20	7.17	67.36	15.01	14.20	2.77	72669.42	19.39	1.97	1.38	120.62	12.04
21	6.63	66.38	14.91	14.24	2.77	72708.16	20.63	3.84	1.39	119.80	12.08
22	6.70	72.03	11.00	14.19	2.79	72055.40	20.04	2.86	1.40	120.38	11.93
23	6.75	74.85	14.19	14.18	2.80	72471.96	19.31	7.19	1.40	121.01	11.99
24	6.83	72.13	11.48	14.04	2.82	73728.38	18.80	4.38	1.41	121.66	11.98
25	6.30	71.01	11.95	14.19	2.82	72852.09	19.68	6.00	1.41	120.32	12.04
26	6.52	67.21	11.72	14.16	2.81	72907.50	19.53	5.44	1.40	119.95	11.99
27	7.46	62.69	12.58	14.04	2.82	73119.14	19.19	11.41	1.41	120.89	11.84
28	6.63	69.86	12.72	14.18	2.83	72577.30	19.09	11.81	1.41	120.09	11.97
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	7.04	69.98	15.13	14.29	2.76	71834.77	20.79	7.86	1.38	119.25	12.03
最大值	8.60	79.75	21.27	14.54	2.83	73728.38	22.99	18.46	1.41	121.66	12.30
發生日期											
最小值	5.53	62.69	10.08	14.04	2.70	69960.11	18.80	1.97	1.35	115.88	11.80
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管