

連續自動監測紀錄月報表

中華民國115年6月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂ 二氧化 硫	NO _x 氮氧化 物	CO 一氧化 碳	O ₂ 氧氣	DUST 粉塵濃 度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光 率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	2.97	60.71	13.39	10.91	1.13	74640.70	19.99	8.87	0.87	184.58	13.71
02	2.63	60.02	12.23	11.04	1.16	74653.32	20.20	8.50	0.89	187.08	14.01
03	3.62	58.65	13.10	10.90	1.15	74512.13	20.27	9.17	0.88	186.01	13.78
04	2.73	63.18	12.82	10.80	1.12	75269.24	20.02	9.00	0.86	184.98	13.71
05	1.76	59.10	13.00	10.76	1.04	76295.33	20.45	9.19	0.80	186.28	13.95
06	1.29	54.79	13.21	10.72	1.04	76977.93	20.69	8.80	0.80	187.13	14.08
07	1.35	52.76	12.84	10.60	1.08	76652.40	20.96	8.75	0.83	186.68	13.90
08	0.91	55.71	11.87	10.54	1.07	77184.91	21.02	8.71	0.82	189.12	13.99
09	0.99	55.13	13.54	10.62	1.08	77447.71	21.24	8.98	0.83	187.88	14.16
10	1.28	55.34	12.39	11.01	1.09	75083.27	20.93	9.64	0.84	189.25	14.26
11	1.38	51.79	12.59	10.78	1.16	74729.01	21.13	9.55	0.89	193.01	14.02
12	0.89	53.24	13.06	10.62	1.15	76723.98	21.30	9.75	0.88	198.28	14.35
13	0.71	54.50	14.11	10.57	1.12	76756.39	21.77	9.09	0.87	201.29	14.47
14	0.69	52.59	13.43	10.46	1.11	77097.93	22.13	9.72	0.86	203.67	14.52
15	0.99	49.39	12.21	10.77	1.12	77316.32	21.33	8.55	0.86	200.75	14.78
16	0.35	48.73	12.63	10.26	1.12	78973.60	22.00	9.43	0.87	209.15	14.75
17	0.92	52.47	12.17	10.39	1.10	77989.81	21.57	8.61	0.84	199.34	14.36
18	0.93	49.85	12.59	10.33	1.08	78303.00	21.52	9.28	0.83	195.96	14.23
19	0.51	51.02	12.91	10.22	1.09	78926.85	22.17	9.20	0.84	202.87	14.52
20	0.82	48.61	11.15	10.16	1.07	78729.82	22.27	8.53	0.82	206.15	14.53
21	0.83	49.56	14.23	10.06	1.10	79154.45	21.96	7.95	0.84	208.18	14.50
22	0.88	50.07	13.07	10.08	1.08	78863.52	21.23	9.01	0.83	208.35	14.31
23	0.78	48.58	12.85	10.19	1.07	78604.66	21.31	10.59	0.82	210.51	14.50
24	1.01	50.04	11.72	10.32	1.09	77960.40	21.00	9.86	0.83	203.01	14.27
25	1.20	53.26	13.96	10.47	1.05	76632.08	20.80	10.01	0.80	188.79	13.76
26	0.71	54.21	13.01	10.48	1.05	77999.37	21.18	10.34	0.80	195.10	14.28
27	0.59	54.86	12.23	10.27	1.04	78498.65	21.99	10.34	0.80	193.60	14.19
28	0.49	54.25	12.49	10.28	1.06	78532.16	21.82	9.82	0.81	195.35	14.23
29	0.42	53.32	12.16	10.20	1.08	78629.60	21.32	10.61	0.83	200.77	14.22
30	0.31	53.56	13.15	10.13	1.07	78782.71	21.85	8.98	0.82	204.35	14.36
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	1.16	53.64	12.80	10.50	1.09	77264.04	21.25	9.29	0.84	196.25	14.22
最大值	3.62	63.18	14.23	11.04	1.16	79154.45	22.27	10.61	0.89	210.51	14.78
發生日期											
最小值	0.31	48.58	11.15	10.06	1.04	74512.13	19.99	7.95	0.80	184.58	13.71
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國115年6月30日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂ 二氧化 硫	NO _x 氮氧化 物	CO 一氧化 碳	O ₂ 氧氣	DUST 粉塵濃 度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光 率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	3.21	52.91	12.31	9.98	0.85	75039.62	22.07	8.89	0.65	185.20	12.49
02	3.09	54.05	11.21	10.24	0.85	75064.68	22.82	8.29	0.65	187.91	12.99
03	3.70	53.05	13.36	10.29	0.82	74534.38	22.34	9.02	0.62	187.82	12.90
04	3.10	56.25	13.34	10.20	0.79	75228.15	21.96	8.87	0.60	186.02	12.79
05	3.48	48.30	12.88	9.92	0.78	76509.81	22.81	8.98	0.59	186.52	12.83
06	2.68	48.77	12.96	9.89	0.76	77132.29	22.94	8.93	0.59	187.24	12.94
07	2.85	47.28	13.07	9.66	0.76	76830.25	23.33	9.60	0.58	186.32	12.66
08	2.66	48.76	12.59	9.58	0.75	77768.50	23.53	8.96	0.58	186.47	12.77
09	1.53	50.91	12.66	9.74	0.75	77676.39	23.53	7.54	0.58	187.59	12.96
10	1.73	51.82	11.92	9.83	0.78	78417.34	23.01	9.04	0.59	191.00	13.19
11	1.52	54.52	12.59	9.99	0.77	77947.77	22.72	8.92	0.59	197.84	13.46
12	1.35	53.44	12.56	10.26	0.79	75953.13	23.07	9.25	0.60	202.84	13.65
13	1.36	51.38	13.14	9.92	0.84	77037.85	23.68	9.04	0.64	205.54	13.59
14	1.67	48.08	13.32	9.63	0.89	78835.65	24.26	8.99	0.68	208.31	13.75
15	1.32	47.36	11.53	9.62	0.94	78099.05	24.01	8.86	0.72	209.31	13.59
16	1.43	50.22	11.29	10.28	0.95	78240.70	23.07	8.78	0.74	209.77	14.31
17	2.15	48.74	11.68	9.72	0.92	77869.69	23.29	8.69	0.71	202.36	13.36
18	1.84	51.55	11.26	9.86	0.91	77559.93	23.10	8.35	0.70	200.72	13.38
19	0.98	51.81	11.91	9.84	0.89	77780.90	23.99	8.77	0.68	207.45	13.73
20	1.22	49.45	12.73	9.78	0.84	78373.86	23.84	8.24	0.64	211.21	13.85
21	1.47	50.87	12.84	9.65	0.82	79347.17	23.42	8.38	0.63	214.12	13.87
22	1.49	53.84	11.20	9.66	0.84	78922.87	22.78	8.58	0.64	213.99	13.69
23	1.00	54.86	12.02	9.90	0.88	78329.99	22.97	9.01	0.67	217.30	14.02
24	1.53	53.92	12.18	9.85	0.85	77918.50	22.57	8.96	0.65	210.46	13.62
25	1.70	57.77	12.78	9.99	0.82	77334.92	22.35	9.18	0.62	194.94	13.22
26	1.09	56.43	12.79	10.01	0.82	78490.58	22.87	9.04	0.63	203.44	13.76
27	0.95	56.68	12.56	9.94	0.81	78201.24	23.50	9.15	0.61	201.59	13.68
28	1.11	56.31	12.94	9.86	0.82	78763.11	23.42	9.03	0.62	201.95	13.68
29	0.83	59.24	13.35	9.75	0.80	78194.86	22.72	9.05	0.61	206.63	13.45
30	0.72	59.12	13.33	9.74	0.78	78416.92	23.15	9.11	0.60	212.11	13.71
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	1.83	52.59	12.48	9.89	0.83	77527.34	23.10	8.85	0.63	200.13	13.40
最大值	3.70	59.24	13.36	10.29	0.95	79347.17	24.26	9.60	0.74	217.30	14.31
發生日期											
最小值	0.72	47.28	11.20	9.58	0.75	74534.38	21.96	7.54	0.58	185.20	12.49
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											
廠長			維修組長			操作組長			值班主管		