

# 連續自動監測紀錄月報表

中華民國110年9月30日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	3.51	61.69	9.15	9.40	1.41	83191.69	18.41	11.94	0.94	180.22	12.92
02	3.49	60.14	7.06	9.35	1.39	83040.82	18.84	11.57	0.93	180.03	12.90
03	3.03	62.34	7.97	9.42	1.39	84528.34	19.29	12.07	0.92	183.05	13.37
04	2.97	60.47	8.32	9.43	1.39	84752.99	19.17	12.50	0.92	182.83	13.39
05	3.26	62.31	7.71	9.37	1.43	83905.68	19.08	12.40	0.95	181.98	13.16
06	2.92	59.77	8.13	9.18	1.51	83982.34	19.21	12.04	1.00	181.09	12.95
07	2.60	62.24	7.00	9.31	1.57	84032.80	19.96	12.08	1.05	182.52	13.26
08	3.15	58.86	7.25	9.30	1.76	83742.64	19.41	11.77	1.18	181.81	13.09
09	3.01	58.92	6.66	9.25	1.77	84524.94	19.00	12.16	1.18	182.32	13.12
10	2.81	61.70	8.91	9.23	1.78	85039.05	19.38	12.37	1.19	183.26	13.26
11	2.62	59.40	11.26	9.37	1.76	84131.32	19.23	12.43	1.17	181.79	13.21
12	2.42	59.86	10.16	9.40	1.75	84878.09	19.72	12.09	1.17	182.39	13.46
13	2.63	60.36	8.72	9.13	1.78	83652.87	19.27	11.91	1.19	180.29	12.83
14	2.68	61.21	7.40	9.15	1.73	83174.57	19.32	11.44	1.16	179.85	12.78
15	2.96	60.02	8.27	9.27	1.75	82322.35	18.71	11.76	1.16	179.04	12.66
16	3.28	60.87	7.87	9.25	1.73	82763.76	18.78	12.07	1.15	178.63	12.71
17	2.68	61.08	7.11	9.22	1.70	83160.80	19.53	11.51	1.13	180.34	12.90
18	2.85	62.25	7.57	9.31	1.70	82902.63	19.03	12.10	1.13	180.25	12.88
19	2.77	61.43	7.43	9.25	1.71	83137.18	19.50	11.86	1.14	181.01	12.94
20	2.78	61.54	8.07	9.20	1.70	83395.23	19.16	11.78	1.13	180.25	12.85
21	2.72	60.60	6.28	9.22	1.70	83166.36	19.51	11.31	1.13	180.30	12.89
22	2.88	63.22	5.86	9.37	1.68	82345.54	18.91	10.87	1.12	179.97	12.83
23	2.87	64.12	5.64	9.29	1.67	82253.64	18.60	11.40	1.11	178.93	12.65
24	2.70	62.87	6.08	9.32	1.74	81794.93	18.90	11.17	1.16	179.34	12.66
25	3.07	62.62	7.46	9.34	1.74	82793.65	18.77	11.91	1.16	179.40	12.83
26	3.20	59.61	6.83	9.28	1.73	82719.60	19.33	10.64	1.15	180.16	12.85
27	3.33	61.96	7.70	9.27	1.71	81825.78	18.76	11.52	1.14	178.38	12.56
28	2.54	61.59	8.76	9.36	1.67	82855.71	19.15	11.21	1.12	180.82	12.95
29	2.84	59.26	8.20	9.18	1.67	82444.17	19.10	11.64	1.11	178.72	12.64
30	2.68	58.85	8.14	9.03	1.69	82890.54	18.70	11.85	1.13	178.06	12.46
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	2.91	61.04	7.77	9.28	1.66	83311.67	19.12	11.78	1.10	180.57	12.93
最大值	3.51	64.12	11.26	9.43	1.78	85039.05	19.96	12.50	1.19	183.26	13.46
發生日期											
最小值	2.42	58.85	5.64	9.03	1.39	81794.93	18.41	10.64	0.92	178.06	12.46
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國110年9月30日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	5.18	64.12	11.25	10.29	1.53	82919.75	17.77	12.35	1.02	194.72	14.29
02	4.93	64.44	10.99	10.22	1.55	83540.15	18.41	12.26	1.04	194.83	14.41
03	4.63	64.61	11.75	10.23	1.63	84115.37	18.80	12.46	1.08	196.64	14.65
04	4.43	62.68	10.03	10.27	1.65	83760.30	18.56	12.67	1.10	195.38	14.56
05	4.59	58.70	9.19	10.15	1.57	83014.58	18.73	12.48	1.04	194.22	14.27
06	4.40	58.84	10.33	9.97	1.56	84064.84	18.97	12.33	1.04	194.17	14.25
07	4.03	63.09	9.57	10.18	1.61	83693.04	19.51	12.22	1.07	196.33	14.62
08	4.73	59.71	10.50	10.12	1.69	83699.62	18.99	12.45	1.12	195.20	14.43
09	4.57	61.44	9.54	10.22	1.66	83340.46	18.51	12.44	1.11	194.99	14.40
10	4.71	63.23	9.90	10.19	1.66	873793.50	18.95	12.68	1.11	196.17	14.56
11	4.35	60.98	11.41	10.24	1.65	82595.47	18.89	12.63	1.10	193.99	14.33
12	4.50	59.04	10.93	10.25	1.66	82991.93	19.29	12.35	1.11	193.99	14.50
13	4.56	59.90	10.08	10.05	1.68	82357.41	18.92	12.24	1.12	193.09	14.02
14	4.18	60.85	9.62	9.99	1.66	81893.77	19.29	12.13	1.11	192.13	13.91
15	4.58	58.69	10.64	10.03	1.64	81858.97	18.68	12.62	1.09	191.76	13.84
16	4.09	60.20	9.60	10.26	1.65	82191.82	18.15	11.81	1.10	191.31	14.09
17	4.01	59.60	10.94	10.11	1.66	83054.58	19.20	12.17	1.11	194.46	14.31
18	4.47	66.20	9.60	10.25	1.68	82930.60	18.88	12.03	1.12	195.21	14.45
19	4.10	65.20	10.18	10.22	1.68	82637.46	18.93	12.03	1.12	195.00	14.35
20	4.30	62.12	11.04	10.11	1.67	82644.83	18.88	12.16	1.12	194.22	14.18
21	4.30	61.63	9.47	10.18	1.66	82118.18	19.20	11.34	1.11	194.17	14.22
22	4.33	59.22	10.50	10.02	1.73	82456.91	19.13	11.48	1.15	196.25	14.14
23	4.64	59.76	9.32	10.08	1.70	81855.86	18.63	12.17	1.13	192.72	13.91
24	4.49	58.00	10.44	10.02	1.70	82336.66	18.98	12.22	1.13	193.13	13.99
25	4.57	60.50	9.98	10.22	1.70	82348.47	18.59	11.94	1.14	193.47	14.20
26	4.36	59.33	8.82	10.20	1.67	82948.47	18.94	11.51	1.12	194.83	14.37
27	4.69	58.61	10.43	10.22	1.63	82280.81	18.63	12.29	1.09	194.49	14.22
28	4.34	59.61	10.44	10.20	1.55	83492.04	19.07	11.96	1.03	195.27	14.50
29	4.06	58.74	10.02	10.13	1.52	82398.61	18.80	11.32	1.01	193.49	14.12
30	4.03	59.68	8.69	10.14	1.54	81940.26	18.13	11.85	1.03	192.71	13.92
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	4.44	60.96	10.17	10.16	1.64	109175.82	18.81	12.15	1.09	194.28	14.27
最大值	5.18	66.20	11.75	10.29	1.73	873793.50	19.51	12.68	1.15	196.64	14.65
發生日期											
最小值	4.01	58.00	8.69	9.97	1.52	81855.86	17.77	11.32	1.01	191.31	13.84
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管