

# 連續自動監測紀錄月報表

中華民國108年7月31

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	11.33	68.48	22.24	10.34	2.48	86540.01	18.57	11.07	1.03	151.67	13.68
02	11.99	92.64	19.80	10.67	2.42	84010.21	16.32	15.87	1.01	148.76	13.29
03	12.62	95.11	15.30	10.73	2.43	82824.70	16.85	25.64	1.01	154.43	13.44
04	10.49	91.81	13.96	10.48	2.43	83055.22	17.07	16.36	1.01	154.64	13.19
05	9.47	105.24	8.35	11.49	2.46	76904.23	17.14	14.23	1.03	165.52	13.87
06	10.34	96.10	13.21	11.21	2.44	77726.67	18.60	15.69	1.01	166.52	13.90
07	11.06	94.32	10.25	11.00	2.47	77747.16	18.84	14.88	1.03	151.18	13.19
08	9.65	95.46	8.94	11.34	2.46	75174.06	18.27	16.82	1.03	157.22	13.30
09	10.43	102.35	8.43	11.48	2.46	77991.68	18.53	15.17	1.03	152.89	13.90
10	13.72	95.16	14.14	11.16	2.37	77830.68	18.00	14.97	0.99	151.33	13.27
11	12.19	96.97	12.48	10.94	2.28	79180.82	18.29	13.61	0.95	149.00	13.19
12	11.36	97.61	13.46	11.12	2.28	80445.69	17.74	16.69	0.95	156.85	13.80
13	10.34	93.50	11.98	11.19	2.37	78128.48	16.49	17.80	0.99	170.29	13.73
14	11.04	93.46	12.69	11.12	2.37	80378.03	17.87	18.46	0.99	155.03	13.76
15	9.58	93.51	9.35	11.20	2.33	79265.41	18.08	13.62	0.97	150.51	13.57
16	10.58	102.39	9.09	11.49	2.32	79245.77	16.92	14.38	0.97	159.54	14.07
17	10.16	98.00	7.09	11.39	2.35	79217.84	15.93	16.51	0.98	173.20	14.18
18	10.00	100.64	6.91	11.24	2.30	80303.61	17.50	14.73	0.96	158.87	13.96
19	9.93	100.78	9.39	11.41	2.25	79525.56	18.50	10.82	0.94	146.72	13.85
20	9.66	102.49	5.33	11.45	2.25	78621.63	18.13	11.02	0.94	146.29	13.68
21	9.79	98.28	4.81	11.30	2.24	78948.74	17.98	13.05	0.94	147.31	13.53
22	9.25	96.06	7.73	11.08	2.24	80385.40	16.52	16.50	0.93	174.74	14.09
23	9.25	102.17	4.06	11.20	2.28	79821.63	16.53	15.88	0.95	176.37	14.22
24	10.73	83.62	16.16	11.30	2.27	80165.19	16.49	17.02	0.95	176.78	14.45
25	10.84	67.25	14.68	11.11	2.22	81847.09	16.92	22.45	0.93	179.08	14.62
26	11.24	84.01	9.80	11.17	2.22	81489.56	16.89	20.87	0.92	178.63	14.61
27	10.63	71.14	11.30	11.06	2.18	81577.45	16.91	16.33	0.91	176.92	14.41
28	11.00	83.23	4.50	11.02	2.15	81163.78	17.40	15.47	0.90	163.06	13.92
29	10.91	105.28	2.34	10.98	2.21	80884.66	15.88	18.94	0.92	174.52	13.92
30	10.32	106.23	5.15	11.08	2.26	81137.08	16.19	15.86	0.94	175.78	14.20
31	10.40	100.25	7.23	11.13	2.26	80315.81	15.95	16.98	0.94	174.78	14.06
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	10.65	93.99	10.33	11.13	2.32	80059.80	17.33	16.05	0.97	161.88	13.83
最大值	13.72	106.23	22.24	11.49	2.48	86540.01	18.84	25.64	1.03	179.08	14.62
發生日期											
最小值	9.25	67.25	2.34	10.34	2.15	75174.06	15.88	10.82	0.90	146.29	13.19
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國108年7月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機
02	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機
03	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機
04	19.00	105.59	32.04	12.05	2.78	68817.27	15.21	14.55	1.16	152.93	12.53
05	16.35	104.41	25.96	11.39	2.57	70961.39	16.98	13.32	1.07	145.70	12.12
06	13.72	98.80	18.50	11.36	2.69	70922.46	15.86	14.61	1.12	169.78	12.56
07	14.56	96.87	26.44	11.29	2.73	73670.98	17.52	17.38	1.14	156.49	12.82
08	12.61	92.55	17.50	11.28	2.76	74155.80	17.59	17.26	1.15	156.53	12.93
09	14.45	101.55	24.84	11.47	2.78	74133.76	17.63	16.96	1.16	150.52	12.98
10	16.77	101.25	26.70	11.47	2.72	74680.66	17.49	14.52	1.13	151.63	13.08
11	14.78	102.70	22.61	11.21	2.80	77876.12	17.94	16.02	1.16	150.22	13.31
12	15.40	102.20	19.35	11.37	2.91	78873.28	17.09	16.60	1.21	162.18	13.95
13	12.87	94.59	24.54	11.43	3.07	77727.07	15.83	13.54	1.28	187.78	14.43
14	13.44	91.42	25.66	11.23	3.12	79572.24	18.42	17.49	1.30	161.62	14.07
15	13.82	95.30	24.50	11.22	3.06	80746.10	18.75	17.11	1.28	155.69	14.12
16	14.19	101.17	17.22	11.67	2.96	77376.29	17.21	15.27	1.23	166.08	14.27
17	13.54	96.77	17.10	11.61	2.91	77999.56	16.04	14.45	1.21	182.17	14.63
18	14.22	101.76	13.49	11.36	2.94	78899.57	17.86	13.58	1.22	164.77	14.18
19	13.98	103.31	11.56	11.38	2.94	74543.36	18.19	12.33	1.22	154.04	13.15
20	15.67	107.01	9.25	11.75	2.86	75668.36	17.69	13.30	1.19	150.65	13.65
21	13.09	95.05	11.72	11.17	2.91	73099.27	18.10	8.71	1.21	149.43	12.47
22	10.79	87.38	10.07	10.67	3.03	68560.90	16.76	12.21	1.26	182.14	11.79
23	11.93	92.61	11.58	10.88	3.09	70779.99	16.80	15.78	1.29	188.15	12.60
24	13.28	86.99	22.40	11.45	3.08	72210.09	15.86	15.56	1.28	183.52	13.32
25	14.07	103.02	16.73	11.34	3.10	73758.04	15.90	19.19	1.29	182.50	13.43
26	14.41	109.32	17.03	11.29	3.13	75517.98	16.32	18.36	1.30	184.42	13.79
27	13.50	105.00	17.95	11.21	3.19	75934.15	16.54	16.12	1.33	184.16	13.78
28	14.63	99.00	20.49	10.98	3.18	77512.09	18.61	17.71	1.33	171.62	13.71
29	13.50	100.27	20.22	11.04	3.21	76240.28	17.02	16.06	1.34	187.20	13.76
30	13.89	115.19	13.73	11.13	3.11	75272.46	17.16	13.53	1.30	186.67	13.72
31	13.40	110.25	15.60	11.19	3.02	75190.58	16.11	15.11	1.26	188.46	13.68
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	14.14	100.05	19.10	11.32	2.95	75025.00	17.09	15.24	1.23	168.11	13.39
最大值	19.00	115.19	32.04	12.05	3.21	80746.10	18.75	19.19	1.34	188.46	14.63
發生日期											
最小值	10.79	86.99	9.25	10.67	2.57	68560.90	15.21	8.71	1.07	145.70	11.79
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管