

連續自動監測紀錄月報表

中華民國108年12月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	9.43	55.03	3.60	10.93	2.16	78462.46	16.60	13.84	0.90	172.58	13.50
02	9.43	56.76	2.98	10.95	2.17	80273.93	16.11	12.68	0.90	173.01	13.77
03	9.58	57.30	4.56	11.08	2.17	78279.84	15.86	13.68	0.90	170.41	13.48
04	9.14	57.09	5.54	11.11	2.20	78413.53	15.90	10.92	0.92	171.15	13.57
05	9.43	58.36	4.20	10.96	2.30	80366.37	16.53	13.43	0.96	172.13	13.84
06	8.04	62.92	4.02	11.25	2.27	79335.51	16.36	13.42	0.94	172.94	14.09
07	6.36	61.03	3.64	10.97	2.21	80615.79	16.60	14.78	0.92	172.14	13.90
08	6.36	61.98	3.94	10.76	2.26	81786.45	16.52	14.60	0.94	171.84	13.79
09	6.13	63.91	3.37	10.96	2.26	80541.62	16.53	14.43	0.94	177.02	14.02
10	6.31	63.63	3.52	11.08	2.27	80298.86	16.80	14.66	0.95	176.07	14.16
11	6.68	63.38	4.32	11.26	2.28	78860.05	16.20	14.76	0.95	176.12	14.05
12	6.58	63.70	6.00	11.08	2.30	79998.73	15.71	14.46	0.96	180.33	14.07
13	6.55	63.51	5.90	11.00	2.37	81879.87	16.26	14.83	0.99	178.75	14.32
14	6.30	63.98	5.20	11.05	2.39	80652.73	16.46	14.85	0.99	182.03	14.30
15	6.32	63.59	5.21	10.73	2.37	82204.75	16.97	14.88	0.99	180.82	14.19
16	6.18	62.26	4.05	10.83	2.28	81092.36	17.20	14.55	0.95	176.64	14.03
17	6.95	62.43	5.34	11.25	2.22	77820.74	16.42	14.87	0.93	173.86	13.83
18	7.18	63.63	4.89	11.02	2.23	80874.21	16.25	14.87	0.93	175.22	14.05
19	7.10	63.96	7.38	11.23	2.26	78901.76	15.83	14.88	0.94	174.08	13.90
20	6.84	63.42	9.46	11.02	2.23	81958.40	16.39	13.91	0.93	174.72	14.26
21	6.74	63.41	10.44	10.97	2.26	82475.56	16.63	14.92	0.94	176.93	14.39
22	6.54	63.41	6.70	10.76	2.23	83776.75	17.24	14.37	0.93	178.00	14.45
23	6.38	63.52	7.33	10.84	2.23	82420.39	16.79	14.20	0.93	177.19	14.24
24	6.18	63.30	5.56	10.99	2.23	81234.22	16.94	14.14	0.93	176.53	14.24
25	6.26	63.47	9.14	10.97	2.25	81283.77	16.90	13.56	0.94	176.58	14.22
26	6.33	63.53	6.81	10.91	2.23	82281.64	16.57	13.81	0.93	175.95	14.23
27	6.72	63.10	7.74	11.09	2.20	82047.47	15.76	13.31	0.91	173.94	14.25
28	6.62	63.30	8.69	11.04	2.21	81190.75	16.32	13.67	0.92	174.20	14.13
29	6.27	62.38	8.67	10.81	2.26	83496.94	17.02	13.01	0.94	177.46	14.43
30	6.14	62.51	5.57	10.76	2.28	82516.52	17.38	12.88	0.95	176.55	14.21
31	6.24	62.38	6.20	10.90	2.22	82923.35	16.91	12.28	0.93	175.77	14.38
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	7.01	62.13	5.81	10.99	2.25	80911.78	16.51	13.98	0.94	175.51	14.07
最大值	9.58	63.98	10.44	11.26	2.39	83776.75	17.38	14.92	0.99	182.03	14.45
發生日期											
最小值	6.13	55.03	2.98	10.73	2.16	77820.74	15.71	10.92	0.90	170.41	13.48
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國108年12月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	8.08	56.99	11.17	11.25	2.78	78651.88	16.41	12.20	1.16	198.98	14.77
02	7.96	57.09	11.95	11.14	2.86	78490.38	16.21	10.87	1.19	197.41	14.50
03	8.96	58.62	11.66	11.41	2.94	77904.61	15.66	12.53	1.23	186.35	14.36
04	9.04	58.71	11.58	11.40	3.03	79197.78	15.82	12.73	1.26	189.57	14.71
05	8.49	60.71	7.72	11.35	2.98	79867.02	16.23	11.04	1.24	192.80	14.93
06	6.94	63.18	9.24	11.36	2.85	79845.93	16.70	11.77	1.19	196.33	15.14
07	5.41	60.69	7.90	11.35	2.89	80497.16	16.25	14.48	1.20	190.91	14.99
08	5.54	63.42	8.49	11.25	2.83	80570.56	16.54	14.37	1.18	186.29	14.77
09	5.30	64.02	8.59	11.20	2.72	80155.06	16.39	14.43	1.13	188.39	14.62
10	5.46	64.33	8.92	11.38	2.69	79106.86	16.39	14.42	1.12	188.32	14.71
11	5.93	65.33	10.90	11.41	2.63	78798.87	16.02	14.56	1.10	189.19	14.65
12	5.77	63.87	9.17	11.23	2.66	79480.88	15.92	14.34	1.11	186.73	14.41
13	5.84	66.68	10.90	11.37	2.75	79856.54	15.75	14.86	1.15	189.53	14.75
14	5.66	64.82	7.77	11.45	2.81	78925.45	16.04	14.80	1.17	188.65	14.68
15	5.75	64.33	9.05	11.17	2.84	80074.44	16.37	14.81	1.18	190.22	14.64
16	6.54	65.33	7.09	11.31	2.74	79810.45	17.16	11.57	1.14	175.03	14.43
17	8.94	64.03	9.49	11.55	2.70	77797.55	15.60	14.07	1.12	187.53	14.56
18	9.67	67.09	8.77	11.43	2.81	78374.11	15.42	13.42	1.17	186.75	14.45
19	8.74	64.43	10.08	11.44	2.89	77647.88	15.52	14.76	1.20	184.14	14.25
20	7.19	66.66	9.87	11.43	2.88	77938.27	16.04	13.23	1.20	186.26	14.45
21	6.95	66.66	10.01	11.35	2.99	78364.69	16.14	12.85	1.24	187.27	14.45
22	6.34	65.10	8.66	11.30	3.02	78786.71	16.24	14.38	1.26	189.38	14.54
23	5.81	64.32	8.12	11.25	2.98	78440.31	16.19	14.71	1.24	188.87	14.38
24	5.61	64.08	8.05	11.28	3.06	78173.65	16.56	14.55	1.27	191.07	14.51
25	5.53	63.37	10.26	11.18	3.06	78680.86	16.51	13.97	1.27	192.77	14.49
26	5.95	63.42	9.53	11.22	2.95	79309.73	16.10	13.84	1.23	192.37	14.59
27	5.95	63.80	10.09	11.40	2.82	79136.26	15.44	12.96	1.17	189.94	14.63
28	6.16	64.42	9.86	11.32	2.83	78165.90	15.54	13.65	1.18	186.48	14.25
29	5.89	63.11	8.42	11.16	2.81	79372.01	16.42	13.52	1.17	189.27	14.46
30	5.82	63.34	8.78	11.22	2.89	78408.89	16.39	13.39	1.21	188.98	14.36
31	5.28	64.86	6.93	11.28	2.83	78865.35	16.41	13.08	1.18	189.11	14.55
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	6.66	63.45	9.32	11.32	2.86	78990.19	16.14	13.55	1.19	189.19	14.58
最大值	9.67	67.09	11.95	11.55	3.06	80570.56	17.16	14.86	1.27	198.98	15.14
發生日期											
最小值	5.28	56.99	6.93	11.14	2.63	77647.88	15.42	10.87	1.10	175.03	14.25
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管