

連續自動監測紀錄月報表

中華民國112年5月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	5.08	53.25	5.97	10.93	1.95	77910.83	16.08	10.12	1.30	177.89	13.47
02	4.71	53.90	6.57	10.89	1.98	77493.50	16.82	10.43	1.32	180.07	13.54
03	4.81	54.05	8.42	10.85	1.93	77152.97	16.87	11.35	1.29	178.99	13.40
04	5.21	55.08	5.85	10.84	1.91	76382.23	16.68	12.74	1.27	177.64	13.19
05	4.71	55.57	7.03	10.90	1.87	76841.61	17.10	10.87	1.25	179.06	13.46
06	4.90	52.82	6.10	11.05	1.82	75592.04	16.71	10.76	1.21	178.37	13.35
07	5.13	53.80	6.32	11.71	1.77	77067.15	16.79	11.71	1.18	178.15	13.47
08	5.07	50.88	5.93	10.75	1.72	78488.58	16.59	10.73	1.15	176.84	13.39
09	4.45	50.69	6.83	11.02	1.79	77771.18	16.37	10.14	1.19	178.57	13.64
10	4.77	52.38	7.02	11.06	1.86	78490.86	16.45	11.06	1.24	179.51	13.69
11	5.05	52.26	7.48	10.91	1.84	77634.81	16.02	10.70	1.22	178.20	13.40
12	4.99	53.03	7.10	11.10	1.87	76150.34	16.37	10.88	1.24	178.56	13.46
13	4.98	53.99	5.31	11.11	1.86	76187.41	16.45	10.62	1.24	178.00	13.49
14	4.71	54.59	5.79	11.11	1.87	76658.57	16.35	11.31	1.24	178.84	13.58
15	4.88	53.20	6.44	11.12	1.83	76275.86	16.07	10.49	1.22	180.66	13.53
16	4.72	53.40	7.39	11.23	1.81	75231.70	16.10	10.22	1.21	179.79	13.47
17	4.99	53.25	8.05	11.46	1.83	73357.72	15.53	10.64	1.22	178.58	13.33
18	5.09	51.08	7.28	11.08	1.87	75276.49	16.12	11.81	1.24	177.79	13.23
19	4.14	52.73	8.22	11.24	1.81	75081.15	16.73	10.53	1.20	179.08	13.56
20	4.90	52.51	8.85	11.46	1.76	73608.57	16.12	11.00	1.17	178.11	13.46
21	4.90	52.41	7.40	11.34	1.77	73806.54	16.41	10.92	1.77	179.17	13.41
22	4.73	52.20	4.98	11.31	1.76	73193.12	16.37	10.58	1.17	177.98	13.23
23	4.91	52.36	6.40	11.45	1.74	74640.24	15.63	9.70	1.17	178.12	13.56
24	4.87	51.00	6.30	11.28	1.75	75901.55	15.97	10.03	1.17	179.37	13.63
25	4.82	51.45	8.20	11.26	1.71	75268.86	16.21	10.40	1.14	179.79	13.55
26	4.43	54.60	9.82	11.22	1.77	75070.50	16.50	10.88	1.18	180.31	13.51
27	4.64	54.87	8.12	11.19	1.75	75266.99	16.20	10.40	1.17	179.58	13.43
28	4.74	53.73	8.81	11.08	1.74	75908.94	16.36	10.52	1.16	179.55	13.42
29	4.58	51.02	7.15	10.94	1.73	74867.38	16.53	10.24	1.16	177.53	13.03
30	4.71	50.88	9.05	11.09	1.76	75299.39	16.36	10.50	1.18	179.21	13.32
31	4.73	49.08	6.83	11.18	1.69	74994.66	16.32	10.05	1.13	178.65	13.37
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.82	52.78	7.13	11.13	1.81	75899.09	16.36	10.72	1.23	178.77	13.44
最大值	5.21	55.57	9.82	11.71	1.98	78490.86	17.10	12.74	1.77	180.66	13.69
發生日期											
最小值	4.14	49.08	4.98	10.75	1.69	73193.12	15.53	9.70	1.13	176.84	13.03
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國112年5月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	5.51	50.82	6.98	10.86	1.49	81654.09	16.66	10.46	0.99	188.77	14.47
02	6.96	51.04	7.39	10.96	1.44	79990.32	17.49	9.14	0.96	190.05	14.50
03	4.82	50.84	7.43	11.17	1.48	77985.80	17.39	11.01	0.98	189.43	14.41
04	5.54	52.51	8.77	11.09	1.56	77547.59	17.25	12.07	1.04	187.45	14.12
05	4.77	52.80	7.40	11.28	1.50	76892.76	17.43	11.07	1.00	188.99	14.35
06	3.45	50.46	7.86	11.27	1.45	76528.22	17.16	10.80	0.97	187.70	14.20
07	4.05	49.94	8.86	11.09	1.47	78308.83	17.59	12.16	0.98	187.76	14.34
08	5.26	47.72	8.03	11.03	1.50	79385.35	17.08	10.61	1.00	187.35	14.34
09	4.17	51.67	9.00	11.09	1.50	79913.11	17.31	10.64	1.00	188.76	14.60
10	4.37	50.65	8.41	10.84	1.49	81200.05	17.72	11.04	0.99	189.23	14.56
11	5.33	47.86	8.68	10.89	1.48	79775.52	17.12	11.27	0.99	187.34	14.22
12	4.75	51.23	9.06	11.17	1.48	78503.47	17.45	11.59	0.98	188.76	14.49
13	4.51	53.09	6.83	11.20	1.42	78595.69	17.37	11.68	0.95	188.18	14.52
14	4.36	53.37	6.96	11.05	1.37	79747.34	17.64	12.13	0.91	188.51	14.57
15	4.43	51.04	8.44	10.94	1.36	79768.37	17.64	10.32	0.91	188.34	14.41
16	4.49	50.38	9.97	11.17	1.37	77982.14	17.12	10.20	0.91	188.04	14.33
17	3.33	48.09	10.01	10.98	1.39	78264.97	17.56	10.47	0.93	189.45	14.22
18	4.76	48.59	9.26	10.89	1.44	78345.73	17.20	12.15	0.96	186.85	13.96
19	3.58	50.32	8.76	10.98	1.52	78809.39	18.20	11.08	1.01	187.66	14.38
20	4.19	49.73	9.90	11.04	1.55	78258.65	17.98	11.17	1.03	187.05	14.31
21	4.29	49.42	9.52	10.89	1.52	78590.11	18.32	11.39	1.01	187.55	14.22
22	4.23	49.14	8.23	10.89	1.49	78520.45	17.98	10.91	0.99	186.69	14.11
23	3.88	52.45	8.49	11.19	1.46	78664.60	17.74	9.84	0.98	188.00	14.58
24	4.02	53.23	9.03	11.18	1.45	79921.03	17.16	9.99	0.97	190.23	14.78
25	3.86	51.61	8.50	10.89	1.45	79770.37	17.98	10.99	0.96	188.70	14.41
26	3.88	53.67	8.50	10.94	1.40	79105.27	17.96	12.23	0.94	188.70	14.35
27	3.67	52.76	8.42	10.95	1.43	79151.84	17.60	10.53	0.95	188.43	14.31
28	3.60	51.88	8.98	10.84	1.43	79296.05	18.01	10.30	0.95	188.43	14.25
29	3.63	49.17	7.74	10.81	1.40	78335.90	17.78	10.51	0.93	186.61	13.94
30	3.68	51.26	8.07	10.92	1.38	78296.21	17.92	10.02	0.92	187.60	14.13
31	3.97	50.97	8.64	10.95	1.37	78338.74	17.98	10.46	0.91	187.43	14.20
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.37	50.89	8.46	11.01	1.45	78885.42	17.57	10.91	0.97	188.19	14.34
最大值	6.96	53.67	10.01	11.28	1.56	81654.09	18.32	12.23	1.04	190.23	14.78
發生日期											
最小值	3.33	47.72	6.83	10.81	1.36	76528.22	16.66	9.14	0.91	186.61	13.94
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管