

連續自動監測紀錄月報表

中華民國112年9月30日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	5.62	56.36	9.05	11.67	1.13	69951.04	14.98	8.53	1.89	178.68	12.93
02	5.81	56.18	8.05	11.95	1.10	69354.02	14.68	8.45	1.83	179.71	13.17
03	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐
04	5.54	63.96	7.83	12.12	1.03	70964.54	14.58	8.39	1.72	183.64	13.86
05	5.51	55.68	8.48	11.88	1.02	72782.10	15.02	7.98	1.71	182.60	13.89
06	5.52	56.65	8.95	11.44	0.98	73864.28	15.25	7.95	1.64	178.84	13.37
07	5.67	53.98	8.60	11.08	1.00	76843.02	15.69	8.45	1.67	179.25	13.48
08	5.25	55.64	9.71	10.97	1.05	78281.01	16.00	9.21	1.75	180.15	13.66
09	5.01	50.71	8.37	10.93	1.07	78490.71	16.39	8.42	1.78	180.90	13.73
10	4.76	47.79	8.11	10.76	1.09	79542.14	16.66	8.28	1.81	181.36	13.73
11	4.70	49.60	6.78	10.67	1.11	80069.35	16.79	8.68	1.76	180.95	13.71
12	4.80	48.58	8.02	10.77	1.20	78819.81	16.75	8.51	0.95	181.38	13.64
13	4.51	45.19	8.67	10.84	1.18	78441.33	16.93	8.48	0.91	181.75	13.70
14	5.18	45.63	9.07	11.26	1.18	75333.22	15.49	8.58	0.91	180.50	13.46
15	5.46	43.98	8.74	11.48	1.16	74343.18	15.25	8.49	0.89	180.71	13.56
16	5.48	44.05	8.55	11.56	1.16	73308.28	15.05	8.95	0.89	180.10	13.43
17	5.23	43.19	8.63	11.75	1.16	71843.69	14.95	8.43	0.90	180.60	13.48
18	5.44	47.41	9.41	11.73	1.16	71797.58	15.10	8.34	0.88	180.23	13.39
19	5.38	51.95	8.45	11.79	1.14	71662.62	14.73	8.88	0.89	180.89	13.49
20	5.60	48.15	9.30	11.92	1.16	70690.17	14.54	8.37	0.89	183.00	13.50
21	5.81	46.82	8.60	11.94	1.16	69867.59	14.39	8.75	0.89	179.67	13.24
22	5.98	50.79	9.67	12.21	1.16	69038.07	14.63	8.78	0.88	180.61	13.50
23	5.73	53.00	8.88	12.06	1.14	70355.42	17.48	8.52	0.88	181.45	13.58
24	5.68	50.36	9.10	11.88	1.16	71101.27	14.75	8.51	0.89	180.91	13.46
25	5.91	51.28	8.38	12.11	1.14	69538.30	14.31	8.12	0.88	180.55	13.43
26	5.92	50.23	9.74	12.10	1.15	69228.19	14.20	8.26	0.88	179.75	13.32
27	6.05	50.02	8.93	11.99	1.14	68677.01	14.57	9.13	0.88	178.08	13.04
28	6.07	54.20	8.60	11.99	1.16	70261.00	14.28	9.07	0.90	179.33	13.32
29	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐
30	8.36	39.03	13.20	15.06	1.22	82201.58	9.90	5.65	0.94	155.41	13.65
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	5.57	50.37	8.85	11.71	1.13	73451.80	15.12	8.43	1.20	179.68	13.49
最大值	8.36	63.96	13.20	15.06	1.22	82201.58	17.48	9.21	1.89	183.64	13.89
發生日期											
最小值	4.51	39.03	6.78	10.67	0.98	68677.01	9.90	5.65	0.88	155.41	12.93
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國112年9月30日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	4.91	55.76	8.86	11.13	1.45	76104.78	17.11	7.00	2.43	187.23	13.90
02	5.05	54.29	8.96	11.10	1.46	76305.62	16.91	8.15	2.43	186.08	13.81
03	5.09	52.54	10.29	10.84	1.41	80499.08	17.23	7.36	2.35	185.58	14.25
04	4.56	53.79	10.03	10.90	1.38	78570.60	17.22	8.05	2.29	190.17	14.11
05	3.86	49.84	10.36	10.96	1.34	78163.01	17.94	8.15	2.23	189.38	14.23
06	4.01	49.86	9.35	10.93	1.31	78646.92	17.93	8.54	2.18	189.93	14.29
07	4.46	45.84	10.25	10.70	1.29	80215.40	18.09	9.51	2.15	189.47	14.26
08	4.31	48.76	9.33	10.93	1.34	78885.80	17.93	10.40	2.22	189.43	14.32
09	4.15	52.03	8.08	11.09	1.38	78212.80	17.09	7.40	2.30	188.89	14.27
10	4.14	48.98	9.36	10.91	1.39	79434.04	17.67	8.91	2.32	189.85	14.36
11	4.38	47.75	10.51	10.80	1.27	80258.71	17.66	9.34	2.29	188.97	14.31
12	4.48	46.58	10.21	10.83	1.17	79851.58	17.25	8.44	0.91	188.80	14.22
13	4.04	42.54	10.76	10.67	1.15	80598.04	17.94	8.72	0.88	190.84	14.31
14	4.14	41.08	9.24	10.51	1.10	80717.02	17.96	8.63	0.85	189.52	14.08
15	3.69	42.02	10.13	10.70	1.11	79892.25	17.64	8.06	0.85	191.55	14.20
16	3.26	42.68	9.97	10.78	1.15	79346.66	17.55	9.04	0.89	190.67	14.17
17	3.81	40.14	9.33	10.70	1.17	79322.06	18.10	8.21	0.90	189.90	14.13
18	4.04	39.52	9.00	10.59	1.10	80224.56	17.59	7.75	0.85	189.40	14.03
19	3.75	42.72	9.29	10.71	1.04	79845.90	17.78	7.23	0.80	190.81	14.20
20	4.29	41.14	10.07	10.80	1.11	79219.91	17.59	7.16	0.85	190.22	14.17
21	4.67	47.08	9.86	11.03	1.16	79579.67	16.75	8.49	0.90	191.32	14.44
22	4.19	44.29	8.84	10.89	1.15	78956.86	17.35	7.92	0.89	190.23	14.21
23	4.04	43.59	9.84	10.84	1.14	79401.62	17.48	8.12	0.88	190.84	14.26
24	4.52	41.69	10.63	10.68	1.14	79922.77	17.55	10.39	0.88	190.71	14.14
25	3.69	42.77	9.23	10.78	1.13	79201.13	17.15	6.63	0.87	190.17	14.05
26	4.97	48.27	10.72	10.97	1.17	78489.38	16.80	7.80	0.90	190.16	14.15
27	5.78	51.98	9.40	10.85	1.19	79773.41	17.19	10.00	0.91	189.99	14.27
28	4.60	51.94	10.22	10.82	1.18	79301.30	17.10	9.16	0.91	189.97	14.11
29	4.86	48.70	9.70	10.70	1.19	80875.82	17.20	9.45	0.92	190.31	14.27
30	3.96	47.31	9.32	10.77	1.20	80261.86	17.50	6.59	0.92	189.48	14.28
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	4.32	46.85	9.70	10.83	1.23	79335.95	17.48	8.35	1.40	189.66	14.19
最大值	5.78	55.76	10.76	11.13	1.46	80875.82	18.10	10.40	2.43	191.55	14.44
發生日期											
最小值	3.26	39.52	8.08	10.51	1.04	76104.78	16.75	6.59	0.80	185.58	13.81
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管